



BARNARD ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

| | Building Location: Building Name | RECORD ID | Date Analyzed | Floor | Device Type | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ppb) |
|----|----------------------------------|------------|---------------|-------|------------------|--------------------------|----------------------|-------------------------------|----------------------|-------------------------------|
| 1 | BARNARD ELEMENTARY SCHOOL | WS- 001182 | 12/13/2016 | 1 | Break Room | In staff lounge room 122 | FT-102016-001182-A | < 1 | FT-102016-001182-B | < 1 |
| 2 | BARNARD ELEMENTARY SCHOOL | WS- 002475 | 12/13/2016 | 1 | Break Room | In staff lounge 158 | FT-102016-002475-A | < 1 | FT-102016-002475-B | < 1 |
| 3 | BARNARD ELEMENTARY SCHOOL | WS- 001154 | 12/13/2016 | 1 | Classroom Faucet | In classroom 105 | FT-122016-001154-A | 1.3 | FT-122016-001154-B | < 1 |
| 4 | BARNARD ELEMENTARY SCHOOL | WS- 001165 | 12/13/2016 | 1 | Classroom Faucet | In classroom 114 | FT-122016-001165-A | < 1 | FT-122016-001165-B | < 1 |
| 5 | BARNARD ELEMENTARY SCHOOL | WS- 001174 | 12/13/2016 | 1 | Classroom Faucet | In classroom 120 | FT-122016-001174-A | < 1 | FT-122016-001174-B | < 1 |
| 6 | BARNARD ELEMENTARY SCHOOL | WS- 001163 | 12/13/2016 | 1 | Classroom Faucet | In classroom 113 | FT-122016-001163-A | < 1 | FT-122016-001163-B | < 1 |
| 7 | BARNARD ELEMENTARY SCHOOL | WS- 001167 | 12/13/2016 | 1 | Classroom Faucet | In classroom 115 | FT-122016-001167-A | < 1 | FT-122016-001167-B | < 1 |
| 8 | BARNARD ELEMENTARY SCHOOL | WS- 001172 | 12/13/2016 | 1 | Classroom Faucet | In classroom 119 | FT-122016-001172-A | < 1 | FT-122016-001172-B | < 1 |
| 9 | BARNARD ELEMENTARY SCHOOL | WS- 001168 | 12/13/2016 | 1 | Classroom Faucet | In classroom 116 | FT-122016-001168-A | < 1 | FT-122016-001168-B | < 1 |
| 10 | BARNARD ELEMENTARY SCHOOL | WS- 001161 | 12/13/2016 | 1 | Classroom Faucet | In classroom 112 | FT-122016-001161-A | < 1 | FT-122016-001161-B | < 1 |
| 11 | BARNARD ELEMENTARY SCHOOL | WS- 001170 | 12/13/2016 | 1 | Classroom Faucet | In classroom 118 | FT-122016-001170-A | < 1 | FT-122016-001170-B | < 1 |
| 12 | BARNARD ELEMENTARY SCHOOL | WS- 001169 | 12/13/2016 | 1 | Classroom Faucet | In classroom 117 | FT-122016-001169-A | < 1 | FT-122016-001169-B | < 1 |
| 13 | BARNARD ELEMENTARY SCHOOL | WS- 001157 | 12/13/2016 | 1 | Classroom Faucet | In classroom 110 | FT-122016-001157-A | 3.1 | FT-122016-001157-B | < 1 |
| 14 | BARNARD ELEMENTARY SCHOOL | WS- 001151 | 12/13/2016 | 1 | Classroom Faucet | In classroom 104 | FT-122016-001151-A | < 1 | FT-122016-001151-B | < 1 |
| 15 | BARNARD ELEMENTARY SCHOOL | WS- 001159 | 12/13/2016 | 1 | Classroom Faucet | In classroom 111 | FT-122016-001159-A | < 1 | FT-122016-001159-B | < 1 |
| 16 | BARNARD ELEMENTARY SCHOOL | WS- 001155 | 12/13/2016 | 1 | Classroom Faucet | In classroom 109 | FT-122016-001155-A | < 1 | FT-122016-001155-B | < 1 |
| 17 | BARNARD ELEMENTARY SCHOOL | WS- 001152 | 12/13/2016 | 1 | Classroom Faucet | In classroom 106 | FT-122016-001152-A | 1.1 | FT-122016-001152-B | < 1 |

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

| | | | | | | | | | | |
|----|---------------------------|------------|-----------|---|------------------|------------------|--------------------|-----|--------------------|-----|
| 3 | BARNARD ELEMENTARY SCHOOL | WS- 001154 | 1/25/2017 | 1 | Classroom Faucet | In classroom 105 | FT-122016-001154-A | < 1 | FT-122016-001154-B | < 1 |
| 13 | BARNARD ELEMENTARY SCHOOL | WS- 001157 | 1/25/2017 | 1 | Classroom Faucet | In classroom 110 | FT-122016-001157-A | < 1 | FT-122016-001157-B | < 1 |
| 17 | BARNARD ELEMENTARY SCHOOL | WS- 001152 | 1/25/2017 | 1 | Classroom Faucet | In classroom 106 | FT-122016-001152-A | < 1 | FT-122016-001152-B | < 1 |

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb