



Barnard ES Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001156	5/31/2017	5/31/2018	1	Combo Fountain	In classroom 109 in bathroom	WF-52017-001156	11/9/2017	FT-FY18--52017-001156-A	<1	FT-FY18--52017-001156-B	<1
WS- 001162	5/31/2017	5/31/2018	1	Combo Fountain	In classroom 112 in bathroom	WF-52017-001162	11/9/2017	FT-FY18--52017-001162-A	<1	FT-FY18--52017-001162-B	<1
WS- 001168	10/24/2017	10/24/2018	1	Classroom Faucet	In classroom 116	WF-102017-001168	11/9/2017	FT-FY18-102017-001168-A	<1	FT-FY18-102017-001168-B	<1
WS- 001171	5/31/2017	5/31/2018	1	Combo Fountain	In classroom 118 in bathroom	WF-52017-001171	11/9/2017	FT-FY18--52017-001171-A	<1	FT-FY18--52017-001171-B	<1
WS- 001172	10/24/2017	10/24/2018	1	Classroom Faucet	In classroom 119	WF-102017-001172	11/9/2017	FT-FY18-102017-001172-A	<1	FT-FY18-102017-001172-B	<1
WS- 001174	10/24/2017	10/24/2018	1	Classroom Faucet	In classroom 120	WF-102017-001174	11/9/2017	FT-FY18-102017-001174-A	<1	FT-FY18-102017-001174-B	<1
WS- 001176	5/31/2017	5/31/2018	1	Cooler	In hallway adjacent to room 121	WF-52017-001176	11/9/2017	FT-FY18--52017-001176-A	<1	FT-FY18--52017-001176-B	<1
WS- 001180	5/31/2017	5/31/2018	1	Cooler	In hallway adjacent to girls' restroom	WF-52017-001180	11/9/2017	FT-FY18--52017-001180-A	<1	FT-FY18--52017-001180-B	<1
WS- 001181	5/31/2017	5/31/2018	1	Cooler	In hallway adjacent to girls' restroom	WF-52017-001181	11/9/2017	FT-FY18--52017-001181-A	<1	FT-FY18--52017-001181-B	<1
WS- 001188	5/31/2017	5/31/2018	1	Health Suite	In health suite 157	WF-52017-001188	11/9/2017	FT-FY18--52017-001188-A	<1	FT-FY18--52017-001188-B	<1
WS- 001208	5/31/2017	5/31/2018	2	Cooler	In hallway adjacent room 210	WF-52017-001208	11/9/2017	FT-FY18--52017-001208-A	<1	FT-FY18--52017-001208-B	<1
WS- 001210	5/31/2017	5/31/2018	2	Cooler	In hallway adjacent to room 206	WF-52017-001210	11/9/2017	FT-FY18--52017-001210-A	<1	FT-FY18--52017-001210-B	<1
WS- 001213	5/31/2017	5/31/2018	2	Cooler	In hallway adjacent to art room 239	WF-52017-001213	11/9/2017	FT-FY18--52017-001213-A	<1	FT-FY18--52017-001213-B	<1
WS- 001214	5/31/2017	5/31/2018	1	Cooler	Annex B, in hallway	WF-52017-001214	11/9/2017	FT-FY18--52017-001214-A	<1	FT-FY18--52017-001214-B	<1
WS- 002475	5/31/2017	5/31/2018	1	Break Room	In staff lounge 158	WF-52017-002475	11/9/2017	FT-FY18--52017-002475-A	<1	FT-FY18--52017-002475-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation

RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 001185	1	Food Prep Sink	In kitchen south wall Mid	11/9/2017	FT-FY18-102017-001185-A	<1	FT-FY18-102017-001185-B	<1