



Barry Farm RC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006114	5/9/2018	5/9/2019	1	Cooler	In pool area	High Left	WF-05092018-006114	3/19/2019	FT-FY19-032019-006114-A	<1	FT-FY19-032019-006114-B	<1
WS- 006115	5/9/2018	5/9/2019	1	Cooler	In pool area	Right	WF-05092018-006115	3/19/2019	FT-FY19-032019-006115-A	<1	FT-FY19-032019-006115-B	<1
WS- 006116	5/9/2018	5/9/2019	1	Break Room	In seniors' lounge		WF-05092018-006116	3/19/2019	FT-FY19-032019-006116-A	<1	FT-FY19-032019-006116-B	<1
WS- 006118	5/9/2018	5/9/2019	1	Cooler	In hallway adjacent to seniors' lounge	High Left	WF-05092018-006118	3/19/2019	FT-FY19-032019-006118-A	<1	FT-FY19-032019-006118-B	<1
WS- 006119	5/9/2018	5/9/2019	1	Cooler	In hallway adjacent to seniors' lounge	Low Right	WF-05092018-006119	3/19/2019	FT-FY19-032019-006119-A	<1	FT-FY19-032019-006119-B	<1
WS- 006121	5/9/2018	5/9/2019	1	Cooler	In hallway adjacent to gym entrance	High Left	WF-05092018-006121	3/19/2019	FT-FY19-032019-006121-A	<1	FT-FY19-032019-006121-B	<1
WS- 006122	5/9/2018	5/9/2019	1	Cooler	In hallway adjacent to gym entrance	Low Right	WF-05092018-006122	3/19/2019	FT-FY19-032019-006122-A	<1	FT-FY19-032019-006122-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 006112	5/9/2018	5/9/2019	1	Food Prep Sink	In kitchen	Left	WF-05092018-006112	3/19/2019	FT-FY19-032019-006112-A	<1	FT-FY19-032019-006112-B	<1
WS- 006113	5/9/2018	5/9/2019	1	Food Prep Sink	In kitchen	Right	WF-05092018-006113	3/19/2019	FT-FY19-032019-006113-A	<1	FT-FY19-032019-006113-B	<1