



BARRY FARM REC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BARRY FARM RECREATION CENTER	WS- 006112	9/21/2016	1	Food Prep Sink	In kitchen Left	FT-82016-006112-A	< 1	FT-82016-006112-B	< 1
2	BARRY FARM RECREATION CENTER	WS- 006113	9/21/2016	1	Food Prep Sink	In kitchen Right	FT-82016-006113-A	< 1	FT-82016-006113-B	< 1
3	BARRY FARM RECREATION CENTER	WS- 006114	9/21/2016	1	Cooler	In pool area High Left	FT-82016-006114-A	< 1	FT-82016-006114-B	< 1
4	BARRY FARM RECREATION CENTER	WS- 006115	9/21/2016	1	Cooler	In pool area Right	FT-82016-006115-A	< 1	FT-82016-006115-B	< 1
5	BARRY FARM RECREATION CENTER	WS- 006116	9/21/2016	1	Break Room	In seniors' lounge	FT-82016-006116-A	< 1	FT-82016-006116-B	< 1
6	BARRY FARM RECREATION CENTER	WS- 006117	9/21/2016	1	Ice Maker	In seniors' lounge (ice maker)	FT-82016-006117-A	< 1	FT-82016-006117-B	< 1
7	BARRY FARM RECREATION CENTER	WS- 006118	9/21/2016	1	Cooler	In hallway adjacent to seniors' lounge High Left	FT-82016-006118-A	< 1	FT-82016-006118-B	< 1
8	BARRY FARM RECREATION CENTER	WS- 006119	9/21/2016	1	Cooler	In hallway adjacent to seniors' lounge Low Right	FT-82016-006119-A	< 1	FT-82016-006119-B	< 1
9	BARRY FARM RECREATION CENTER	WS- 006121	9/21/2016	1	Cooler	In hallway adjacent to gym entrance High Left	FT-82016-006121-A	< 1	FT-82016-006121-B	< 1
10	BARRY FARM RECREATION CENTER	WS- 006122	9/21/2016	1	Cooler	In hallway adjacent to gym entrance Low Right	FT-82016-006122-A	< 1	FT-82016-006122-B	< 1