



Beers Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004468	4/6/2020	4/6/2021	Basement	Cooler	In cafeteria High Left	WF-04062020-004468	1/13/2021	FT-FY21-012021-004468-A	<1	FT-FY21-012021-004468-B	<1
WS-004469	4/6/2020	4/6/2021	Basement	Cooler	In cafeteria Low Right	WF-04062020-004469	1/13/2021	FT-FY21-012021-004469-A	<1	FT-FY21-012021-004469-B	<1
WS-004472	4/6/2020	4/6/2021	1	Cooler	In hallway across from room D102	WF-04062020-004472	1/13/2021	FT-FY21-012021-004472-A	<1	FT-FY21-012021-004472-B	<1
WS-004473	4/6/2020	4/6/2021	1	Cooler	In hallway across from room D108	WF-04062020-004473	1/13/2021	FT-FY21-012021-004473-A	<1	FT-FY21-012021-004473-B	<1
WS-004476	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to auditorium C101 High Left	WF-04062020-004476	1/13/2021	FT-FY21-012021-004476-A	<1	FT-FY21-012021-004476-B	<1
WS-004477	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to auditorium C102 Low Right	WF-04062020-004477	1/13/2021	FT-FY21-012021-004477-A	<1	FT-FY21-012021-004477-B	<1
WS-004478	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room B101 High Left	WF-04062020-004478	1/13/2021	FT-FY21-012021-004478-A	<1	FT-FY21-012021-004478-B	<1
WS-004479	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room B102 Low Right	WF-04062020-004479	1/13/2021	FT-FY21-012021-004479-A	<1	FT-FY21-012021-004479-B	<1
WS-004480	4/6/2020	4/6/2021	1	Cooler	In classroom A109	WF-04062020-004480	1/13/2021	FT-FY21-012021-004480-A	<1	FT-FY21-012021-004480-B	<1
WS-004481	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom A109	WF-09142020-004481	1/13/2021	FT-FY21-012021-004481-A	<1	FT-FY21-012021-004481-B	<1
WS-004482	4/6/2020	4/6/2021	1	Cooler	In classroom A108	WF-04062020-004482	1/13/2021	FT-FY21-012021-004482-A	<1	FT-FY21-012021-004482-B	<1
WS-004483	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom A108	WF-09142020-004483	1/13/2021	FT-FY21-012021-004483-A	3.2	FT-FY21-012021-004483-B	<1
WS-004484	4/6/2020	4/6/2021	1	Cooler	In hallway across from room A110	WF-04062020-004484	1/13/2021	FT-FY21-012021-004484-A	<1	FT-FY21-012021-004484-B	<1
WS-004485	4/6/2020	4/6/2021	1	Cooler	In classroom A110	WF-04062020-004485	1/13/2021	FT-FY21-012021-004485-A	<1	FT-FY21-012021-004485-B	<1
WS-004486	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom A110	WF-09142020-004486	1/13/2021	FT-FY21-012021-004486-A	<1	FT-FY21-012021-004486-B	<1
WS-004487	4/6/2020	4/6/2021	1	Cooler	In health suite A115	WF-04062020-004487	1/13/2021	FT-FY21-012021-004487-A	<1	FT-FY21-012021-004487-B	<1
WS-004488	4/6/2020	4/6/2021	1	Health Suite	In health suite A115	WF-04062020-004488	1/13/2021	FT-FY21-012021-004488-A	<1	FT-FY21-012021-004488-B	<1
WS-004489	4/6/2020	4/6/2021	1	Cooler	In classroom A112	WF-04062020-004489	1/13/2021	FT-FY21-012021-004489-A	<1	FT-FY21-012021-004489-B	<1
WS-004490	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom A112	WF-09142020-004490	1/13/2021	FT-FY21-012021-004490-A	<1	FT-FY21-012021-004490-B	<1
WS-004491	4/6/2020	4/6/2021	1	Cooler	In classroom A119	WF-04062020-004491	1/13/2021	FT-FY21-012021-004491-A	<1	FT-FY21-012021-004491-B	<1
WS-004493	4/6/2020	4/6/2021	1	Cooler	In hallway across from room B106	WF-04062020-004493	1/13/2021	FT-FY21-012021-004493-A	<1	FT-FY21-012021-004493-B	<1
WS-004494	4/6/2020	4/6/2021	2	Cooler	In hallway across from room B208	WF-04062020-004494	1/13/2021	FT-FY21-012021-004494-A	<1	FT-FY21-012021-004494-B	<1
WS-004495	4/6/2020	4/6/2021	2	Cooler	In classroom B209	WF-04062020-004495	1/13/2021	FT-FY21-012021-004495-A	<1	FT-FY21-012021-004495-B	<1
WS-004496	9/14/2020	9/14/2021	2	Classroom Faucet	In classroom B209	WF-09142020-004496	1/13/2021	FT-FY21-012021-004496-A	<1	FT-FY21-012021-004496-B	<1
WS-004497	4/6/2020	4/6/2021	2	Cooler	In hallway adjacent to room B201 Low Right	WF-04062020-004497	1/13/2021	FT-FY21-012021-004497-A	<1	FT-FY21-012021-004497-B	<1
WS-004498	4/6/2020	4/6/2021	2	Cooler	In hallway adjacent to room B201 High Left	WF-04062020-004498	1/13/2021	FT-FY21-012021-004498-A	<1	FT-FY21-012021-004498-B	<1
WS-004499	6/30/2020	6/30/2021	2	Cooler	In classroom A205	WF-06302020-004499	1/13/2021	FT-FY21-012021-004499-A	<1	FT-FY21-012021-004499-B	<1
WS-004500	9/14/2020	9/14/2021	2	Classroom Faucet	In classroom A205	WF-09142020-004500	1/13/2021	FT-FY21-012021-004500-A	2.0	FT-FY21-012021-004500-B	<1
WS-004501	4/6/2020	4/6/2021	2	Cooler	In hallway across from room A207	WF-04062020-004501	1/13/2021	FT-FY21-012021-004501-A	<1	FT-FY21-012021-004501-B	<1
WS-004502	4/6/2020	4/6/2021	2	Cooler	In classroom A207	WF-04062020-004502	1/13/2021	FT-FY21-012021-004502-A	<1	FT-FY21-012021-004502-B	<1
WS-004503	9/14/2020	9/14/2021	2	Classroom Faucet	In classroom A207	WF-09142020-004503	1/13/2021	FT-FY21-012021-004503-A	3.2	FT-FY21-012021-004503-B	<1
WS-004504	4/6/2020	4/6/2021	2	Cooler	In classroom A214	WF-04062020-004504	1/13/2021	FT-FY21-012021-004504-A	<1	FT-FY21-012021-004504-B	<1

WS- 004505	9/14/2020	9/14/2021	2	Classroom Faucet	In classroom A214	WF-09142020-004505	1/13/2021	FT-FY21-012021-004505-A	<1	FT-FY21-012021-004505-B	<1	
WS- 004506	4/6/2020	4/6/2021	2	Cooler	In classroom A211	WF-04062020-004506	1/13/2021	FT-FY21-012021-004506-A	<1	FT-FY21-012021-004506-B	<1	
WS- 004507	9/14/2020	9/14/2021	2	Classroom Faucet	In classroom A211	WF-09142020-004507	1/13/2021	FT-FY21-012021-004507-A	<1	FT-FY21-012021-004507-B	<1	
WS- 004508	7/13/2020	7/13/2021	2	Cooler	In classroom A216	WF-07132020-004508	1/13/2021	FT-FY21-012021-004508-A	<1	FT-FY21-012021-004508-B	<1	
WS- 004510	9/14/2020	9/14/2021	2	Break Room	In staff lounge 202	WF-09142020-004510	1/13/2021	FT-FY21-012021-004510-A	<1	FT-FY21-012021-004510-B	<1	
WS- 004511	4/6/2020	4/6/2021	2	Cooler	In hallway adjacent to room D201	WF-04062020-004511	1/13/2021	FT-FY21-012021-004511-A	<1	FT-FY21-012021-004511-B	<1	
WS- 004512	4/6/2020	4/6/2021	2	Cooler	In hallway across from room D210	WF-04062020-004512	1/13/2021	FT-FY21-012021-004512-A	<1	FT-FY21-012021-004512-B	<1	
WS- 004513	9/14/2020	9/14/2021	2	Classroom Faucet	In art room D210	Left	WF-09142020-004513	1/13/2021	FT-FY21-012021-004513-A	<1	FT-FY21-012021-004513-B	<1
WS- 004514	9/14/2020	9/14/2021	2	Classroom Faucet	In art room D210	Right	WF-09142020-004514	1/13/2021	FT-FY21-012021-004514-A	<1	FT-FY21-012021-004514-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004471	2/24/2020	2/24/2021	Basement	Food Prep Sink	In kitchen	Right	WF-02242020-004471	1/13/2021	FT-FY21-012021-004471-A	<1	FT-FY21-012021-004471-B	<1

FY21 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004492	9/14/2020	9/14/2021	1	Classroom Faucet	In classroom A119	WF-09142020-004492	1/13/2021	FT-FY21-012021-004492-A	9.9	FT-FY21-012021-004492-B	<1