



Beers ES Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004468	4/17/2019	4/17/2020	Basement	Cooler	In cafeteria High Left	WF-04172019-004468	10/21/2019	FT-FY20-102019-004468-A	<1	FT-FY20-102019-004468-B	<1
WS- 004469	4/17/2019	4/17/2020	Basement	Cooler	In cafeteria Low Right	WF-04172019-004469	10/21/2019	FT-FY20-102019-004469-A	<1	FT-FY20-102019-004469-B	<1
WS- 004472	4/17/2019	4/17/2020	1	Cooler	In hallway across from room D102	WF-04172019-004472	10/21/2019	FT-FY20-102019-004472-A	<1	FT-FY20-102019-004472-B	<1
WS- 004473	4/17/2019	4/17/2020	1	Cooler	In hallway across from room D108	WF-04172019-004473	10/21/2019	FT-FY20-102019-004473-A	<1	FT-FY20-102019-004473-B	<1
WS- 004476	4/17/2019	4/17/2020	1	Cooler	In hallway adjacent to auditorium C101 High Left	WF-04172019-004476	10/21/2019	FT-FY20-102019-004476-A	<1	FT-FY20-102019-004476-B	<1
WS- 004477	4/17/2019	4/17/2020	1	Cooler	In hallway adjacent to auditorium C102 Low Right	WF-04172019-004477	10/21/2019	FT-FY20-102019-004477-A	<1	FT-FY20-102019-004477-B	<1
WS- 004478	4/17/2019	4/17/2020	1	Cooler	In hallway adjacent to room B101 High Left	WF-04172019-004478	10/21/2019	FT-FY20-102019-004478-A	<1	FT-FY20-102019-004478-B	<1
WS- 004479	4/17/2019	4/17/2020	1	Cooler	In hallway adjacent to room B102 Low Right	WF-04172019-004479	10/21/2019	FT-FY20-102019-004479-A	<1	FT-FY20-102019-004479-B	<1
WS- 004480	4/17/2019	4/17/2020	1	Cooler	In classroom A109	WF-04172019-004480	10/21/2019	FT-FY20-102019-004480-A	<1	FT-FY20-102019-004480-B	<1
WS- 004481	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom A109	WF-09232019-004481	10/21/2019	FT-FY20-102019-004481-A	<1	FT-FY20-102019-004481-B	<1
WS- 004482	4/17/2019	4/17/2020	1	Cooler	In classroom A108	WF-04172019-004482	10/21/2019	FT-FY20-102019-004482-A	<1	FT-FY20-102019-004482-B	<1
WS- 004483	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom A108	WF-09232019-004483	10/21/2019	FT-FY20-102019-004483-A	<1	FT-FY20-102019-004483-B	<1
WS- 004484	4/17/2019	4/17/2020	1	Cooler	In hallway across from room A110	WF-04172019-004484	10/21/2019	FT-FY20-102019-004484-A	<1	FT-FY20-102019-004484-B	<1
WS- 004485	4/17/2019	4/17/2020	1	Cooler	In classroom A110	WF-04172019-004485	10/21/2019	FT-FY20-102019-004485-A	<1	FT-FY20-102019-004485-B	<1
WS- 004486	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom A110	WF-09232019-004486	10/21/2019	FT-FY20-102019-004486-A	<1	FT-FY20-102019-004486-B	<1
WS- 004487	4/17/2019	4/17/2020	1	Cooler	In health suite A115	WF-04172019-004487	10/21/2019	FT-FY20-102019-004487-A	<1	FT-FY20-102019-004487-B	<1
WS- 004488	4/17/2019	4/17/2020	1	Health Suite	In health suite A115	WF-04172019-004488	10/21/2019	FT-FY20-102019-004488-A	<1	FT-FY20-102019-004488-B	<1
WS- 004489	4/17/2019	4/17/2020	1	Cooler	In classroom A112	WF-04172019-004489	10/21/2019	FT-FY20-102019-004489-A	<1	FT-FY20-102019-004489-B	<1
WS- 004490	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom A112	WF-09232019-004490	10/21/2019	FT-FY20-102019-004490-A	<1	FT-FY20-102019-004490-B	<1
WS- 004491	4/17/2019	4/17/2020	1	Cooler	In classroom A119	WF-04172019-004491	10/21/2019	FT-FY20-102019-004491-A	<1	FT-FY20-102019-004491-B	<1
WS- 004492	9/23/2019	9/23/2020	1	Classroom Faucet	In classroom A119	WF-09232019-004492	10/21/2019	FT-FY20-102019-004492-A	4.2	FT-FY20-102019-004492-B	<1
WS- 004493	4/17/2019	4/17/2020	1	Cooler	In hallway across from room B106	WF-04172019-004493	10/21/2019	FT-FY20-102019-004493-A	<1	FT-FY20-102019-004493-B	<1
WS- 004494	4/17/2019	4/17/2020	2	Cooler	In hallway across from room B208	WF-04172019-004494	10/21/2019	FT-FY20-102019-004494-A	<1	FT-FY20-102019-004494-B	<1
WS- 004495	4/17/2019	4/17/2020	2	Cooler	In classroom B209	WF-04172019-004495	10/21/2019	FT-FY20-102019-004495-A	<1	FT-FY20-102019-004495-B	<1
WS- 004496	9/23/2019	9/23/2020	2	Classroom Faucet	In classroom B209	WF-09232019-004496	10/21/2019	FT-FY20-102019-004496-A	2.4	FT-FY20-102019-004496-B	<1
WS- 004497	4/17/2019	4/17/2020	2	Cooler	In hallway adjacent to room B201 Low Right	WF-04172019-004497	10/21/2019	FT-FY20-102019-004497-A	<1	FT-FY20-102019-004497-B	<1
WS- 004498	4/17/2019	4/17/2020	2	Cooler	In hallway adjacent to room B201 High Left	WF-04172019-004498	10/21/2019	FT-FY20-102019-004498-A	<1	FT-FY20-102019-004498-B	<1
WS- 004499	4/17/2019	4/17/2020	2	Cooler	In classroom A205	WF-04172019-004499	10/21/2019	FT-FY20-102019-004499-A	<1	FT-FY20-102019-004499-B	<1
WS- 004500	9/23/2019	9/23/2020	2	Classroom Faucet	In classroom A205	WF-09232019-004500	10/21/2019	FT-FY20-102019-004500-A	<1	FT-FY20-102019-004500-B	<1
WS- 004501	4/17/2019	4/17/2020	2	Cooler	In hallway across from room A207	WF-04172019-004501	10/21/2019	FT-FY20-102019-004501-A	<1	FT-FY20-102019-004501-B	<1
WS- 004502	4/17/2019	4/17/2020	2	Cooler	In classroom A207	WF-04172019-004502	10/21/2019	FT-FY20-102019-004502-A	<1	FT-FY20-102019-004502-B	<1
WS- 004503	9/23/2019	9/23/2020	2	Classroom Faucet	In classroom A207	WF-09232019-004503	10/21/2019	FT-FY20-102019-004503-A	<1	FT-FY20-102019-004503-B	<1
WS- 004504	4/17/2019	4/17/2020	2	Cooler	In classroom A214	WF-04172019-004504	10/21/2019	FT-FY20-102019-004504-A	<1	FT-FY20-102019-004504-B	<1

WS- 004505	9/23/2019	9/23/2020	2	Classroom Faucet	In classroom A214	WF-09232019-004505	10/21/2019	FT-FY20-102019-004505-A	1.4	FT-FY20-102019-004505-B	<1	
WS- 004506	4/17/2019	4/17/2020	2	Cooler	In classroom A211	WF-04172019-004506	10/21/2019	FT-FY20-102019-004506-A	<1	FT-FY20-102019-004506-B	<1	
WS- 004507	9/23/2019	9/23/2020	2	Classroom Faucet	In classroom A211	WF-09232019-004507	10/21/2019	FT-FY20-102019-004507-A	<1	FT-FY20-102019-004507-B	<1	
WS- 004508	4/17/2019	4/17/2020	2	Cooler	In classroom A216	WF-04172019-004508	10/21/2019	FT-FY20-102019-004508-A	<1	FT-FY20-102019-004508-B	<1	
WS- 004510	9/23/2019	9/23/2020	2	Break Room	In staff lounge 202	WF-09232019-004510	10/21/2019	FT-FY20-102019-004510-A	1.3	FT-FY20-102019-004510-B	<1	
WS- 004511	4/17/2019	4/17/2020	2	Cooler	In hallway adjacent to room D201	WF-04172019-004511	10/21/2019	FT-FY20-102019-004511-A	<1	FT-FY20-102019-004511-B	<1	
WS- 004512	4/17/2019	4/17/2020	2	Cooler	In hallway across from room D210	WF-04172019-004512	10/21/2019	FT-FY20-102019-004512-A	<1	FT-FY20-102019-004512-B	<1	
WS- 004513	9/23/2019	9/23/2020	2	Classroom Faucet	In art room D210	Left	WF-09232019-004513	10/21/2019	FT-FY20-102019-004513-A	2.3	FT-FY20-102019-004513-B	<1
WS- 004514	9/23/2019	9/23/2020	2	Classroom Faucet	In art room D210	Right	WF-09232019-004514	10/21/2019	FT-FY20-102019-004514-A	2.4	FT-FY20-102019-004514-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 004471	7/1/2019	7/1/2020	Basement	Food Prep Sink	In kitchen	Right	WF-07012019-004471	10/21/2019	FT-FY20-102019-004471-A	<1	FT-FY20-102019-004471-B	<1