



# BEERS ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BEERS ELEMENTARY SCHOOL	WS- 004468	8/14/2016	Basement	Cooler	In cafeteria High Left	FT-72016-004468-A	< 1	FT-72016-004468-B	< 1
2	BEERS ELEMENTARY SCHOOL	WS- 004469	8/14/2016	Basement	Cooler	In cafeteria Low Right	FT-82016-004469-A	< 1	FT-82016-004469-B	< 1
3	BEERS ELEMENTARY SCHOOL	WS- 004471	8/14/2016	Basement	Food Prep Sink	In kitchen Right	FT-72016-004471-A	< 1	FT-72016-004471-B	< 1
4	BEERS ELEMENTARY SCHOOL	WS- 004472	8/14/2016	1	Cooler	In hallway across from room D102	FT-72016-004472-A	< 1	FT-72016-004472-B	< 1
5	BEERS ELEMENTARY SCHOOL	WS- 004473	8/14/2016	1	Cooler	In hallway across from room D108	FT-72016-004473-A	< 1	FT-72016-004473-B	< 1
6	BEERS ELEMENTARY SCHOOL	WS- 004476	8/14/2016	1	Cooler	In hallway adjacent to auditorium C101 High	FT-72016-004476-A	< 1	FT-72016-004476-B	< 1
7	BEERS ELEMENTARY SCHOOL	WS- 004477	8/14/2016	1	Cooler	In hallway adjacent to auditorium C102	FT-82016-004477-A	< 1	FT-82016-004477-B	< 1
8	BEERS ELEMENTARY SCHOOL	WS- 004478	8/14/2016	1	Cooler	In hallway adjacent to room B101 High	FT-72016-004478-A	< 1	FT-72016-004478-B	< 1
9	BEERS ELEMENTARY SCHOOL	WS- 004479	8/14/2016	1	Cooler	In hallway adjacent to room B102 Low	FT-82016-004479-A	< 1	FT-82016-004479-B	< 1
10	BEERS ELEMENTARY SCHOOL	WS- 004480	8/14/2016	1	Cooler	In classroom A109	FT-72016-004480-A	< 1	FT-72016-004480-B	< 1
11	BEERS ELEMENTARY SCHOOL	WS- 004482	8/14/2016	1	Cooler	In classroom A108	FT-72016-004482-A	< 1	FT-72016-004482-B	< 1
12	BEERS ELEMENTARY SCHOOL	WS- 004484	8/14/2016	1	Cooler	In hallway across from room A110	FT-72016-004484-A	< 1	FT-72016-004484-B	< 1
13	BEERS ELEMENTARY SCHOOL	WS- 004485	8/14/2016	1	Cooler	In classroom A110	FT-72016-004485-A	< 1	FT-72016-004485-B	< 1
14	BEERS ELEMENTARY SCHOOL	WS- 004487	8/14/2016	1	Cooler	In health suite A115	FT-72016-004487-A	< 1	FT-72016-004487-B	< 1
15	BEERS ELEMENTARY SCHOOL	WS- 004488	8/14/2016	1	Health Suite	In health suite A115	FT-72016-004488-A	< 1	FT-72016-004488-B	< 1
16	BEERS ELEMENTARY SCHOOL	WS- 004489	8/14/2016	1	Cooler	In classroom A112	FT-72016-004489-A	< 1	FT-72016-004489-B	< 1
17	BEERS ELEMENTARY SCHOOL	WS- 004491	8/14/2016	1	Cooler	In classroom A119	FT-72016-004491-A	2	FT-72016-004491-B	4.7
			10/10/2016				Re-test A	< 1	Re-test B	< 1
18	BEERS ELEMENTARY SCHOOL	WS- 004493	8/14/2016	1	Cooler	In hallway across from room B106	FT-72016-004493-A	< 1	FT-72016-004493-B	< 1
19	BEERS ELEMENTARY SCHOOL	WS- 004494	8/14/2016	2	Cooler	In hallway across from room B208	FT-72016-004494-A	< 1	FT-72016-004494-B	< 1
20	BEERS ELEMENTARY SCHOOL	WS- 004495	8/14/2016	2	Cooler	In classroom B209	FT-82016-004495-A	< 1	FT-82016-004495-B	< 1
21	BEERS ELEMENTARY SCHOOL	WS- 004497	8/14/2016	2	Cooler	In hallway adjacent to room B201 Low Right	FT-82016-004497-A	< 1	FT-82016-004497-B	< 1
22	BEERS ELEMENTARY SCHOOL	WS- 004498	8/14/2016	2	Cooler	In hallway adjacent to room B201 High Left	FT-72016-004498-A	< 1	FT-72016-004498-B	< 1
23	BEERS ELEMENTARY SCHOOL	WS- 004499	8/14/2016	2	Cooler	In classroom A205	FT-72016-004499-A	< 1	FT-72016-004499-B	< 1
24	BEERS ELEMENTARY SCHOOL	WS- 004501	8/14/2016	2	Cooler	In hallway across from room A207	FT-72016-004501-A	< 1	FT-72016-004501-B	< 1
25	BEERS ELEMENTARY SCHOOL	WS- 004502	8/14/2016	2	Cooler	In classroom A207	FT-72016-004502-A	< 1	FT-72016-004502-B	< 1
26	BEERS ELEMENTARY SCHOOL	WS- 004504	8/14/2016	2	Cooler	In classroom A214	FT-72016-004504-A	4.6	FT-72016-004504-B	2
			10/10/2016				Re-test A	< 1	Re-test B	< 1
27	BEERS ELEMENTARY SCHOOL	WS- 004506	8/14/2016	2	Cooler	In classroom A211	FT-72016-004506-A	< 1	FT-72016-004506-B	< 1
28	BEERS ELEMENTARY SCHOOL	WS- 004508	8/14/2016	2	Cooler	In classroom A216	FT-72016-004508-A	< 1	FT-72016-004508-B	1.2
			10/10/2016				Re-test A	< 1	Re-test B	< 1
29	BEERS ELEMENTARY SCHOOL	WS- 004511	8/14/2016	2	Cooler	In hallway adjacent to room D201	FT-72016-004511-A	< 1	FT-72016-004511-B	< 1
30	BEERS ELEMENTARY SCHOOL	WS- 004512	8/14/2016	2	Cooler	In hallway across from room D210	FT-72016-004512-A	< 1	FT-72016-004512-B	< 1
31	BEERS ELEMENTARY SCHOOL	WS- 004515	8/14/2016	Ground Floor	Exterior Fountain	Exterior, in area adjacent to soccer field High	FT-72016-004515-A	< 1	FT-72016-004515-B	< 1
32	BEERS ELEMENTARY SCHOOL	WS- 004516	8/14/2016	Ground Floor	Exterior Fountain	Exterior, in area adjacent to soccer field Low	FT-82016-004516-A	< 1	FT-82016-004516-B	< 1