



BEERS LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004467	Utility	Basement	In exterior boiler room near restroom	WT-042916-4484- A	7.51	WT-042916-4484- B	1.37			
2	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004468	Cooler	Basement	In cafeteria	High	WT-042916-4485- A	< 1	WT-042916-4485- B	< 1		
3	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004469	Cooler	Basement	In cafeteria	Low	WT-042916-4486- A	< 1	WT-042916-4486- B	< 1		
4	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004470	Kitchen	Basement	In kitchen spray nozzle	Left	WT-042916-4487- A	< 1	WT-042916-4487- B	< 1		
5	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004471	Kitchen	Basement	In kitchen	Right	WT-042916-4488- A	< 1	WT-042916-4488- B	< 1		
6	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004472	Cooler	1	In hallway across from classroom D102		WT-042916-4489- A	< 1	WT-042916-4489- B	< 1		
7	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004473	Cooler	1	In hallway across from classroom D108		WT-042916-4490- A	< 1	WT-042916-4490- B	< 1		
8	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004474	Classroom	1	In science lab D108	Right	WT-042916-4491- A	< 1	WT-042916-4491- B	1.65		
9	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004475	Classroom	1	In science lab D108	Left	WT-042916-4492- A	1.83	WT-042916-4492- B	2.46		
10	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004476	Cooler	1	In hallway adjacent auditorium C101	High	WT-042916-4493- A	< 1	WT-042916-4493- B	< 1		
11	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004477	Cooler	1	In hallway adjacent auditorium C101		WT-042916-4494- A	< 1	WT-042916-4494- B	< 1		
12	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004478	Cooler	1	In hallway adjacent classroom B101	High	WT-042916-4495- A	< 1	WT-042916-4495- B	< 1		
13	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004479	Cooler	1	In hallway adjacent classroom B101	Low	WT-042916-4496- A	< 1	WT-042916-4496- B	< 1		
14	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004480	Cooler	1	In classroom 109		WT-042916-4497- A	< 1	WT-042916-4497- B	< 1		
15	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004481	Classroom	1	In classroom 109		WT-042916-4498- A	< 1	WT-042916-4498- B	< 1		
16	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004482	Cooler	1	In classroom 108		WT-042916-4499- A	< 1	WT-042916-4499- B	< 1		
17	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004483	Classroom	1	In classroom 108		WT-042916-4500- A	< 1	WT-042916-4500- B	< 1		
18	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004484	Cooler	1	In hallway across classroom A110		WT-042916-4501- A	< 1	WT-042916-4501- B	< 1		
19	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004485	Cooler	1	In classroom A110		WT-042916-4502- A	< 1	WT-042916-4502- B	< 1		
20	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004486	Classroom	1	In classroom A110		WT-042916-4503- A	< 1	WT-042916-4503- B	< 1		
21	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004487	Cooler	1	In health suite A115		WT-042916-4504- A	< 1	WT-042916-4504- B	< 1		
22	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004488	Health Suite	1	In health suite A115		WT-042916-4505- A	< 1	WT-042916-4505- B	< 1		
23	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004489	Cooler	1	In classroom A112		WT-042916-4506- A	< 1	WT-042916-4506- B	< 1		
24	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004490	Classroom	1	In classroom A112		WT-042916-4507- A	< 1	WT-042916-4507- B	< 1		
25	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004491	Cooler	1	In classroom A119		WT-042916-4508- A	< 1	WT-042916-4508- B	< 1		
26	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004492	Classroom	1	In classroom A119		WT-042916-4509- A	1.06	WT-042916-4509- B	< 1		
27	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004493	Cooler	1	In hallway across from classroom B106		WT-042916-4510- A	< 1	WT-042916-4510- B	< 1		
28	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004494	Cooler	2	In hallway across from B208		WT-042916-4511- A	< 1	WT-042916-4511- B	< 1		
29	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004495	Cooler	2	In classroom B209		WT-042916-4512- A	< 1	WT-042916-4512- B	< 1		
30	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004496	Classroom	2	In classroom B209		WT-042916-4513- A	2.46	WT-042916-4513- B	< 1		
31	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004497	Cooler	2	In hallway adjacent classroom B201	Low	WT-042916-4514- A	< 1	WT-042916-4514- B	< 1		
32	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004498	Cooler	2	In hallway across from classroom B204	High	WT-042916-4515- A	< 1	WT-042916-4515- B	< 1		
33	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004499	Cooler	2	In classroom A205		WT-042916-4516- A	< 1	WT-042916-4516- B	< 1		
34	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004500	Classroom	2	In classroom A205		WT-042916-4517- A	< 1	WT-042916-4517- B	< 1		
35	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004501	Cooler	2	In hallway across A207		WT-042916-4518- A	< 1	WT-042916-4518- B	< 1		
36	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004502	Cooler	2	In classroom A207		WT-042916-4519- A	< 1	WT-042916-4519- B	< 1		
37	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004503	Classroom	2	In classroom A207		WT-042916-4520- A	< 1	WT-042916-4520- B	1.54		
38	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004504	Cooler	2	In classroom A214		WT-042916-4521- A	< 1	WT-042916-4521- B	< 1		
39	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004505	Classroom	2	In classroom A214		WT-042916-4522- A	< 1	WT-042916-4522- B	< 1		
40	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004506	Cooler	2	In classroom A211		WT-042916-4523- A	< 1	WT-042916-4523- B	< 1		
41	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004507	Classroom	2	In classroom A211		WT-042916-4524- A	< 1	WT-042916-4524- B	< 1		
42	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004508	Cooler	2	In classroom A216		WT-042916-4525- A	< 1	WT-042916-4525- B	< 1		
43	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004509	Classroom	2	In classroom A216		WT-042916-4526- A	1.16	WT-042916-4526- B	< 1		
44	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004510	Break Room	1	In teacher's lounge 202		WT-042916-4527- A	1.48	WT-042916-4527- B	< 1		
45	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004511	Cooler	2	In hallway adjacent room D201		WT-042916-4528- A	< 1	WT-042916-4528- B	< 1		
46	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004512	Cooler	2	In hallway across art room D210		WT-042916-4529- A	< 1	WT-042916-4529- B	< 1		
47	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004513	Classroom	2	In art room D210	Left	WT-042916-4530- A	1.44	WT-042916-4530- B	< 1		
48	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004514	Classroom	2	In art room D210	Right	WT-042916-4531- A	< 1	WT-042916-4531- B	< 1		
49	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004515	Fountain	Ground Floor	In soccer field	High	WT-042916-4532- A	< 1	WT-042916-4532- B	< 1		
50	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004516	Fountain	Ground Floor	In soccer field	Low	WT-042916-4533- A	< 1	WT-042916-4533- B	< 1		
51	BEERS ELEMENTARY SCHOOL	5/6/2016	WS- 004517	Kitchen	Basement	In kitchen adjacent dressing room C001.1		WT-042916-4534- A	1.51	WT-042916-4534- B	< 1		

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.