



BEERS ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	BEERS ELEMENTARY SCHOOL	WS- 004510	12/20/2016	2	Break Room	In staff lounge 202	FT-102016-004510-A	< 1	FT-102016-004510-B	< 1
2	BEERS ELEMENTARY SCHOOL	WS- 004496	12/20/2016	2	Classroom Faucet	In classroom B209	FT-122016-004496-A	< 1	FT-122016-004496-B	< 1
3	BEERS ELEMENTARY SCHOOL	WS- 004500	12/20/2016	2	Classroom Faucet	In classroom A205	FT-122016-004500-A	< 1	FT-122016-004500-B	< 1
4	BEERS ELEMENTARY SCHOOL	WS- 004514	12/20/2016	2	Classroom Faucet	In art room D210 Right	FT-122016-004514-A	< 1	FT-122016-004514-B	< 1
5	BEERS ELEMENTARY SCHOOL	WS- 004513	12/20/2016	2	Classroom Faucet	In art room D210 Left	FT-122016-004513-A	< 1	FT-122016-004513-B	< 1
6	BEERS ELEMENTARY SCHOOL	WS- 004481	12/20/2016	1	Classroom Faucet	In classroom A109	FT-122016-004481-A	< 1	FT-122016-004481-B	< 1
7	BEERS ELEMENTARY SCHOOL	WS- 004505	12/20/2016	2	Classroom Faucet	In classroom A214	FT-122016-004505-A	< 1	FT-122016-004505-B	< 1
8	BEERS ELEMENTARY SCHOOL	WS- 004507	12/20/2016	2	Classroom Faucet	In classroom A211	FT-122016-004507-A	< 1	FT-122016-004507-B	< 1
9	BEERS ELEMENTARY SCHOOL	WS- 004503	12/20/2016	2	Classroom Faucet	In classroom A207	FT-122016-004503-A	< 1	FT-122016-004503-B	< 1
10	BEERS ELEMENTARY SCHOOL	WS- 004490	12/20/2016	1	Classroom Faucet	In classroom A112	FT-122016-004490-A	< 1	FT-122016-004490-B	< 1
11	BEERS ELEMENTARY SCHOOL	WS- 004492	12/20/2016	1	Classroom Faucet	In classroom A119	FT-122016-004492-A	< 1	FT-122016-004492-B	< 1
12	BEERS ELEMENTARY SCHOOL	WS- 004483	12/20/2016	1	Classroom Faucet	In classroom A108	FT-122016-004483-A	< 1	FT-122016-004483-B	< 1
13	BEERS ELEMENTARY SCHOOL	WS- 004486	12/20/2016	1	Classroom Faucet	In classroom A110	FT-122016-004486-A	< 1	FT-122016-004486-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb