



Boone ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013000	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 136	Low Left	WF-08062018-013000	8/30/2018	FT-FY19-082018-013000-A	< 1	FT-FY19-082018-013000-B	< 1
WS-013001	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 136	Low Left	WF-08062018-013001	8/30/2018	FT-FY19-082018-013001-A	< 1	FT-FY19-082018-013001-B	1.2
WS-013002	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 136	High Right	WF-08062018-013002	8/30/2018	FT-FY19-082018-013002-A	< 1	FT-FY19-082018-013002-B	< 1
WS-013003	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 136	High Right	WF-08062018-013003	8/30/2018	FT-FY19-082018-013003-A	< 1	FT-FY19-082018-013003-B	< 1
WS-013004	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 137	High Left	WF-08062018-013004	8/30/2018	FT-FY19-082018-013004-A	< 1	FT-FY19-082018-013004-B	< 1
WS-013005	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 137	High Left	WF-08062018-013005	8/30/2018	FT-FY19-082018-013005-A	< 1	FT-FY19-082018-013005-B	< 1
WS-013006	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 137	Low Right	WF-08062018-013006	8/30/2018	FT-FY19-082018-013006-A	< 1	FT-FY19-082018-013006-B	< 1
WS-013007	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 137	Low Right	WF-08062018-013007	8/30/2018	FT-FY19-082018-013007-A	< 1	FT-FY19-082018-013007-B	< 1
WS-013008	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 134	High Left	WF-08062018-013008	8/30/2018	FT-FY19-082018-013008-A	< 1	FT-FY19-082018-013008-B	< 1
WS-013009	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 134	High Left	WF-08062018-013009	8/30/2018	FT-FY19-082018-013009-A	< 1	FT-FY19-082018-013009-B	< 1
WS-013010	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 134	Low Right	WF-08062018-013010	8/30/2018	FT-FY19-082018-013010-A	< 1	FT-FY19-082018-013010-B	< 1
WS-013011	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 134	Low Right	WF-08062018-013011	8/30/2018	FT-FY19-082018-013011-A	< 1	FT-FY19-082018-013011-B	< 1
WS-013012	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 135	Low Left	WF-08062018-013012	8/30/2018	FT-FY19-082018-013012-A	< 1	FT-FY19-082018-013012-B	< 1
WS-013013	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 135	Low Left	WF-08062018-013013	8/30/2018	FT-FY19-082018-013013-A	< 1	FT-FY19-082018-013013-B	< 1
WS-013014	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 135	High Right	WF-08062018-013014	8/30/2018	FT-FY19-082018-013014-A	< 1	FT-FY19-082018-013014-B	< 1
WS-013015	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 135	High Right	WF-08062018-013015	8/30/2018	FT-FY19-082018-013015-A	< 1	FT-FY19-082018-013015-B	1.4
WS-013016	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 133	High Left	WF-08062018-013016	8/30/2018	FT-FY19-082018-013016-A	< 1	FT-FY19-082018-013016-B	1.7
WS-013017	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 133	High Left	WF-08062018-013017	8/30/2018	FT-FY19-082018-013017-A	< 1	FT-FY19-082018-013017-B	2.4
WS-013018	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 133	Low Right	WF-08062018-013018	8/30/2018	FT-FY19-082018-013018-A	< 1	FT-FY19-082018-013018-B	< 1
WS-013019	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 133	Low Right	WF-08062018-013019	8/30/2018	FT-FY19-082018-013019-A	< 1	FT-FY19-082018-013019-B	< 1
WS-013021	8/6/2018	8/6/2019	1	Combo Fountain	In workroom 132		WF-08062018-013021	8/30/2018	FT-FY19-082018-013021-A	< 1	FT-FY19-082018-013021-B	< 1
WS-013023	8/6/2018	8/6/2019	1	Combo Fountain	In academic resource room 139		WF-08062018-013023	8/30/2018	FT-FY19-082018-013023-A	< 1	FT-FY19-082018-013023-B	< 1
WS-013024	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 131	Low Left	WF-08062018-013024	8/30/2018	FT-FY19-082018-013024-A	< 1	FT-FY19-082018-013024-B	< 1
WS-013025	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 131	Low Left	WF-08062018-013025	8/30/2018	FT-FY19-082018-013025-A	< 1	FT-FY19-082018-013025-B	< 1
WS-013026	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 131	High Right	WF-08062018-013026	8/30/2018	FT-FY19-082018-013026-A	< 1	FT-FY19-082018-013026-B	< 1
WS-013027	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 131	High Right	WF-08062018-013027	8/30/2018	FT-FY19-082018-013027-A	1.6	FT-FY19-082018-013027-B	< 1
WS-013028	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 128	Low Left	WF-08062018-013028	8/30/2018	FT-FY19-082018-013028-A	< 1	FT-FY19-082018-013028-B	< 1
WS-013029	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 128	Low Left	WF-08062018-013029	8/30/2018	FT-FY19-082018-013029-A	< 1	FT-FY19-082018-013029-B	< 1
WS-013030	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 128	High Right	WF-08062018-013030	8/30/2018	FT-FY19-082018-013030-A	< 1	FT-FY19-082018-013030-B	< 1
WS-013031	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 128	High Right	WF-08062018-013031	8/30/2018	FT-FY19-082018-013031-A	< 1	FT-FY19-082018-013031-B	< 1
WS-013032	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 126	High Left	WF-08062018-013032	8/30/2018	FT-FY19-082018-013032-A	< 1	FT-FY19-082018-013032-B	< 1
WS-013033	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 126	High Left	WF-08062018-013033	8/30/2018	FT-FY19-082018-013033-A	< 1	FT-FY19-082018-013033-B	< 1
WS-013034	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 126	Low Right	WF-08062018-013034	8/30/2018	FT-FY19-082018-013034-A	< 1	FT-FY19-082018-013034-B	< 1
WS-013035	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 126	Low Right	WF-08062018-013035	8/30/2018	FT-FY19-082018-013035-A	< 1	FT-FY19-082018-013035-B	< 1
WS-013036	8/6/2018	8/6/2019	1	Cooler	In hallway across from classroom 127	Low Right	WF-08062018-013036	8/30/2018	FT-FY19-082018-013036-A	< 1	FT-FY19-082018-013036-B	< 1

WS-013037	8/6/2018	8/6/2019	1	Cooler	In hallway across from classroom 127	High	Left	WF-08062018-013037	8/30/2018	FT-FY19-082018-013037-A	< 1	FT-FY19-082018-013037-B	< 1
WS-013038	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 127	High	Left	WF-08062018-013038	8/30/2018	FT-FY19-082018-013038-A	< 1	FT-FY19-082018-013038-B	< 1
WS-013039	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 127	High	Left	WF-08062018-013039	8/30/2018	FT-FY19-082018-013039-A	< 1	FT-FY19-082018-013039-B	< 1
WS-013040	8/6/2018	8/6/2019	1	Combo Faucet	In classroom 127	Low	Right	WF-08062018-013040	8/30/2018	FT-FY19-082018-013040-A	< 1	FT-FY19-082018-013040-B	< 1
WS-013041	8/6/2018	8/6/2019	1	Combo Fountain	In classroom 127	Low	Right	WF-08062018-013041	8/30/2018	FT-FY19-082018-013041-A	< 1	FT-FY19-082018-013041-B	< 1
WS-013052	8/6/2018	8/6/2019	1	Cooler	In cafeteria	High	Left	WF-08062018-013052	8/30/2018	FT-FY19-082018-013052-A	< 1	FT-FY19-082018-013052-B	< 1
WS-013053	8/6/2018	8/6/2019	1	Cooler	In cafeteria	Low	Right	WF-08062018-013053	8/30/2018	FT-FY19-082018-013053-A	< 1	FT-FY19-082018-013053-B	< 1
WS-013054	8/6/2018	8/6/2019	1	Health Suite	In treatment room 110b			WF-08062018-013054	8/30/2018	FT-FY19-082018-013054-A	< 1	FT-FY19-082018-013054-B	< 1
WS-013055	8/6/2018	8/6/2019	1	Combo Fountain	In treatment room 110b			WF-08062018-013055	8/30/2018	FT-FY19-082018-013055-A	< 1	FT-FY19-082018-013055-B	< 1
WS-013056	8/6/2018	8/6/2019	1	Bottle Filler	In hallway across from extended day office 101			WF-08062018-013056	8/30/2018	FT-FY19-082018-013056-A	< 1	FT-FY19-082018-013056-B	< 1
WS-013057	8/6/2018	8/6/2019	1	Fountain	In hallway across from extended day office 101	Low	Left	WF-08062018-013057	8/30/2018	FT-FY19-082018-013057-A	< 1	FT-FY19-082018-013057-B	< 1
WS-013058	8/6/2018	8/6/2019	1	Cooler	In gym	High	Left	WF-08062018-013058	8/30/2018	FT-FY19-082018-013058-A	< 1	FT-FY19-082018-013058-B	< 1
WS-013059	8/6/2018	8/6/2019	1	Cooler	In gym	Low	Right	WF-08062018-013059	8/30/2018	FT-FY19-082018-013059-A	< 1	FT-FY19-082018-013059-B	< 1
WS-013061	8/6/2018	8/6/2019	2	Combo Fountain	In science classroom 245 first clockwise from entry door			WF-08062018-013061	8/30/2018	FT-FY19-082018-013061-A	< 1	FT-FY19-082018-013061-B	< 1
WS-013063	8/6/2018	8/6/2019	2	Combo Fountain	In science classroom 245 second clockwise from entry door			WF-08062018-013063	8/30/2018	FT-FY19-082018-013063-A	< 1	FT-FY19-082018-013063-B	< 1
WS-013065	8/6/2018	8/6/2019	2	Combo Fountain	In science classroom 245 third clockwise from entry door			WF-08062018-013065	8/30/2018	FT-FY19-082018-013065-A	< 1	FT-FY19-082018-013065-B	< 1
WS-013067	8/6/2018	8/6/2019	2	Combo Fountain	In science classroom 245 fourth clockwise from entry door			WF-08062018-013067	8/30/2018	FT-FY19-082018-013067-A	< 1	FT-FY19-082018-013067-B	< 1
WS-013069	8/6/2018	8/6/2019	2	Combo Fountain	In classroom 243			WF-08062018-013069	8/30/2018	FT-FY19-082018-013069-A	< 1	FT-FY19-082018-013069-B	< 1
WS-013071	8/6/2018	8/6/2019	2	Combo Fountain	In classroom 244			WF-08062018-013071	8/30/2018	FT-FY19-082018-013071-A	< 1	FT-FY19-082018-013071-B	< 1
WS-013073	8/6/2018	8/6/2019	2	Combo Fountain	In classroom 242			WF-08062018-013073	8/30/2018	FT-FY19-082018-013073-A	< 1	FT-FY19-082018-013073-B	< 1
WS-013075	8/6/2018	8/6/2019	2	Combo Fountain	In classroom 241			WF-08062018-013075	8/30/2018	FT-FY19-082018-013075-A	< 1	FT-FY19-082018-013075-B	< 1
WS-013077	8/6/2018	8/6/2019	2	Combo Fountain	In workroom 239			WF-08062018-013077	8/30/2018	FT-FY19-082018-013077-A	< 1	FT-FY19-082018-013077-B	< 1
WS-013079	8/6/2018	8/6/2019	2	Combo Fountain	In room 237b inside reading learning center 237			WF-08062018-013079	8/30/2018	FT-FY19-082018-013079-A	< 1	FT-FY19-082018-013079-B	< 1
WS-013080	8/6/2018	8/6/2019	2	Cooler	In hallway across from classroom 234	High	Left	WF-08062018-013080	8/30/2018	FT-FY19-082018-013080-A	< 1	FT-FY19-082018-013080-B	< 1
WS-013081	8/6/2018	8/6/2019	2	Cooler	In hallway across from classroom 234	Low	Right	WF-08062018-013081	8/30/2018	FT-FY19-082018-013081-A	< 1	FT-FY19-082018-013081-B	< 1
WS-013083	8/6/2018	8/6/2019	2	Combo Fountain	In classroom 234			WF-08062018-013083	8/30/2018	FT-FY19-082018-013083-A	< 1	FT-FY19-082018-013083-B	< 1
WS-013085	8/6/2018	8/6/2019	2	Combo Fountain	In classroom 232			WF-08062018-013085	8/30/2018	FT-FY19-082018-013085-A	< 1	FT-FY19-082018-013085-B	< 1
WS-013087	8/6/2018	8/6/2019	2	Combo Fountain	In classroom 231			WF-08062018-013087	8/30/2018	FT-FY19-082018-013087-A	< 1	FT-FY19-082018-013087-B	< 1
WS-013091	8/6/2018	8/6/2019	2	Break Room	In staff lounge 209			WF-08062018-013091	8/30/2018	FT-FY19-082018-013091-A	< 1	FT-FY19-082018-013091-B	< 1
WS-013094	8/6/2018	8/6/2019	2	Cooler	In hallway adjacent to security room 212	High	Left	WF-08062018-013094	8/30/2018	FT-FY19-082018-013094-A	< 1	FT-FY19-082018-013094-B	< 1
WS-013095	8/6/2018	8/6/2019	2	Cooler	In hallway adjacent to security room 212	Low	Right	WF-08062018-013095	8/30/2018	FT-FY19-082018-013095-A	< 1	FT-FY19-082018-013095-B	< 1
WS-013097	8/6/2018	8/6/2019	2	Combo Fountain	In music room 214			WF-08062018-013097	8/30/2018	FT-FY19-082018-013097-A	< 1	FT-FY19-082018-013097-B	< 1
WS-013098	8/6/2018	8/6/2019	2	Cooler	In music room 214			WF-08062018-013098	8/30/2018	FT-FY19-082018-013098-A	< 1	FT-FY19-082018-013098-B	< 1
WS-013100	8/6/2018	8/6/2019	3	Combo Fountain	In classroom 318			WF-08062018-013100	8/30/2018	FT-FY19-082018-013100-A	< 1	FT-FY19-082018-013100-B	< 1
WS-013102	8/6/2018	8/6/2019	3	Combo Fountain	In classroom 317			WF-08062018-013102	8/30/2018	FT-FY19-082018-013102-A	< 1	FT-FY19-082018-013102-B	< 1
WS-013104	8/6/2018	8/6/2019	3	Combo Fountain	In classroom 316			WF-08062018-013104	8/30/2018	FT-FY19-082018-013104-A	< 1	FT-FY19-082018-013104-B	< 1
WS-013106	8/6/2018	8/6/2019	3	Combo Fountain	In classroom 315			WF-08062018-013106	8/30/2018	FT-FY19-082018-013106-A	< 1	FT-FY19-082018-013106-B	< 1
WS-013108	8/6/2018	8/6/2019	3	Combo Fountain	In classroom 314			WF-08062018-013108	8/30/2018	FT-FY19-082018-013108-A	< 1	FT-FY19-082018-013108-B	< 1
WS-013110	8/6/2018	8/6/2019	3	Combo Fountain	In classroom 313			WF-08062018-013110	8/30/2018	FT-FY19-082018-013110-A	< 1	FT-FY19-082018-013110-B	< 1
WS-013111	8/6/2018	8/6/2019	3	Break Room	In workroom 309			WF-08062018-013111	8/30/2018	FT-FY19-082018-013111-A	< 1	FT-FY19-082018-013111-B	< 1
WS-013112	8/6/2018	8/6/2019	3	Combo Fountain	In workroom 309			WF-08062018-013112	8/30/2018	FT-FY19-082018-013112-A	< 1	FT-FY19-082018-013112-B	< 1

WS-013114	8/6/2018	8/6/2019	3	Combo Fountain	In instructional coach room 308		WF-08062018-013114	8/30/2018	FT-FY19-082018-013114-A	< 1	FT-FY19-082018-013114-B	< 1
WS-013116	8/6/2018	8/6/2019	3	Combo Fountain	In classroom 310		WF-08062018-013116	8/30/2018	FT-FY19-082018-013116-A	< 1	FT-FY19-082018-013116-B	< 1
WS-013117	8/6/2018	8/6/2019	3	Cooler	In hallway across from classroom 310	High Left	WF-08062018-013117	8/30/2018	FT-FY19-082018-013117-A	< 1	FT-FY19-082018-013117-B	< 1
WS-013118	8/6/2018	8/6/2019	3	Cooler	In hallway across from classroom 310	Low Right	WF-08062018-013118	8/30/2018	FT-FY19-082018-013118-A	< 1	FT-FY19-082018-013118-B	< 1
WS-013120	8/6/2018	8/6/2019	3	Combo Fountain	In classroom 306		WF-08062018-013120	8/30/2018	FT-FY19-082018-013120-A	< 1	FT-FY19-082018-013120-B	< 1
WS-013122	8/6/2018	8/6/2019	3	Combo Fountain	In classroom 305		WF-08062018-013122	8/30/2018	FT-FY19-082018-013122-A	< 1	FT-FY19-082018-013122-B	< 1
WS-013123	8/6/2018	8/6/2019	1	Fountain	In hallway across from extended day office 101	High Right	WF-08062018-013123	8/30/2018	FT-FY19-082018-013123-A	< 1	FT-FY19-082018-013123-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Floor	Device Type	Device Location				Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013048	1	Food Prep Sink	In rear of kitchen				8/30/2018	FT-FY19-082018-013048-A	< 1	FT-FY19-082018-013048-B	< 1