



Boone ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-013000	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 136	Low Left	WF-10222019-013000	12/27/2019	FT-FY20-122019-013000-A	<1	FT-FY20-122019-013000-B	<1
WS-013001	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 136	Low Left	WF-06052019-013001	12/27/2019	FT-FY20-122019-013001-A	<1	FT-FY20-122019-013001-B	<1
WS-013002	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 136	High Right	WF-10222019-013002	12/27/2019	FT-FY20-122019-013002-A	<1	FT-FY20-122019-013002-B	<1
WS-013003	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 136	High Right	WF-06052019-013003	12/27/2019	FT-FY20-122019-013003-A	<1	FT-FY20-122019-013003-B	<1
WS-013004	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 137	High Left	WF-10222019-013004	12/27/2019	FT-FY20-122019-013004-A	1.6	FT-FY20-122019-013004-B	<1
WS-013005	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 137	High Left	WF-06052019-013005	12/27/2019	FT-FY20-122019-013005-A	<1	FT-FY20-122019-013005-B	<1
WS-013006	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 137	Low Right	WF-10222019-013006	12/27/2019	FT-FY20-122019-013006-A	<1	FT-FY20-122019-013006-B	<1
WS-013007	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 137	Low Right	WF-06052019-013007	12/27/2019	FT-FY20-122019-013007-A	<1	FT-FY20-122019-013007-B	<1
WS-013008	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 134	High Left	WF-10222019-013008	12/27/2019	FT-FY20-122019-013008-A	<1	FT-FY20-122019-013008-B	<1
WS-013009	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 134	High Left	WF-06052019-013009	12/27/2019	FT-FY20-122019-013009-A	<1	FT-FY20-122019-013009-B	<1
WS-013010	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 134	Low Right	WF-10222019-013010	12/27/2019	FT-FY20-122019-013010-A	<1	FT-FY20-122019-013010-B	<1
WS-013011	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 134	Low Right	WF-06052019-013011	12/27/2019	FT-FY20-122019-013011-A	<1	FT-FY20-122019-013011-B	<1
WS-013012	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 135	Low Left	WF-10222019-013012	12/27/2019	FT-FY20-122019-013012-A	<1	FT-FY20-122019-013012-B	<1
WS-013013	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 135	Low Left	WF-06052019-013013	12/27/2019	FT-FY20-122019-013013-A	<1	FT-FY20-122019-013013-B	<1
WS-013014	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 135	High Right	WF-10222019-013014	12/27/2019	FT-FY20-122019-013014-A	<1	FT-FY20-122019-013014-B	<1
WS-013015	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 135	High Right	WF-06052019-013015	12/27/2019	FT-FY20-122019-013015-A	<1	FT-FY20-122019-013015-B	<1
WS-013016	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 133	High Left	WF-10222019-013016	12/27/2019	FT-FY20-122019-013016-A	<1	FT-FY20-122019-013016-B	<1
WS-013017	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 133	High Left	WF-06052019-013017	12/27/2019	FT-FY20-122019-013017-A	<1	FT-FY20-122019-013017-B	<1
WS-013018	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 133	Low Right	WF-10222019-013018	12/27/2019	FT-FY20-122019-013018-A	<1	FT-FY20-122019-013018-B	<1
WS-013019	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 133	Low Right	WF-06052019-013019	12/27/2019	FT-FY20-122019-013019-A	<1	FT-FY20-122019-013019-B	<1
WS-013021	6/5/2019	6/5/2020	1	Combo Fountain	In workroom 132		WF-06052019-013021	12/27/2019	FT-FY20-122019-013021-A	<1	FT-FY20-122019-013021-B	<1
WS-013023	6/5/2019	6/5/2020	1	Combo Fountain	In academic resource room 139		WF-06052019-013023	12/27/2019	FT-FY20-122019-013023-A	<1	FT-FY20-122019-013023-B	<1
WS-013024	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 131	Low Left	WF-10222019-013024	12/27/2019	FT-FY20-122019-013024-A	2.3	FT-FY20-122019-013024-B	<1
WS-013025	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 131	Low Left	WF-06052019-013025	12/27/2019	FT-FY20-122019-013025-A	<1	FT-FY20-122019-013025-B	<1
WS-013026	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 131	High Right	WF-10222019-013026	12/27/2019	FT-FY20-122019-013026-A	<1	FT-FY20-122019-013026-B	<1
WS-013027	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 131	High Right	WF-06052019-013027	12/27/2019	FT-FY20-122019-013027-A	<1	FT-FY20-122019-013027-B	<1
WS-013028	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 128	Low Left	WF-10222019-013028	12/27/2019	FT-FY20-122019-013028-A	<1	FT-FY20-122019-013028-B	<1
WS-013029	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 128	Low Left	WF-06052019-013029	12/27/2019	FT-FY20-122019-013029-A	<1	FT-FY20-122019-013029-B	<1
WS-013030	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 128	High Right	WF-10222019-013030	12/27/2019	FT-FY20-122019-013030-A	<1	FT-FY20-122019-013030-B	<1
WS-013031	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 128	High Right	WF-06052019-013031	12/27/2019	FT-FY20-122019-013031-A	<1	FT-FY20-122019-013031-B	<1
WS-013032	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 126	High Left	WF-10222019-013032	12/27/2019	FT-FY20-122019-013032-A	<1	FT-FY20-122019-013032-B	<1
WS-013033	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 126	High Left	WF-06052019-013033	12/27/2019	FT-FY20-122019-013033-A	<1	FT-FY20-122019-013033-B	<1
WS-013034	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 126	Low Right	WF-10222019-013034	12/27/2019	FT-FY20-122019-013034-A	<1	FT-FY20-122019-013034-B	<1
WS-013035	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 126	Low Right	WF-06052019-013035	12/27/2019	FT-FY20-122019-013035-A	<1	FT-FY20-122019-013035-B	<1
WS-013036	6/5/2019	6/5/2020	1	Cooler	In hallway across from classroom 127	Low Right	WF-06052019-013036	12/27/2019	FT-FY20-122019-013036-A	<1	FT-FY20-122019-013036-B	<1
WS-013037	6/5/2019	6/5/2020	1	Cooler	In hallway across from classroom 127	High Left	WF-06052019-013037	12/27/2019	FT-FY20-122019-013037-A	<1	FT-FY20-122019-013037-B	<1

WS-013038	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 127	High Left	WF-10222019-013038	12/27/2019	FT-FY20-122019-013038-A	2.8	FT-FY20-122019-013038-B	<1
WS-013039	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 127	High Left	WF-06052019-013039	12/27/2019	FT-FY20-122019-013039-A	<1	FT-FY20-122019-013039-B	<1
WS-013040	10/22/2019	10/22/2020	1	Combo Faucet	In classroom 127	Low Right	WF-10222019-013040	12/27/2019	FT-FY20-122019-013040-A	<1	FT-FY20-122019-013040-B	<1
WS-013041	6/5/2019	6/5/2020	1	Combo Fountain	In classroom 127	Low Right	WF-06052019-013041	12/27/2019	FT-FY20-122019-013041-A	<1	FT-FY20-122019-013041-B	<1
WS-013052	6/5/2019	6/5/2020	1	Cooler	In cafeteria	High Left	WF-06052019-013052	12/27/2019	FT-FY20-122019-013052-A	<1	FT-FY20-122019-013052-B	<1
WS-013053	6/5/2019	6/5/2020	1	Cooler	In cafeteria	Low Right	WF-06052019-013053	12/27/2019	FT-FY20-122019-013053-A	<1	FT-FY20-122019-013053-B	<1
WS-013054	6/5/2019	6/5/2020	1	Health Suite	In treatment room 110b		WF-06052019-013054	12/27/2019	FT-FY20-122019-013054-A	<1	FT-FY20-122019-013054-B	<1
WS-013055	6/5/2019	6/5/2020	1	Combo Fountain	In treatment room 110b		WF-06052019-013055	12/27/2019	FT-FY20-122019-013055-A	<1	FT-FY20-122019-013055-B	<1
WS-013056	6/5/2019	6/5/2020	1	Bottle Filler	In hallway across from extended day office 101		WF-06052019-013056	12/27/2019	FT-FY20-122019-013056-A	<1	FT-FY20-122019-013056-B	<1
WS-013057	6/5/2019	6/5/2020	1	Fountain	In hallway across from extended day office 101	Low Left	WF-06052019-013057	12/27/2019	FT-FY20-122019-013057-A	<1	FT-FY20-122019-013057-B	2.5
WS-013058	6/5/2019	6/5/2020	1	Cooler	In gym	High Left	WF-06052019-013058	12/27/2019	FT-FY20-122019-013058-A	<1	FT-FY20-122019-013058-B	<1
WS-013059	6/5/2019	6/5/2020	1	Cooler	In gym	Low Right	WF-06052019-013059	12/27/2019	FT-FY20-122019-013059-A	<1	FT-FY20-122019-013059-B	<1
WS-013065	6/5/2019	6/5/2020	2	Combo Fountain	In science classroom 245 third clockwise from entry door		WF-06052019-013065	12/27/2019	FT-FY20-122019-013065-A	<1	FT-FY20-122019-013065-B	<1
WS-013067	6/5/2019	6/5/2020	2	Combo Fountain	In science classroom 245 fourth clockwise from entry door		WF-06052019-013067	12/27/2019	FT-FY20-122019-013067-A	<1	FT-FY20-122019-013067-B	<1
WS-013069	6/5/2019	6/5/2020	2	Combo Fountain	In classroom 243		WF-06052019-013069	12/27/2019	FT-FY20-122019-013069-A	<1	FT-FY20-122019-013069-B	<1
WS-013071	6/5/2019	6/5/2020	2	Combo Fountain	In classroom 244		WF-06052019-013071	12/27/2019	FT-FY20-122019-013071-A	<1	FT-FY20-122019-013071-B	<1
WS-013073	6/5/2019	6/5/2020	2	Combo Fountain	In classroom 242		WF-06052019-013073	12/27/2019	FT-FY20-122019-013073-A	<1	FT-FY20-122019-013073-B	<1
WS-013075	6/5/2019	6/5/2020	2	Combo Fountain	In classroom 241		WF-06052019-013075	12/27/2019	FT-FY20-122019-013075-A	<1	FT-FY20-122019-013075-B	<1
WS-013077	6/5/2019	6/5/2020	2	Combo Fountain	In workroom 239		WF-06052019-013077	12/27/2019	FT-FY20-122019-013077-A	<1	FT-FY20-122019-013077-B	<1
WS-013079	6/5/2019	6/5/2020	2	Combo Fountain	In room 237b inside reading learning center 237		WF-06052019-013079	12/27/2019	FT-FY20-122019-013079-A	<1	FT-FY20-122019-013079-B	<1
WS-013080	6/5/2019	6/5/2020	2	Cooler	In hallway across from classroom 234	High Left	WF-06052019-013080	12/27/2019	FT-FY20-122019-013080-A	<1	FT-FY20-122019-013080-B	<1
WS-013081	6/5/2019	6/5/2020	2	Cooler	In hallway across from classroom 234	Low Right	WF-06052019-013081	12/27/2019	FT-FY20-122019-013081-A	<1	FT-FY20-122019-013081-B	<1
WS-013083	6/5/2019	6/5/2020	2	Combo Fountain	In classroom 234		WF-06052019-013083	12/27/2019	FT-FY20-122019-013083-A	<1	FT-FY20-122019-013083-B	<1
WS-013085	6/5/2019	6/5/2020	2	Combo Fountain	In classroom 232		WF-06052019-013085	12/27/2019	FT-FY20-122019-013085-A	<1	FT-FY20-122019-013085-B	<1
WS-013087	6/5/2019	6/5/2020	2	Combo Fountain	In classroom 231		WF-06052019-013087	12/27/2019	FT-FY20-122019-013087-A	<1	FT-FY20-122019-013087-B	<1
WS-013091	6/5/2019	6/5/2020	2	Break Room	In staff lounge 209		WF-06052019-013091	12/27/2019	FT-FY20-122019-013091-A	<1	FT-FY20-122019-013091-B	<1
WS-013094	6/5/2019	6/5/2020	2	Cooler	In hallway adjacent to security room 212	High Left	WF-06052019-013094	12/27/2019	FT-FY20-122019-013094-A	<1	FT-FY20-122019-013094-B	<1
WS-013095	6/5/2019	6/5/2020	2	Cooler	In hallway adjacent to security room 212	Low Right	WF-06052019-013095	12/27/2019	FT-FY20-122019-013095-A	<1	FT-FY20-122019-013095-B	<1
WS-013097	6/5/2019	6/5/2020	2	Combo Fountain	In music room 214		WF-06052019-013097	12/27/2019	FT-FY20-122019-013097-A	<1	FT-FY20-122019-013097-B	<1
WS-013098	6/5/2019	6/5/2020	2	Cooler	In music room 214		WF-06052019-013098	12/27/2019	FT-FY20-122019-013098-A	<1	FT-FY20-122019-013098-B	<1
WS-013100	6/5/2019	6/5/2020	3	Combo Fountain	In classroom 318		WF-06052019-013100	12/27/2019	FT-FY20-122019-013100-A	<1	FT-FY20-122019-013100-B	<1
WS-013102	6/5/2019	6/5/2020	3	Combo Fountain	In classroom 317		WF-06052019-013102	12/27/2019	FT-FY20-122019-013102-A	<1	FT-FY20-122019-013102-B	<1
WS-013104	6/5/2019	6/5/2020	3	Combo Fountain	In classroom 316		WF-06052019-013104	12/27/2019	FT-FY20-122019-013104-A	<1	FT-FY20-122019-013104-B	<1
WS-013106	6/5/2019	6/5/2020	3	Combo Fountain	In classroom 315		WF-06052019-013106	12/27/2019	FT-FY20-122019-013106-A	<1	FT-FY20-122019-013106-B	<1
WS-013108	6/5/2019	6/5/2020	3	Combo Fountain	In classroom 314		WF-06052019-013108	12/27/2019	FT-FY20-122019-013108-A	<1	FT-FY20-122019-013108-B	<1
WS-013110	6/5/2019	6/5/2020	3	Combo Fountain	In classroom 313		WF-06052019-013110	12/27/2019	FT-FY20-122019-013110-A	<1	FT-FY20-122019-013110-B	<1
WS-013112	6/5/2019	6/5/2020	3	Combo Fountain	In workroom 309		WF-06052019-013112	12/27/2019	FT-FY20-122019-013112-A	<1	FT-FY20-122019-013112-B	<1
WS-013114	6/5/2019	6/5/2020	3	Combo Fountain	In instructional coach room 308		WF-06052019-013114	12/27/2019	FT-FY20-122019-013114-A	<1	FT-FY20-122019-013114-B	<1
WS-013116	6/5/2019	6/5/2020	3	Combo Fountain	In classroom 310		WF-06052019-013116	12/27/2019	FT-FY20-122019-013116-A	<1	FT-FY20-122019-013116-B	<1
WS-013117	6/5/2019	6/5/2020	3	Cooler	In hallway across from classroom 310	High Left	WF-06052019-013117	12/27/2019	FT-FY20-122019-013117-A	<1	FT-FY20-122019-013117-B	<1
WS-013118	6/5/2019	6/5/2020	3	Cooler	In hallway across from classroom 310	Low Right	WF-06052019-013118	12/27/2019	FT-FY20-122019-013118-A	<1	FT-FY20-122019-013118-B	<1
WS-013120	6/5/2019	6/5/2020	3	Combo Fountain	In classroom 306		WF-06052019-013120	12/27/2019	FT-FY20-122019-013120-A	<1	FT-FY20-122019-013120-B	<1

WS-013122	6/5/2019	6/5/2020	3	Combo Fountain	In classroom 305	WF-06052019-013122	12/27/2019	FT-FY20-122019-013122-A	<1	FT-FY20-122019-013122-B	<1
WS-013123	6/5/2019	6/5/2020	1	Fountain	In hallway across from extended day office 101 High Right	WF-06052019-013123	12/27/2019	FT-FY20-122019-013123-A	<1	FT-FY20-122019-013123-B	<1
WS-013124	6/5/2019	6/5/2020	1	Bottle Filler	In hallway across from classroom 127	WF-06052019-013124	12/27/2019	FT-FY20-122019-013124-A	<1	FT-FY20-122019-013124-B	<1
WS-013125	6/5/2019	6/5/2020	1	Bottle Filler	In cafeteria	WF-06052019-013125	12/27/2019	FT-FY20-122019-013125-A	<1	FT-FY20-122019-013125-B	<1
WS-013126	6/5/2019	6/5/2020	2	Bottle Filler	In hallway adjacent to security room 212	WF-06052019-013126	12/27/2019	FT-FY20-122019-013126-A	<1	FT-FY20-122019-013126-B	<1
WS-013127	6/5/2019	6/5/2020	2	Bottle Filler	In hallway across from classroom 234	WF-06052019-013127	12/27/2019	FT-FY20-122019-013127-A	<1	FT-FY20-122019-013127-B	<1
WS-013128	6/5/2019	6/5/2020	3	Bottle Filler	In hallway across from classroom 310	WF-06052019-013128	12/27/2019	FT-FY20-122019-013128-A	<1	FT-FY20-122019-013128-B	<1
WS-013129	6/5/2019	6/5/2020	1	Bottle Filler	In gym	WF-06052019-013129	12/27/2019	FT-FY20-122019-013129-A	<1	FT-FY20-122019-013129-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013048	7/17/2019	7/17/2020	1	Food Prep Sink	In rear of kitchen	WF-07172019-013048	12/27/2019	FT-FY20-122019-013048-A	<1	FT-FY20-122019-013048-B	<1

FY20 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013111	6/5/2019	6/5/2020	3	Break Room	In workroom 309	WF-06052019-013111	12/27/2019	FT-FY20-122019-013111-A	<1	FT-FY20-122019-013111-B	13