



Boone Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-013000	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 136	Low Left	WF-10062021-013000	2/8/2022	FT-FY22-01182022-013000-A	1.3	FT-FY22-01182022-013000-B	<1
WS-013001	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 136	Low Left	WF-04282021-013001	2/8/2022	FT-FY22-01182022-013001-A	1.7	FT-FY22-01182022-013001-B	<1
WS-013002	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 136	High Right	WF-10062021-013002	2/8/2022	FT-FY22-01182022-013002-A	1.8	FT-FY22-01182022-013002-B	<1
WS-013003	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 136	High Right	WF-04282021-013003	2/8/2022	FT-FY22-01182022-013003-A	1.7	FT-FY22-01182022-013003-B	<1
WS-013004	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 137	High Left	WF-10062021-013004	2/8/2022	FT-FY22-01182022-013004-A	<1	FT-FY22-01182022-013004-B	1.9
WS-013006	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 137	Low Right	WF-10062021-013006	2/8/2022	FT-FY22-01182022-013006-A	1.3	FT-FY22-01182022-013006-B	1.5
WS-013007	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 137	Low Right	WF-04282021-013007	2/8/2022	FT-FY22-01182022-013007-A	1.4	FT-FY22-01182022-013007-B	<1
WS-013008	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 134	High Left	WF-10062021-013008	2/8/2022	FT-FY22-01182022-013008-A	<1	FT-FY22-01182022-013008-B	<1
WS-013010	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 134	Low Right	WF-10062021-013010	2/8/2022	FT-FY22-01182022-013010-A	<1	FT-FY22-01182022-013010-B	<1
WS-013011	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 134	Low Right	WF-04282021-013011	2/8/2022	FT-FY22-01182022-013011-A	1.4	FT-FY22-01182022-013011-B	<1
WS-013012	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 135	Low Left	WF-10062021-013012	2/8/2022	FT-FY22-01182022-013012-A	<1	FT-FY22-01182022-013012-B	<1
WS-013013	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 135	Low Left	WF-04282021-013013	2/8/2022	FT-FY22-01182022-013013-A	<1	FT-FY22-01182022-013013-B	<1
WS-013014	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 135	High Right	WF-10062021-013014	2/8/2022	FT-FY22-01182022-013014-A	1.1	FT-FY22-01182022-013014-B	<1
WS-013015	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 135	High Right	WF-04282021-013015	2/8/2022	FT-FY22-01182022-013015-A	1.8	FT-FY22-01182022-013015-B	<1
WS-013016	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 133	High Left	WF-10062021-013016	2/8/2022	FT-FY22-01182022-013016-A	<1	FT-FY22-01182022-013016-B	<1
WS-013017	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 133	High Left	WF-04282021-013017	2/8/2022	FT-FY22-01182022-013017-A	<1	FT-FY22-01182022-013017-B	<1
WS-013018	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 133	Low Right	WF-10062021-013018	2/8/2022	FT-FY22-01182022-013018-A	<1	FT-FY22-01182022-013018-B	<1
WS-013019	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 133	Low Right	WF-04282021-013019	2/8/2022	FT-FY22-01182022-013019-A	<1	FT-FY22-01182022-013019-B	<1
WS-013021	4/28/2021	4/28/2022	1	Combo Fountain	In workroom 132		WF-04282021-013021	2/8/2022	FT-FY22-01182022-013021-A	<1	FT-FY22-01182022-013021-B	<1
WS-013023	4/28/2021	4/28/2022	1	Combo Fountain	In academic resource room 139		WF-04282021-013023	2/8/2022	FT-FY22-01182022-013023-A	<1	FT-FY22-01182022-013023-B	<1
WS-013024	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 131	Low Left	WF-10062021-013024	2/8/2022	FT-FY22-01182022-013024-A	<1	FT-FY22-01182022-013024-B	1.3
WS-013025	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 131	Low Left	WF-04282021-013025	2/8/2022	FT-FY22-01182022-013025-A	1.4	FT-FY22-01182022-013025-B	<1
WS-013026	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 131	High Right	WF-10062021-013026	2/8/2022	FT-FY22-01182022-013026-A	<1	FT-FY22-01182022-013026-B	<1
WS-013027	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 131	High Right	WF-04282021-013027	2/8/2022	FT-FY22-01182022-013027-A	2.5	FT-FY22-01182022-013027-B	<1
WS-013028	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 128	Low Left	WF-10062021-013028	2/8/2022	FT-FY22-01182022-013028-A	1.4	FT-FY22-01182022-013028-B	<1
WS-013029	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 128	Low Left	WF-04282021-013029	2/8/2022	FT-FY22-01182022-013029-A	<1	FT-FY22-01182022-013029-B	<1
WS-013030	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 128	High Right	WF-10062021-013030	2/8/2022	FT-FY22-01182022-013030-A	1.2	FT-FY22-01182022-013030-B	<1
WS-013031	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 128	High Right	WF-04282021-013031	2/8/2022	FT-FY22-01182022-013031-A	2.0	FT-FY22-01182022-013031-B	<1
WS-013032	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 126	High Left	WF-10062021-013032	2/8/2022	FT-FY22-01182022-013032-A	<1	FT-FY22-01182022-013032-B	<1
WS-013033	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 126	High Left	WF-04282021-013033	2/8/2022	FT-FY22-01182022-013033-A	<1	FT-FY22-01182022-013033-B	<1
WS-013034	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 126	Low Right	WF-10062021-013034	2/8/2022	FT-FY22-01182022-013034-A	<1	FT-FY22-01182022-013034-B	<1
WS-013035	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 126	Low Right	WF-04282021-013035	2/8/2022	FT-FY22-01182022-013035-A	<1	FT-FY22-01182022-013035-B	<1
WS-013036	4/28/2021	4/28/2022	1	Cooler	In hallway across from classroom 127	Low Right	WF-04282021-013036	2/8/2022	FT-FY22-01182022-013036-A	<1	FT-FY22-01182022-013036-B	<1
WS-013037	4/28/2021	4/28/2022	1	Cooler	In hallway across from classroom 127	High Left	WF-04282021-013037	2/8/2022	FT-FY22-01182022-013037-A	<1	FT-FY22-01182022-013037-B	<1
WS-013038	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 127	High Left	WF-10062021-013038	2/8/2022	FT-FY22-01182022-013038-A	1.0	FT-FY22-01182022-013038-B	<1
WS-013039	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 127	High Left	WF-04282021-013039	2/8/2022	FT-FY22-01182022-013039-A	1.9	FT-FY22-01182022-013039-B	<1
WS-013040	10/6/2021	10/6/2022	1	Combo Faucet	In classroom 127	Low Right	WF-10062021-013040	2/8/2022	FT-FY22-01182022-013040-A	<1	FT-FY22-01182022-013040-B	<1

WS-013041	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 127	Low	Right	WF-04282021-013041	2/8/2022	FT-FY22-01182022-013041-A	<1	FT-FY22-01182022-013041-B	<1
WS-013052	4/28/2021	4/28/2022	1	Cooler	In cafeteria	High	Left	WF-04282021-013052	2/8/2022	FT-FY22-01182022-013052-A	<1	FT-FY22-01182022-013052-B	<1
WS-013053	4/28/2021	4/28/2022	1	Cooler	In cafeteria	Low	Right	WF-04282021-013053	2/8/2022	FT-FY22-01182022-013053-A	<1	FT-FY22-01182022-013053-B	<1
WS-013054	4/28/2021	4/28/2022	1	Health Suite	In treatment room 110b			WF-04282021-013054	2/8/2022	FT-FY22-01182022-013054-A	<1	FT-FY22-01182022-013054-B	<1
WS-013055	4/28/2021	4/28/2022	1	Combo Fountain	In treatment room 110b			WF-04282021-013055	2/8/2022	FT-FY22-01182022-013055-A	<1	FT-FY22-01182022-013055-B	<1
WS-013065	4/28/2021	4/28/2022	2	Combo Fountain	In science classroom 245 second clockwise from entry door			WF-04282021-013065	2/8/2022	FT-FY22-01182022-013065-A	<1	FT-FY22-01182022-013065-B	<1
WS-013067	4/28/2021	4/28/2022	2	Combo Fountain	In science classroom 245 first clockwise from entry door			WF-04282021-013067	2/8/2022	FT-FY22-01182022-013067-A	<1	FT-FY22-01182022-013067-B	<1
WS-013069	4/28/2021	4/28/2022	2	Combo Fountain	In classroom 243			WF-04282021-013069	2/8/2022	FT-FY22-01182022-013069-A	<1	FT-FY22-01182022-013069-B	<1
WS-013071	4/28/2021	4/28/2022	2	Combo Fountain	In classroom 244			WF-04282021-013071	2/8/2022	FT-FY22-01182022-013071-A	<1	FT-FY22-01182022-013071-B	<1
WS-013073	4/28/2021	4/28/2022	2	Combo Fountain	In classroom 242			WF-04282021-013073	2/8/2022	FT-FY22-01182022-013073-A	<1	FT-FY22-01182022-013073-B	<1
WS-013075	4/28/2021	4/28/2022	2	Combo Fountain	In classroom 241			WF-04282021-013075	2/8/2022	FT-FY22-01182022-013075-A	<1	FT-FY22-01182022-013075-B	<1
WS-013077	4/28/2021	4/28/2022	2	Combo Fountain	In workroom 239			WF-04282021-013077	2/8/2022	FT-FY22-01182022-013077-A	<1	FT-FY22-01182022-013077-B	<1
WS-013079	4/28/2021	4/28/2022	2	Combo Fountain	In room 237b inside reading learning center 237			WF-04282021-013079	2/8/2022	FT-FY22-01182022-013079-A	2.6	FT-FY22-01182022-013079-B	<1
WS-013080	4/28/2021	4/28/2022	2	Cooler	In hallway across from classroom 234	High	Left	WF-04282021-013080	2/8/2022	FT-FY22-01182022-013080-A	<1	FT-FY22-01182022-013080-B	<1
WS-013081	4/28/2021	4/28/2022	2	Cooler	In hallway across from classroom 234	Low	Right	WF-04282021-013081	2/8/2022	FT-FY22-01182022-013081-A	<1	FT-FY22-01182022-013081-B	<1
WS-013083	4/28/2021	4/28/2022	2	Combo Fountain	In classroom 234			WF-04282021-013083	2/8/2022	FT-FY22-01182022-013083-A	<1	FT-FY22-01182022-013083-B	<1
WS-013085	4/28/2021	4/28/2022	2	Combo Fountain	In classroom 232			WF-04282021-013085	2/8/2022	FT-FY22-01182022-013085-A	<1	FT-FY22-01182022-013085-B	<1
WS-013087	4/28/2021	4/28/2022	2	Combo Fountain	In classroom 231			WF-04282021-013087	2/8/2022	FT-FY22-01182022-013087-A	<1	FT-FY22-01182022-013087-B	<1
WS-013091	4/28/2021	4/28/2022	2	Break Room	In staff lounge 209			WF-04282021-013091	2/8/2022	FT-FY22-01182022-013091-A	<1	FT-FY22-01182022-013091-B	<1
WS-013094	4/28/2021	4/28/2022	2	Cooler	In hallway adjacent to security room 212	High	Left	WF-04282021-013094	2/8/2022	FT-FY22-01182022-013094-A	<1	FT-FY22-01182022-013094-B	<1
WS-013095	4/28/2021	4/28/2022	2	Cooler	In hallway adjacent to security room 212	Low	Right	WF-04282021-013095	2/8/2022	FT-FY22-01182022-013095-A	<1	FT-FY22-01182022-013095-B	<1
WS-013097	4/28/2021	4/28/2022	2	Combo Fountain	In music room 214			WF-04282021-013097	2/8/2022	FT-FY22-01182022-013097-A	<1	FT-FY22-01182022-013097-B	<1
WS-013098	4/28/2021	4/28/2022	2	Cooler	In music room 214			WF-04282021-013098	2/8/2022	FT-FY22-01182022-013098-A	<1	FT-FY22-01182022-013098-B	<1
WS-013100	4/28/2021	4/28/2022	3	Combo Fountain	In classroom 318			WF-04282021-013100	2/8/2022	FT-FY22-01182022-013100-A	<1	FT-FY22-01182022-013100-B	<1
WS-013102	4/28/2021	4/28/2022	3	Combo Fountain	In classroom 317			WF-04282021-013102	2/8/2022	FT-FY22-01182022-013102-A	<1	FT-FY22-01182022-013102-B	<1
WS-013104	4/28/2021	4/28/2022	3	Combo Fountain	In classroom 316			WF-04282021-013104	2/8/2022	FT-FY22-01182022-013104-A	1.1	FT-FY22-01182022-013104-B	<1
WS-013106	4/28/2021	4/28/2022	3	Combo Fountain	In classroom 315			WF-04282021-013106	2/8/2022	FT-FY22-01182022-013106-A	<1	FT-FY22-01182022-013106-B	<1
WS-013108	4/28/2021	4/28/2022	3	Combo Fountain	In classroom 314			WF-04282021-013108	2/8/2022	FT-FY22-01182022-013108-A	1.5	FT-FY22-01182022-013108-B	<1
WS-013110	4/28/2021	4/28/2022	3	Combo Fountain	In classroom 313			WF-04282021-013110	2/8/2022	FT-FY22-01182022-013110-A	1.5	FT-FY22-01182022-013110-B	<1
WS-013111	4/28/2021	4/28/2022	3	Break Room	In workroom 309			WF-04282021-013111	2/8/2022	FT-FY22-01182022-013111-A	<1	FT-FY22-01182022-013111-B	<1
WS-013114	4/28/2021	4/28/2022	3	Combo Fountain	In instructional coach room 308			WF-04282021-013114	2/8/2022	FT-FY22-01182022-013114-A	<1	FT-FY22-01182022-013114-B	1.1
WS-013116	4/28/2021	4/28/2022	3	Combo Fountain	In classroom 310			WF-04282021-013116	2/8/2022	FT-FY22-01182022-013116-A	<1	FT-FY22-01182022-013116-B	<1
WS-013117	4/28/2021	4/28/2022	3	Cooler	In hallway across from classroom 310	High	Left	WF-04282021-013117	2/8/2022	FT-FY22-01182022-013117-A	<1	FT-FY22-01182022-013117-B	<1
WS-013118	4/28/2021	4/28/2022	3	Cooler	In hallway across from classroom 310	Low	Right	WF-04282021-013118	2/8/2022	FT-FY22-01182022-013118-A	<1	FT-FY22-01182022-013118-B	<1
WS-013120	4/28/2021	4/28/2022	3	Combo Fountain	In classroom 306			WF-04282021-013120	2/8/2022	FT-FY22-01182022-013120-A	<1	FT-FY22-01182022-013120-B	<1
WS-013122	4/28/2021	4/28/2022	3	Combo Fountain	In classroom 305			WF-04282021-013122	2/8/2022	FT-FY22-01182022-013122-A	<1	FT-FY22-01182022-013122-B	<1
WS-013123	4/28/2021	4/28/2022	1	Fountain	In hallway across from extended day office 101	High	Right	WF-04282021-013123	2/8/2022	FT-FY22-01182022-013123-A	<1	FT-FY22-01182022-013123-B	<1
WS-013124	4/28/2021	4/28/2022	1	Bottle Filler	In hallway across from classroom 127			WF-04282021-013124	2/8/2022	FT-FY22-01182022-013124-A	<1	FT-FY22-01182022-013124-B	<1
WS-013125	4/28/2021	4/28/2022	1	Bottle Filler	In cafeteria			WF-04282021-013125	2/8/2022	FT-FY22-01182022-013125-A	<1	FT-FY22-01182022-013125-B	<1
WS-013126	4/28/2021	4/28/2022	2	Bottle Filler	In hallway adjacent to security room 212			WF-04282021-013126	2/8/2022	FT-FY22-01182022-013126-A	<1	FT-FY22-01182022-013126-B	<1
WS-013127	4/28/2021	4/28/2022	2	Bottle Filler	In hallway across from classroom 234			WF-04282021-013127	2/8/2022	FT-FY22-01182022-013127-A	<1	FT-FY22-01182022-013127-B	<1
WS-013128	4/28/2021	4/28/2022	3	Bottle Filler	In hallway across from classroom 310			WF-04282021-013128	2/8/2022	FT-FY22-01182022-013128-A	<1	FT-FY22-01182022-013128-B	<1
WS-013129	4/28/2021	4/28/2022	1	Bottle Filler	In gym			WF-04282021-013129	2/8/2022	FT-FY22-01182022-013129-A	<1	FT-FY22-01182022-013129-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013048	1/10/2022	1/10/2023	1	Food Prep Sink	In rear of kitchen	WF-01102022-013048	2/8/2022	FT-FY22-01182022-013048-A	<1	FT-FY22-01182022-013048-B	<1

FY22 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013005	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 137 High Left	WF-04282021-013005	2/8/2022	FT-FY22-01182022-013005-A	6.6	FT-FY22-01182022-013005-B	<1
WS-013009	4/28/2021	4/28/2022	1	Combo Fountain	In classroom 134 High Left	WF-04282021-013009	2/8/2022	FT-FY22-01182022-013009-A	7.9	FT-FY22-01182022-013009-B	1.7
WS-013112	4/28/2021	4/28/2022	3	Combo Fountain	In workroom 309	WF-04282021-013112	2/8/2022	FT-FY22-01182022-013112-A	6.1	FT-FY22-01182022-013112-B	<1