



Boone Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013000	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 136	WF-09172024-013000	2/19/2025	FT-FY25-12262024-013000-A	4.1	FT-FY25-12262024-013000-B	<2
WS-013001	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 136	WF-04022024-013001	2/19/2025	FT-FY25-12262024-013001-A	<2	FT-FY25-12262024-013001-B	<2
WS-013002	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 136	WF-09172024-013002	2/19/2025	FT-FY25-12262024-013002-A	3.5	FT-FY25-12262024-013002-B	<2
WS-013003	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 136	WF-04022024-013003	2/19/2025	FT-FY25-12262024-013003-A	<2	FT-FY25-12262024-013003-B	<2
WS-013004	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 137	WF-09172024-013004	2/19/2025	FT-FY25-12262024-013004-A	4.9	FT-FY25-12262024-013004-B	<2
WS-013005	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 137	WF-04022024-013005	2/19/2025	FT-FY25-12262024-013005-A	<2	FT-FY25-12262024-013005-B	<2
WS-013007	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 137	WF-04022024-013007	2/19/2025	FT-FY25-12262024-013007-A	<2	FT-FY25-12262024-013007-B	<2
WS-013011	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 134	WF-04022024-013011	2/19/2025	FT-FY25-12262024-013011-A	<2	FT-FY25-12262024-013011-B	<2
WS-013012	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 135	WF-09172024-013012	2/19/2025	FT-FY25-12262024-013012-A	<2	FT-FY25-12262024-013012-B	<2
WS-013013	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 135	WF-04022024-013013	2/19/2025	FT-FY25-12262024-013013-A	<2	FT-FY25-12262024-013013-B	<2
WS-013014	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 135	WF-09172024-013014	2/19/2025	FT-FY25-12262024-013014-A	2.9	FT-FY25-12262024-013014-B	<2
WS-013015	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 135	WF-04022024-013015	2/19/2025	FT-FY25-12262024-013015-A	<2	FT-FY25-12262024-013015-B	<2
WS-013019	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 133	WF-04022024-013019	2/19/2025	FT-FY25-12262024-013019-A	<2	FT-FY25-12262024-013019-B	<2
WS-013021	4/2/2024	4/2/2025	1	Combo Fountain	In workroom 132	WF-04022024-013021	2/19/2025	FT-FY25-12262024-013021-A	<2	FT-FY25-12262024-013021-B	<2
WS-013023	4/2/2024	4/2/2025	1	Combo Fountain	In academic resource room 139	WF-04022024-013023	2/19/2025	FT-FY25-12262024-013023-A	<2	FT-FY25-12262024-013023-B	<2
WS-013027	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 131	WF-04022024-013027	2/19/2025	FT-FY25-12262024-013027-A	<2	FT-FY25-12262024-013027-B	<2
WS-013029	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 128	WF-04022024-013029	2/19/2025	FT-FY25-12262024-013029-A	<2	FT-FY25-12262024-013029-B	<2
WS-013031	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 128	WF-04022024-013031	2/19/2025	FT-FY25-12262024-013031-A	<2	FT-FY25-12262024-013031-B	<2
WS-013032	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 126	WF-09172024-013032	2/19/2025	FT-FY25-12262024-013032-A	2.6	FT-FY25-12262024-013032-B	<2
WS-013033	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 126	WF-04022024-013033	2/19/2025	FT-FY25-12262024-013033-A	<2	FT-FY25-12262024-013033-B	<2
WS-013034	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 126	WF-09172024-013034	2/19/2025	FT-FY25-12262024-013034-A	<2	FT-FY25-12262024-013034-B	<2
WS-013035	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 126	WF-04022024-013035	2/19/2025	FT-FY25-12262024-013035-A	<2	FT-FY25-12262024-013035-B	<2
WS-013036	4/2/2024	4/2/2025	1	Cooler	In hallway across from classroom 127	WF-04022024-013036	2/19/2025	FT-FY25-12262024-013036-A	<2	FT-FY25-12262024-013036-B	<2
WS-013037	4/2/2024	4/2/2025	1	Cooler	In hallway across from classroom 127	WF-04022024-013037	2/19/2025	FT-FY25-12262024-013037-A	<2	FT-FY25-12262024-013037-B	<2
WS-013038	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 127	WF-09172024-013038	2/19/2025	FT-FY25-12262024-013038-A	2.9	FT-FY25-12262024-013038-B	<2
WS-013039	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 127	WF-04022024-013039	2/19/2025	FT-FY25-12262024-013039-A	<2	FT-FY25-12262024-013039-B	<2
WS-013040	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 127	WF-09172024-013040	2/19/2025	FT-FY25-12262024-013040-A	<2	FT-FY25-12262024-013040-B	<2
WS-013041	4/2/2024	4/2/2025	1	Combo Fountain	In classroom 127	WF-04022024-013041	2/19/2025	FT-FY25-12262024-013041-A	<2	FT-FY25-12262024-013041-B	<2
WS-013054	4/2/2024	4/2/2025	1	Health Suite	In treatment room 110b	WF-04022024-013054	2/19/2025	FT-FY25-12262024-013054-A	<2	FT-FY25-12262024-013054-B	<2
WS-013055	4/2/2024	4/2/2025	1	Combo Fountain	In treatment room 110b	WF-04022024-013055	2/19/2025	FT-FY25-12262024-013055-A	<2	FT-FY25-12262024-013055-B	<2
WS-013069	4/2/2024	4/2/2025	2	Combo Fountain	In classroom 243	WF-04022024-013069	2/19/2025	FT-FY25-12262024-013069-A	<2	FT-FY25-12262024-013069-B	<2
WS-013071	4/2/2024	4/2/2025	2	Combo Fountain	In classroom 244	WF-04022024-013071	2/19/2025	FT-FY25-12262024-013071-A	<2	FT-FY25-12262024-013071-B	<2
WS-013073	4/2/2024	4/2/2025	2	Combo Fountain	In classroom 242	WF-04022024-013073	2/19/2025	FT-FY25-12262024-013073-A	<2	FT-FY25-12262024-013073-B	<2
WS-013075	4/2/2024	4/2/2025	2	Combo Fountain	In classroom 241	WF-04022024-013075	2/19/2025	FT-FY25-12262024-013075-A	<2	FT-FY25-12262024-013075-B	<2

WS-013077	4/2/2024	4/2/2025	2	Combo Fountain	In workroom 239		WF-04022024-013077	2/19/2025	FT-FY25-12262024-013077-A	<2	FT-FY25-12262024-013077-B	<2
WS-013079	4/2/2024	4/2/2025	2	Combo Fountain	In room 237b inside reading learning center 237		WF-04022024-013079	2/19/2025	FT-FY25-12262024-013079-A	<2	FT-FY25-12262024-013079-B	<2
WS-013080	4/2/2024	4/2/2025	2	Cooler	In hallway across from classroom 234	High Left	WF-04022024-013080	2/19/2025	FT-FY25-12262024-013080-A	<2	FT-FY25-12262024-013080-B	<2
WS-013081	4/2/2024	4/2/2025	2	Cooler	In hallway across from classroom 234	Low Right	WF-04022024-013081	2/19/2025	FT-FY25-12262024-013081-A	<2	FT-FY25-12262024-013081-B	<2
WS-013083	4/2/2024	4/2/2025	2	Combo Fountain	In classroom 234		WF-04022024-013083	2/19/2025	FT-FY25-12262024-013083-A	<2	FT-FY25-12262024-013083-B	<2
WS-013091	4/2/2024	4/2/2025	2	Break Room	In staff lounge 209		WF-04022024-013091	2/19/2025	FT-FY25-12262024-013091-A	<2	FT-FY25-12262024-013091-B	<2
WS-013094	4/2/2024	4/2/2025	2	Cooler	In hallway adjacent to security room 212	High Left	WF-04022024-013094	2/19/2025	FT-FY25-12262024-013094-A	<2	FT-FY25-12262024-013094-B	<2
WS-013095	4/2/2024	4/2/2025	2	Cooler	In hallway adjacent to security room 212	Low Right	WF-04022024-013095	2/19/2025	FT-FY25-12262024-013095-A	<2	FT-FY25-12262024-013095-B	<2
WS-013097	4/2/2024	4/2/2025	2	Combo Fountain	In music room 214		WF-04022024-013097	2/19/2025	FT-FY25-12262024-013097-A	<2	FT-FY25-12262024-013097-B	<2
WS-013098	4/2/2024	4/2/2025	2	Cooler	In music room 214		WF-04022024-013098	2/19/2025	FT-FY25-12262024-013098-A	<2	FT-FY25-12262024-013098-B	<2
WS-013100	4/2/2024	4/2/2025	3	Combo Fountain	In classroom 318		WF-04022024-013100	2/19/2025	FT-FY25-12262024-013100-A	<2	FT-FY25-12262024-013100-B	<2
WS-013102	4/2/2024	4/2/2025	3	Combo Fountain	In classroom 317		WF-04022024-013102	2/19/2025	FT-FY25-12262024-013102-A	<2	FT-FY25-12262024-013102-B	<2
WS-013104	4/2/2024	4/2/2025	3	Combo Fountain	In classroom 316		WF-04022024-013104	2/19/2025	FT-FY25-12262024-013104-A	<2	FT-FY25-12262024-013104-B	<2
WS-013106	4/2/2024	4/2/2025	3	Combo Fountain	In classroom 315		WF-04022024-013106	2/19/2025	FT-FY25-12262024-013106-A	<2	FT-FY25-12262024-013106-B	<2
WS-013108	4/2/2024	4/2/2025	3	Combo Fountain	In classroom 314		WF-04022024-013108	2/19/2025	FT-FY25-12262024-013108-A	<2	FT-FY25-12262024-013108-B	<2
WS-013110	4/2/2024	4/2/2025	3	Combo Fountain	In classroom 313		WF-04022024-013110	2/19/2025	FT-FY25-12262024-013110-A	<2	FT-FY25-12262024-013110-B	<2
WS-013111	4/2/2024	4/2/2025	3	Break Room	In workroom 309		WF-04022024-013111	2/19/2025	FT-FY25-12262024-013111-A	<2	FT-FY25-12262024-013111-B	<2
WS-013112	4/2/2024	4/2/2025	3	Combo Fountain	In workroom 309		WF-04022024-013112	2/19/2025	FT-FY25-12262024-013112-A	<2	FT-FY25-12262024-013112-B	<2
WS-013114	4/2/2024	4/2/2025	3	Combo Fountain	In instructional coach room 308		WF-04022024-013114	2/19/2025	FT-FY25-12262024-013114-A	<2	FT-FY25-12262024-013114-B	<2
WS-013116	4/2/2024	4/2/2025	3	Combo Fountain	In classroom 310		WF-04022024-013116	2/19/2025	FT-FY25-12262024-013116-A	<2	FT-FY25-12262024-013116-B	<2
WS-013117	4/2/2024	4/2/2025	3	Cooler	In hallway across from classroom 310	High Left	WF-04022024-013117	2/19/2025	FT-FY25-12262024-013117-A	<2	FT-FY25-12262024-013117-B	<2
WS-013118	4/2/2024	4/2/2025	3	Cooler	In hallway across from classroom 310	Low Right	WF-04022024-013118	2/19/2025	FT-FY25-12262024-013118-A	<2	FT-FY25-12262024-013118-B	<2
WS-013120	4/2/2024	4/2/2025	3	Combo Fountain	In classroom 306		WF-04022024-013120	2/19/2025	FT-FY25-12262024-013120-A	<2	FT-FY25-12262024-013120-B	<2
WS-013122	4/2/2024	4/2/2025	3	Combo Fountain	In classroom 305		WF-04022024-013122	2/19/2025	FT-FY25-12262024-013122-A	<2	FT-FY25-12262024-013122-B	<2
WS-013126	4/2/2024	4/2/2025	2	Bottle Filler	In hallway adjacent to security room 212		WF-04022024-013126	2/19/2025	FT-FY25-12262024-013126-A	<2	FT-FY25-12262024-013126-B	<2
WS-013128	4/2/2024	4/2/2025	3	Bottle Filler	In hallway across from classroom 310		WF-04022024-013128	2/19/2025	FT-FY25-12262024-013128-A	<2	FT-FY25-12262024-013128-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013048	11/18/2024	11/18/2025	1	Food Prep Sink	In rear of kitchen	WF-11182024-013048	2/19/2025	FT-FY25-12262024-013048-A	<2	FT-FY25-12262024-013048-B	<2

FY25 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013006	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 137	WF-09172024-013006	2/19/2025	FT-FY25-12262024-013006-A	5.2	FT-FY25-12262024-013006-B	<2
WS-013008	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 134	WF-09172024-013008	2/19/2025	FT-FY25-12262024-013008-A	6.3	FT-FY25-12262024-013008-B	<2
WS-013010	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 134	WF-09172024-013010	2/19/2025	FT-FY25-12262024-013010-A	5.3	FT-FY25-12262024-013010-B	<2
WS-013016	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 133	WF-09172024-013016	2/19/2025	FT-FY25-12262024-013016-A	6.7	FT-FY25-12262024-013016-B	<2
WS-013018	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 133	WF-09172024-013018	2/19/2025	FT-FY25-12262024-013018-A	5.6	FT-FY25-12262024-013018-B	<2

WS-013024	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 131	Low Left	WF-09172024-013024	2/19/2025	FT-FY25-12262024-013024-A	6.5	FT-FY25-12262024-013024-B	<2
WS-013026	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 131	High Right	WF-09172024-013026	2/19/2025	FT-FY25-12262024-013026-A	6.1	FT-FY25-12262024-013026-B	<2
WS-013028	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 128	Low Left	WF-09172024-013028	2/19/2025	FT-FY25-12262024-013028-A	9.6	FT-FY25-12262024-013028-B	<2
WS-013030	9/17/2024	9/17/2025	1	Combo Faucet	In classroom 128	High Right	WF-09172024-013030	2/19/2025	FT-FY25-12262024-013030-A	5.0	FT-FY25-12262024-013030-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.