



# Boone Elementary School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-013000	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 136	Low Left	WF-10142020-013000	3/22/2021	FT-FY21-032021-013000-A	<1	FT-FY21-032021-013000-B	<1
WS-013001	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 136	Low Left	WF-05282020-013001	3/22/2021	FT-FY21-032021-013001-A	<1	FT-FY21-032021-013001-B	<1
WS-013002	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 136	High Right	WF-10142020-013002	3/22/2021	FT-FY21-032021-013002-A	<1	FT-FY21-032021-013002-B	<1
WS-013003	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 136	High Right	WF-05282020-013003	3/22/2021	FT-FY21-032021-013003-A	<1	FT-FY21-032021-013003-B	<1
WS-013004	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 137	High Left	WF-10142020-013004	3/22/2021	FT-FY21-032021-013004-A	<1	FT-FY21-032021-013004-B	<1
WS-013005	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 137	High Left	WF-05282020-013005	3/22/2021	FT-FY21-032021-013005-A	<1	FT-FY21-032021-013005-B	<1
WS-013006	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 137	Low Right	WF-10142020-013006	3/22/2021	FT-FY21-032021-013006-A	<1	FT-FY21-032021-013006-B	<1
WS-013007	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 137	Low Right	WF-05282020-013007	3/22/2021	FT-FY21-032021-013007-A	<1	FT-FY21-032021-013007-B	<1
WS-013008	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 134	High Left	WF-10142020-013008	3/22/2021	FT-FY21-032021-013008-A	<1	FT-FY21-032021-013008-B	<1
WS-013009	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 134	High Left	WF-05282020-013009	3/22/2021	FT-FY21-032021-013009-A	<1	FT-FY21-032021-013009-B	<1
WS-013010	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 134	Low Right	WF-10142020-013010	3/22/2021	FT-FY21-032021-013010-A	<1	FT-FY21-032021-013010-B	<1
WS-013011	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 134	Low Right	WF-05282020-013011	3/22/2021	FT-FY21-032021-013011-A	<1	FT-FY21-032021-013011-B	<1
WS-013012	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 135	Low Left	WF-10142020-013012	3/22/2021	FT-FY21-032021-013012-A	<1	FT-FY21-032021-013012-B	<1
WS-013013	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 135	Low Left	WF-05282020-013013	3/22/2021	FT-FY21-032021-013013-A	<1	FT-FY21-032021-013013-B	<1
WS-013014	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 135	High Right	WF-10142020-013014	3/22/2021	FT-FY21-032021-013014-A	<1	FT-FY21-032021-013014-B	<1
WS-013015	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 135	High Right	WF-05282020-013015	3/22/2021	FT-FY21-032021-013015-A	<1	FT-FY21-032021-013015-B	<1
WS-013016	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 133	High Left	WF-10142020-013016	3/22/2021	FT-FY21-032021-013016-A	<1	FT-FY21-032021-013016-B	<1
WS-013017	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 133	High Left	WF-05282020-013017	3/22/2021	FT-FY21-032021-013017-A	<1	FT-FY21-032021-013017-B	<1
WS-013018	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 133	Low Right	WF-10142020-013018	3/22/2021	FT-FY21-032021-013018-A	<1	FT-FY21-032021-013018-B	<1
WS-013019	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 133	Low Right	WF-05282020-013019	3/22/2021	FT-FY21-032021-013019-A	<1	FT-FY21-032021-013019-B	<1
WS-013021	5/28/2020	5/28/2021	1	Combo Fountain	In workroom 132		WF-05282020-013021	3/22/2021	FT-FY21-032021-013021-A	<1	FT-FY21-032021-013021-B	<1
WS-013023	5/28/2020	5/28/2021	1	Combo Fountain	In academic resource room 139		WF-05282020-013023	3/22/2021	FT-FY21-032021-013023-A	1.4	FT-FY21-032021-013023-B	1.2
WS-013024	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 131	Low Left	WF-10142020-013024	3/22/2021	FT-FY21-032021-013024-A	<1	FT-FY21-032021-013024-B	<1
WS-013025	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 131	Low Left	WF-05282020-013025	3/22/2021	FT-FY21-032021-013025-A	<1	FT-FY21-032021-013025-B	<1
WS-013026	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 131	High Right	WF-10142020-013026	3/22/2021	FT-FY21-032021-013026-A	<1	FT-FY21-032021-013026-B	<1
WS-013027	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 131	High Right	WF-05282020-013027	3/22/2021	FT-FY21-032021-013027-A	<1	FT-FY21-032021-013027-B	<1
WS-013028	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 128	Low Left	WF-10142020-013028	3/22/2021	FT-FY21-032021-013028-A	<1	FT-FY21-032021-013028-B	<1
WS-013029	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 128	Low Left	WF-05282020-013029	3/22/2021	FT-FY21-032021-013029-A	<1	FT-FY21-032021-013029-B	<1
WS-013030	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 128	High Right	WF-10142020-013030	3/22/2021	FT-FY21-032021-013030-A	<1	FT-FY21-032021-013030-B	<1
WS-013031	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 128	High Right	WF-05282020-013031	3/22/2021	FT-FY21-032021-013031-A	<1	FT-FY21-032021-013031-B	<1
WS-013032	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 126	High Left	WF-10142020-013032	3/22/2021	FT-FY21-032021-013032-A	<1	FT-FY21-032021-013032-B	<1
WS-013033	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 126	High Left	WF-05282020-013033	3/22/2021	FT-FY21-032021-013033-A	<1	FT-FY21-032021-013033-B	<1
WS-013034	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 126	Low Right	WF-10142020-013034	3/22/2021	FT-FY21-032021-013034-A	<1	FT-FY21-032021-013034-B	<1
WS-013035	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 126	Low Right	WF-05282020-013035	3/22/2021	FT-FY21-032021-013035-A	<1	FT-FY21-032021-013035-B	<1

WS-013036	5/28/2020	5/28/2021	1	Cooler	In hallway across from classroom 127	Low	Right	WF-05282020-013036	3/22/2021	FT-FY21-032021-013036-A	<1	FT-FY21-032021-013036-B	<1
WS-013037	5/28/2020	5/28/2021	1	Cooler	In hallway across from classroom 127	High	Left	WF-05282020-013037	3/22/2021	FT-FY21-032021-013037-A	<1	FT-FY21-032021-013037-B	<1
WS-013038	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 127	High	Left	WF-10142020-013038	3/22/2021	FT-FY21-032021-013038-A	<1	FT-FY21-032021-013038-B	<1
WS-013039	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 127	High	Left	WF-05282020-013039	3/22/2021	FT-FY21-032021-013039-A	<1	FT-FY21-032021-013039-B	<1
WS-013040	10/14/2020	10/14/2021	1	Combo Faucet	In classroom 127	Low	Right	WF-10142020-013040	3/22/2021	FT-FY21-032021-013040-A	<1	FT-FY21-032021-013040-B	<1
WS-013041	5/28/2020	5/28/2021	1	Combo Fountain	In classroom 127	Low	Right	WF-05282020-013041	3/22/2021	FT-FY21-032021-013041-A	<1	FT-FY21-032021-013041-B	<1
WS-013052	5/28/2020	5/28/2021	1	Cooler	In cafeteria	High	Left	WF-05282020-013052	3/22/2021	FT-FY21-032021-013052-A	<1	FT-FY21-032021-013052-B	<1
WS-013053	5/28/2020	5/28/2021	1	Cooler	In cafeteria	Low	Right	WF-05282020-013053	3/22/2021	FT-FY21-032021-013053-A	<1	FT-FY21-032021-013053-B	<1
WS-013054	5/28/2020	5/28/2021	1	Health Suite	In treatment room 110b			WF-05282020-013054	3/22/2021	FT-FY21-032021-013054-A	<1	FT-FY21-032021-013054-B	<1
WS-013055	5/28/2020	5/28/2021	1	Combo Fountain	In treatment room 110b			WF-05282020-013055	3/22/2021	FT-FY21-032021-013055-A	<1	FT-FY21-032021-013055-B	<1
WS-013056	5/28/2020	5/28/2021	1	Bottle Filler	In hallway across from extended day office 101			WF-05282020-013056	3/22/2021	FT-FY21-032021-013056-A	<1	FT-FY21-032021-013056-B	<1
WS-013057	5/28/2020	5/28/2021	1	Fountain	In hallway across from extended day office 101	Low	Left	WF-05282020-013057	3/22/2021	FT-FY21-032021-013057-A	<1	FT-FY21-032021-013057-B	<1
WS-013065	5/28/2020	5/28/2021	2	Combo Fountain	In science classroom 245 second clockwise from entry door			WF-05282020-013065	3/22/2021	FT-FY21-032021-013065-A	<1	FT-FY21-032021-013065-B	<1
WS-013067	5/28/2020	5/28/2021	2	Combo Fountain	In science classroom 245 first clockwise from entry door			WF-05282020-013067	3/22/2021	FT-FY21-032021-013067-A	1.0	FT-FY21-032021-013067-B	<1
WS-013069	5/28/2020	5/28/2021	2	Combo Fountain	In classroom 243			WF-05282020-013069	3/22/2021	FT-FY21-032021-013069-A	<1	FT-FY21-032021-013069-B	<1
WS-013071	5/28/2020	5/28/2021	2	Combo Fountain	In classroom 244			WF-05282020-013071	3/22/2021	FT-FY21-032021-013071-A	<1	FT-FY21-032021-013071-B	<1
WS-013073	5/28/2020	5/28/2021	2	Combo Fountain	In classroom 242			WF-05282020-013073	3/22/2021	FT-FY21-032021-013073-A	<1	FT-FY21-032021-013073-B	<1
WS-013075	5/28/2020	5/28/2021	2	Combo Fountain	In classroom 241			WF-05282020-013075	3/22/2021	FT-FY21-032021-013075-A	<1	FT-FY21-032021-013075-B	<1
WS-013077	5/28/2020	5/28/2021	2	Combo Fountain	In workroom 239			WF-05282020-013077	3/22/2021	FT-FY21-032021-013077-A	<1	FT-FY21-032021-013077-B	<1
WS-013079	5/28/2020	5/28/2021	2	Combo Fountain	In room 237b inside reading learning center 237			WF-05282020-013079	3/22/2021	FT-FY21-032021-013079-A	<1	FT-FY21-032021-013079-B	<1
WS-013080	5/28/2020	5/28/2021	2	Cooler	In hallway across from classroom 234	High	Left	WF-05282020-013080	3/22/2021	FT-FY21-032021-013080-A	<1	FT-FY21-032021-013080-B	<1
WS-013081	5/28/2020	5/28/2021	2	Cooler	In hallway across from classroom 234	Low	Right	WF-05282020-013081	3/22/2021	FT-FY21-032021-013081-A	<1	FT-FY21-032021-013081-B	<1
WS-013083	5/28/2020	5/28/2021	2	Combo Fountain	In classroom 234			WF-05282020-013083	3/22/2021	FT-FY21-032021-013083-A	<1	FT-FY21-032021-013083-B	<1
WS-013085	5/28/2020	5/28/2021	2	Combo Fountain	In classroom 232			WF-05282020-013085	3/22/2021	FT-FY21-032021-013085-A	<1	FT-FY21-032021-013085-B	<1
WS-013087	5/28/2020	5/28/2021	2	Combo Fountain	In classroom 231			WF-05282020-013087	3/22/2021	FT-FY21-032021-013087-A	<1	FT-FY21-032021-013087-B	<1
WS-013091	5/28/2020	5/28/2021	2	Break Room	In staff lounge 209			WF-05282020-013091	3/22/2021	FT-FY21-032021-013091-A	<1	FT-FY21-032021-013091-B	<1
WS-013094	5/28/2020	5/28/2021	2	Cooler	In hallway adjacent to security room 212	High	Left	WF-05282020-013094	3/22/2021	FT-FY21-032021-013094-A	<1	FT-FY21-032021-013094-B	<1
WS-013095	5/28/2020	5/28/2021	2	Cooler	In hallway adjacent to security room 212	Low	Right	WF-05282020-013095	3/22/2021	FT-FY21-032021-013095-A	<1	FT-FY21-032021-013095-B	<1
WS-013097	5/28/2020	5/28/2021	2	Combo Fountain	In music room 214			WF-05282020-013097	3/22/2021	FT-FY21-032021-013097-A	<1	FT-FY21-032021-013097-B	<1
WS-013098	5/28/2020	5/28/2021	2	Cooler	In music room 214			WF-05282020-013098	3/22/2021	FT-FY21-032021-013098-A	<1	FT-FY21-032021-013098-B	<1
WS-013100	5/28/2020	5/28/2021	3	Combo Fountain	In classroom 318			WF-05282020-013100	3/22/2021	FT-FY21-032021-013100-A	<1	FT-FY21-032021-013100-B	<1
WS-013102	5/28/2020	5/28/2021	3	Combo Fountain	In classroom 317			WF-05282020-013102	3/22/2021	FT-FY21-032021-013102-A	<1	FT-FY21-032021-013102-B	<1
WS-013104	5/28/2020	5/28/2021	3	Combo Fountain	In classroom 316			WF-05282020-013104	3/22/2021	FT-FY21-032021-013104-A	<1	FT-FY21-032021-013104-B	<1
WS-013106	5/28/2020	5/28/2021	3	Combo Fountain	In classroom 315			WF-05282020-013106	3/22/2021	FT-FY21-032021-013106-A	<1	FT-FY21-032021-013106-B	<1
WS-013108	5/28/2020	5/28/2021	3	Combo Fountain	In classroom 314			WF-05282020-013108	3/22/2021	FT-FY21-032021-013108-A	<1	FT-FY21-032021-013108-B	<1
WS-013110	5/28/2020	5/28/2021	3	Combo Fountain	In classroom 313			WF-05282020-013110	3/22/2021	FT-FY21-032021-013110-A	<1	FT-FY21-032021-013110-B	<1
WS-013111	5/28/2020	5/28/2021	3	Break Room	In workroom 309			WF-05282020-013111	3/22/2021	FT-FY21-032021-013111-A	<1	FT-FY21-032021-013111-B	<1
WS-013112	5/28/2020	5/28/2021	3	Combo Fountain	In workroom 309			WF-05282020-013112	3/22/2021	FT-FY21-032021-013112-A	<1	FT-FY21-032021-013112-B	<1
WS-013114	5/28/2020	5/28/2021	3	Combo Fountain	In instructional coach room 308			WF-05282020-013114	3/22/2021	FT-FY21-032021-013114-A	<1	FT-FY21-032021-013114-B	<1
WS-013116	5/28/2020	5/28/2021	3	Combo Fountain	In classroom 310			WF-05282020-013116	3/22/2021	FT-FY21-032021-013116-A	<1	FT-FY21-032021-013116-B	<1

WS-013117	5/28/2020	5/28/2021	3	Cooler	In hallway across from classroom 310	High Left	WF-05282020-013117	3/22/2021	FT-FY21-032021-013117-A	<1	FT-FY21-032021-013117-B	<1
WS-013118	5/28/2020	5/28/2021	3	Cooler	In hallway across from classroom 310	Low Right	WF-05282020-013118	3/22/2021	FT-FY21-032021-013118-A	<1	FT-FY21-032021-013118-B	<1
WS-013120	5/28/2020	5/28/2021	3	Combo Fountain	In classroom 306		WF-05282020-013120	3/22/2021	FT-FY21-032021-013120-A	<1	FT-FY21-032021-013120-B	<1
WS-013122	5/28/2020	5/28/2021	3	Combo Fountain	In classroom 305		WF-05282020-013122	3/22/2021	FT-FY21-032021-013122-A	<1	FT-FY21-032021-013122-B	<1
WS-013123	5/28/2020	5/28/2021	1	Fountain	In hallway across from extended day office 101	High Right	WF-05282020-013123	3/22/2021	FT-FY21-032021-013123-A	<1	FT-FY21-032021-013123-B	<1
WS-013124	5/28/2020	5/28/2021	1	Bottle Filler	In hallway across from classroom 127		WF-05282020-013124	3/22/2021	FT-FY21-032021-013124-A	<1	FT-FY21-032021-013124-B	<1
WS-013125	5/28/2020	5/28/2021	1	Bottle Filler	In cafeteria		WF-05282020-013125	3/22/2021	FT-FY21-032021-013125-A	<1	FT-FY21-032021-013125-B	<1
WS-013126	5/28/2020	5/28/2021	2	Bottle Filler	In hallway adjacent to security room 212		WF-05282020-013126	3/22/2021	FT-FY21-032021-013126-A	<1	FT-FY21-032021-013126-B	<1
WS-013127	5/28/2020	5/28/2021	2	Bottle Filler	In hallway across from classroom 234		WF-05282020-013127	3/22/2021	FT-FY21-032021-013127-A	<1	FT-FY21-032021-013127-B	<1
WS-013128	5/28/2020	5/28/2021	3	Bottle Filler	In hallway across from classroom 310		WF-05282020-013128	3/22/2021	FT-FY21-032021-013128-A	<1	FT-FY21-032021-013128-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013048	1/21/2021	1/21/2022	1	Food Prep Sink	In rear of kitchen	WF-01212021-013048	3/22/2021	FT-FY21-032021-013048-A	<1	FT-FY21-032021-013048-B	<1