



# Boone Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013000	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 136	Low Left	WF-09272022-013000	10/25/2022	FT-FY23-10102022-013000-A	<1	FT-FY23-10102022-013000-B	<1
WS-013001	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 136	Low Left	WF-04192022-013001	10/25/2022	FT-FY23-10102022-013001-A	<1	FT-FY23-10102022-013001-B	<1
WS-013002	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 136	High Right	WF-09272022-013002	10/25/2022	FT-FY23-10102022-013002-A	<1	FT-FY23-10102022-013002-B	<1
WS-013003	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 136	High Right	WF-04192022-013003	10/25/2022	FT-FY23-10102022-013003-A	<1	FT-FY23-10102022-013003-B	<1
WS-013004	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 137	High Left	WF-09272022-013004	10/25/2022	FT-FY23-10102022-013004-A	<1	FT-FY23-10102022-013004-B	<1
WS-013005	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 137	High Left	WF-04192022-013005	10/25/2022	FT-FY23-10102022-013005-A	<1	FT-FY23-10102022-013005-B	<1
WS-013006	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 137	Low Right	WF-09272022-013006	10/25/2022	FT-FY23-10102022-013006-A	<1	FT-FY23-10102022-013006-B	<1
WS-013007	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 137	Low Right	WF-04192022-013007	10/25/2022	FT-FY23-10102022-013007-A	<1	FT-FY23-10102022-013007-B	<1
WS-013008	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 134	High Left	WF-09272022-013008	10/25/2022	FT-FY23-10102022-013008-A	<1	FT-FY23-10102022-013008-B	<1
WS-013010	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 134	Low Right	WF-09272022-013010	10/25/2022	FT-FY23-10102022-013010-A	<1	FT-FY23-10102022-013010-B	<1
WS-013011	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 134	Low Right	WF-04192022-013011	10/25/2022	FT-FY23-10102022-013011-A	<1	FT-FY23-10102022-013011-B	<1
WS-013012	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 135	Low Left	WF-09272022-013012	10/25/2022	FT-FY23-10102022-013012-A	<1	FT-FY23-10102022-013012-B	<1
WS-013013	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 135	Low Left	WF-04192022-013013	10/25/2022	FT-FY23-10102022-013013-A	<1	FT-FY23-10102022-013013-B	<1
WS-013014	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 135	High Right	WF-09272022-013014	10/25/2022	FT-FY23-10102022-013014-A	<1	FT-FY23-10102022-013014-B	<1
WS-013015	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 135	High Right	WF-04192022-013015	10/25/2022	FT-FY23-10102022-013015-A	<1	FT-FY23-10102022-013015-B	<1
WS-013016	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 133	High Left	WF-09272022-013016	10/25/2022	FT-FY23-10102022-013016-A	<1	FT-FY23-10102022-013016-B	<1
WS-013017	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 133	High Left	WF-04192022-013017	10/25/2022	FT-FY23-10102022-013017-A	<1	FT-FY23-10102022-013017-B	<1
WS-013018	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 133	Low Right	WF-09272022-013018	10/25/2022	FT-FY23-10102022-013018-A	<1	FT-FY23-10102022-013018-B	<1
WS-013019	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 133	Low Right	WF-04192022-013019	10/25/2022	FT-FY23-10102022-013019-A	<1	FT-FY23-10102022-013019-B	<1
WS-013023	4/19/2022	4/19/2023	1	Combo Fountain	In academic resource room 139		WF-04192022-013023	10/25/2022	FT-FY23-10102022-013023-A	<1	FT-FY23-10102022-013023-B	<1
WS-013024	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 131	Low Left	WF-09272022-013024	10/25/2022	FT-FY23-10102022-013024-A	<1	FT-FY23-10102022-013024-B	<1
WS-013025	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 131	Low Left	WF-04192022-013025	10/25/2022	FT-FY23-10102022-013025-A	<1	FT-FY23-10102022-013025-B	1.0
WS-013026	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 131	High Right	WF-09272022-013026	10/25/2022	FT-FY23-10102022-013026-A	<1	FT-FY23-10102022-013026-B	<1
WS-013027	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 131	High Right	WF-04192022-013027	10/25/2022	FT-FY23-10102022-013027-A	<1	FT-FY23-10102022-013027-B	<1
WS-013028	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 128	Low Left	WF-09272022-013028	10/25/2022	FT-FY23-10102022-013028-A	<1	FT-FY23-10102022-013028-B	<1
WS-013029	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 128	Low Left	WF-04192022-013029	10/25/2022	FT-FY23-10102022-013029-A	<1	FT-FY23-10102022-013029-B	<1
WS-013030	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 128	High Right	WF-09272022-013030	10/25/2022	FT-FY23-10102022-013030-A	<1	FT-FY23-10102022-013030-B	<1
WS-013031	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 128	High Right	WF-04192022-013031	10/25/2022	FT-FY23-10102022-013031-A	<1	FT-FY23-10102022-013031-B	<1
WS-013032	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 126	High Left	WF-09272022-013032	10/25/2022	FT-FY23-10102022-013032-A	<1	FT-FY23-10102022-013032-B	<1
WS-013033	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 126	High Left	WF-04192022-013033	10/25/2022	FT-FY23-10102022-013033-A	<1	FT-FY23-10102022-013033-B	<1
WS-013034	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 126	Low Right	WF-09272022-013034	10/25/2022	FT-FY23-10102022-013034-A	<1	FT-FY23-10102022-013034-B	<1
WS-013035	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 126	Low Right	WF-04192022-013035	10/25/2022	FT-FY23-10102022-013035-A	<1	FT-FY23-10102022-013035-B	<1
WS-013036	4/19/2022	4/19/2023	1	Cooler	In hallway across from classroom 127	Low Right	WF-04192022-013036	10/25/2022	FT-FY23-10102022-013036-A	<1	FT-FY23-10102022-013036-B	<1
WS-013037	4/19/2022	4/19/2023	1	Cooler	In hallway across from classroom 127	High Left	WF-04192022-013037	10/25/2022	FT-FY23-10102022-013037-A	<1	FT-FY23-10102022-013037-B	<1
WS-013038	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 127	High Left	WF-09272022-013038	10/25/2022	FT-FY23-10102022-013038-A	<1	FT-FY23-10102022-013038-B	<1

WS-013039	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 127	High	Left	WF-04192022-013039	10/25/2022	FT-FY23-10102022-013039-A	<1	FT-FY23-10102022-013039-B	<1
WS-013040	9/27/2022	9/27/2023	1	Combo Faucet	In classroom 127	Low	Right	WF-09272022-013040	10/25/2022	FT-FY23-10102022-013040-A	<1	FT-FY23-10102022-013040-B	<1
WS-013041	4/19/2022	4/19/2023	1	Combo Fountain	In classroom 127	Low	Right	WF-04192022-013041	10/25/2022	FT-FY23-10102022-013041-A	<1	FT-FY23-10102022-013041-B	<1
WS-013054	4/19/2022	4/19/2023	1	Health Suite	In treatment room 110b			WF-04192022-013054	10/25/2022	FT-FY23-10102022-013054-A	<1	FT-FY23-10102022-013054-B	<1
WS-013055	4/19/2022	4/19/2023	1	Combo Fountain	In treatment room 110b			WF-04192022-013055	10/25/2022	FT-FY23-10102022-013055-A	<1	FT-FY23-10102022-013055-B	<1
WS-013069	4/19/2022	4/19/2023	2	Combo Fountain	In classroom 243			WF-04192022-013069	10/25/2022	FT-FY23-10102022-013069-A	<1	FT-FY23-10102022-013069-B	<1
WS-013071	4/19/2022	4/19/2023	2	Combo Fountain	In classroom 244			WF-04192022-013071	10/25/2022	FT-FY23-10102022-013071-A	<1	FT-FY23-10102022-013071-B	<1
WS-013073	4/19/2022	4/19/2023	2	Combo Fountain	In classroom 242			WF-04192022-013073	10/25/2022	FT-FY23-10102022-013073-A	<1	FT-FY23-10102022-013073-B	<1
WS-013075	4/19/2022	4/19/2023	2	Combo Fountain	In classroom 241			WF-04192022-013075	10/25/2022	FT-FY23-10102022-013075-A	<1	FT-FY23-10102022-013075-B	<1
WS-013077	4/19/2022	4/19/2023	2	Combo Fountain	In workroom 239			WF-04192022-013077	10/25/2022	FT-FY23-10102022-013077-A	4.8	FT-FY23-10102022-013077-B	2.3
WS-013079	4/19/2022	4/19/2023	2	Combo Fountain	In room 237b inside reading learning center 237			WF-04192022-013079	10/25/2022	FT-FY23-10102022-013079-A	3.6	FT-FY23-10102022-013079-B	<1
WS-013080	4/19/2022	4/19/2023	2	Cooler	In hallway across from classroom 234	High	Left	WF-04192022-013080	10/25/2022	FT-FY23-10102022-013080-A	<1	FT-FY23-10102022-013080-B	<1
WS-013081	4/19/2022	4/19/2023	2	Cooler	In hallway across from classroom 234	Low	Right	WF-04192022-013081	10/25/2022	FT-FY23-10102022-013081-A	<1	FT-FY23-10102022-013081-B	<1
WS-013083	4/19/2022	4/19/2023	2	Combo Fountain	In classroom 234			WF-04192022-013083	10/25/2022	FT-FY23-10102022-013083-A	<1	FT-FY23-10102022-013083-B	<1
WS-013087	4/19/2022	4/19/2023	2	Combo Fountain	In classroom 231			WF-04192022-013087	10/25/2022	FT-FY23-10102022-013087-A	<1	FT-FY23-10102022-013087-B	<1
WS-013094	4/19/2022	4/19/2023	2	Cooler	In hallway adjacent to security room 212	High	Left	WF-04192022-013094	10/25/2022	FT-FY23-10102022-013094-A	<1	FT-FY23-10102022-013094-B	<1
WS-013095	4/19/2022	4/19/2023	2	Cooler	In hallway adjacent to security room 212	Low	Right	WF-04192022-013095	10/25/2022	FT-FY23-10102022-013095-A	<1	FT-FY23-10102022-013095-B	<1
WS-013097	4/19/2022	4/19/2023	2	Combo Fountain	In music room 214			WF-04192022-013097	10/25/2022	FT-FY23-10102022-013097-A	<1	FT-FY23-10102022-013097-B	<1
WS-013098	4/19/2022	4/19/2023	2	Cooler	In music room 214			WF-04192022-013098	10/25/2022	FT-FY23-10102022-013098-A	<1	FT-FY23-10102022-013098-B	<1
WS-013100	4/19/2022	4/19/2023	3	Combo Fountain	In classroom 318			WF-04192022-013100	10/25/2022	FT-FY23-10102022-013100-A	<1	FT-FY23-10102022-013100-B	<1
WS-013102	4/19/2022	4/19/2023	3	Combo Fountain	In classroom 317			WF-04192022-013102	10/25/2022	FT-FY23-10102022-013102-A	<1	FT-FY23-10102022-013102-B	<1
WS-013104	4/19/2022	4/19/2023	3	Combo Fountain	In classroom 316			WF-04192022-013104	10/25/2022	FT-FY23-10102022-013104-A	<1	FT-FY23-10102022-013104-B	<1
WS-013106	4/19/2022	4/19/2023	3	Combo Fountain	In classroom 315			WF-04192022-013106	10/25/2022	FT-FY23-10102022-013106-A	<1	FT-FY23-10102022-013106-B	<1
WS-013108	4/19/2022	4/19/2023	3	Combo Fountain	In classroom 314			WF-04192022-013108	10/25/2022	FT-FY23-10102022-013108-A	<1	FT-FY23-10102022-013108-B	<1
WS-013110	4/19/2022	4/19/2023	3	Combo Fountain	In classroom 313			WF-04192022-013110	10/25/2022	FT-FY23-10102022-013110-A	<1	FT-FY23-10102022-013110-B	<1
WS-013111	4/19/2022	4/19/2023	3	Break Room	In workroom 309			WF-04192022-013111	10/25/2022	FT-FY23-10102022-013111-A	<1	FT-FY23-10102022-013111-B	<1
WS-013114	4/19/2022	4/19/2023	3	Combo Fountain	In instructional coach room 308			WF-04192022-013114	10/25/2022	FT-FY23-10102022-013114-A	<1	FT-FY23-10102022-013114-B	<1
WS-013116	4/19/2022	4/19/2023	3	Combo Fountain	In classroom 310			WF-04192022-013116	10/25/2022	FT-FY23-10102022-013116-A	<1	FT-FY23-10102022-013116-B	<1
WS-013117	4/19/2022	4/19/2023	3	Cooler	In hallway across from classroom 310	High	Left	WF-04192022-013117	10/25/2022	FT-FY23-10102022-013117-A	<1	FT-FY23-10102022-013117-B	<1
WS-013118	4/19/2022	4/19/2023	3	Cooler	In hallway across from classroom 310	Low	Right	WF-04192022-013118	10/25/2022	FT-FY23-10102022-013118-A	<1	FT-FY23-10102022-013118-B	<1
WS-013120	4/19/2022	4/19/2023	3	Combo Fountain	In classroom 306			WF-04192022-013120	10/25/2022	FT-FY23-10102022-013120-A	<1	FT-FY23-10102022-013120-B	<1
WS-013122	4/19/2022	4/19/2023	3	Combo Fountain	In classroom 305			WF-04192022-013122	10/25/2022	FT-FY23-10102022-013122-A	<1	FT-FY23-10102022-013122-B	<1
WS-013124	4/19/2022	4/19/2023	1	Bottle Filler	In hallway across from classroom 127			WF-04192022-013124	10/25/2022	FT-FY23-10102022-013124-A	<1	FT-FY23-10102022-013124-B	<1
WS-013126	4/19/2022	4/19/2023	2	Bottle Filler	In hallway adjacent to security room 212			WF-04192022-013126	10/25/2022	FT-FY23-10102022-013126-A	<1	FT-FY23-10102022-013126-B	<1
WS-013128	4/19/2022	4/19/2023	3	Bottle Filler	In hallway across from classroom 310			WF-04192022-013128	10/25/2022	FT-FY23-10102022-013128-A	<1	FT-FY23-10102022-013128-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013048	1/10/2022	1/10/2023	1	Food Prep Sink	In rear of kitchen	WF-01102022-013048	10/25/2022	FT-FY23-10102022-013048-A	<1	FT-FY23-10102022-013048-B	<1