



Boone Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
|-----------|-----------------------|------------------------|-------|----------------|--------------------------------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| WS-013000 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 136 | WF-09172024-013000 | 2/19/2025 | FT-FY25-12262024-013000-A | 4.1 | FT-FY25-12262024-013000-B | <2 |
| WS-013001 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 136 | WF-04022024-013001 | 2/19/2025 | FT-FY25-12262024-013001-A | <2 | FT-FY25-12262024-013001-B | <2 |
| WS-013002 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 136 | WF-09172024-013002 | 2/19/2025 | FT-FY25-12262024-013002-A | 3.5 | FT-FY25-12262024-013002-B | <2 |
| WS-013003 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 136 | WF-04022024-013003 | 2/19/2025 | FT-FY25-12262024-013003-A | <2 | FT-FY25-12262024-013003-B | <2 |
| WS-013004 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 137 | WF-09172024-013004 | 2/19/2025 | FT-FY25-12262024-013004-A | 4.9 | FT-FY25-12262024-013004-B | <2 |
| WS-013005 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 137 | WF-04022024-013005 | 2/19/2025 | FT-FY25-12262024-013005-A | <2 | FT-FY25-12262024-013005-B | <2 |
| WS-013007 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 137 | WF-04022024-013007 | 2/19/2025 | FT-FY25-12262024-013007-A | <2 | FT-FY25-12262024-013007-B | <2 |
| WS-013011 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 134 | WF-04022024-013011 | 2/19/2025 | FT-FY25-12262024-013011-A | <2 | FT-FY25-12262024-013011-B | <2 |
| WS-013012 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 135 | WF-09172024-013012 | 2/19/2025 | FT-FY25-12262024-013012-A | <2 | FT-FY25-12262024-013012-B | <2 |
| WS-013013 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 135 | WF-04022024-013013 | 2/19/2025 | FT-FY25-12262024-013013-A | <2 | FT-FY25-12262024-013013-B | <2 |
| WS-013014 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 135 | WF-09172024-013014 | 2/19/2025 | FT-FY25-12262024-013014-A | 2.9 | FT-FY25-12262024-013014-B | <2 |
| WS-013015 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 135 | WF-04022024-013015 | 2/19/2025 | FT-FY25-12262024-013015-A | <2 | FT-FY25-12262024-013015-B | <2 |
| WS-013019 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 133 | WF-04022024-013019 | 2/19/2025 | FT-FY25-12262024-013019-A | <2 | FT-FY25-12262024-013019-B | <2 |
| WS-013021 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In workroom 132 | WF-04022024-013021 | 2/19/2025 | FT-FY25-12262024-013021-A | <2 | FT-FY25-12262024-013021-B | <2 |
| WS-013023 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In academic resource room 139 | WF-04022024-013023 | 2/19/2025 | FT-FY25-12262024-013023-A | <2 | FT-FY25-12262024-013023-B | <2 |
| WS-013027 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 131 | WF-04022024-013027 | 2/19/2025 | FT-FY25-12262024-013027-A | <2 | FT-FY25-12262024-013027-B | <2 |
| WS-013029 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 128 | WF-04022024-013029 | 2/19/2025 | FT-FY25-12262024-013029-A | <2 | FT-FY25-12262024-013029-B | <2 |
| WS-013031 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 128 | WF-04022024-013031 | 2/19/2025 | FT-FY25-12262024-013031-A | <2 | FT-FY25-12262024-013031-B | <2 |
| WS-013032 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 126 | WF-09172024-013032 | 2/19/2025 | FT-FY25-12262024-013032-A | 2.6 | FT-FY25-12262024-013032-B | <2 |
| WS-013033 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 126 | WF-04022024-013033 | 2/19/2025 | FT-FY25-12262024-013033-A | <2 | FT-FY25-12262024-013033-B | <2 |
| WS-013034 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 126 | WF-09172024-013034 | 2/19/2025 | FT-FY25-12262024-013034-A | <2 | FT-FY25-12262024-013034-B | <2 |
| WS-013035 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 126 | WF-04022024-013035 | 2/19/2025 | FT-FY25-12262024-013035-A | <2 | FT-FY25-12262024-013035-B | <2 |
| WS-013036 | 4/2/2024 | 4/2/2025 | 1 | Cooler | In hallway across from classroom 127 | WF-04022024-013036 | 2/19/2025 | FT-FY25-12262024-013036-A | <2 | FT-FY25-12262024-013036-B | <2 |
| WS-013037 | 4/2/2024 | 4/2/2025 | 1 | Cooler | In hallway across from classroom 127 | WF-04022024-013037 | 2/19/2025 | FT-FY25-12262024-013037-A | <2 | FT-FY25-12262024-013037-B | <2 |
| WS-013038 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 127 | WF-09172024-013038 | 2/19/2025 | FT-FY25-12262024-013038-A | 2.9 | FT-FY25-12262024-013038-B | <2 |
| WS-013039 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 127 | WF-04022024-013039 | 2/19/2025 | FT-FY25-12262024-013039-A | <2 | FT-FY25-12262024-013039-B | <2 |
| WS-013040 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 127 | WF-09172024-013040 | 2/19/2025 | FT-FY25-12262024-013040-A | <2 | FT-FY25-12262024-013040-B | <2 |
| WS-013041 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In classroom 127 | WF-04022024-013041 | 2/19/2025 | FT-FY25-12262024-013041-A | <2 | FT-FY25-12262024-013041-B | <2 |
| WS-013054 | 4/2/2024 | 4/2/2025 | 1 | Health Suite | In treatment room 110b | WF-04022024-013054 | 2/19/2025 | FT-FY25-12262024-013054-A | <2 | FT-FY25-12262024-013054-B | <2 |
| WS-013055 | 4/2/2024 | 4/2/2025 | 1 | Combo Fountain | In treatment room 110b | WF-04022024-013055 | 2/19/2025 | FT-FY25-12262024-013055-A | <2 | FT-FY25-12262024-013055-B | <2 |
| WS-013069 | 4/2/2024 | 4/2/2025 | 2 | Combo Fountain | In classroom 243 | WF-04022024-013069 | 2/19/2025 | FT-FY25-12262024-013069-A | <2 | FT-FY25-12262024-013069-B | <2 |
| WS-013071 | 4/2/2024 | 4/2/2025 | 2 | Combo Fountain | In classroom 244 | WF-04022024-013071 | 2/19/2025 | FT-FY25-12262024-013071-A | <2 | FT-FY25-12262024-013071-B | <2 |
| WS-013073 | 4/2/2024 | 4/2/2025 | 2 | Combo Fountain | In classroom 242 | WF-04022024-013073 | 2/19/2025 | FT-FY25-12262024-013073-A | <2 | FT-FY25-12262024-013073-B | <2 |
| WS-013075 | 4/2/2024 | 4/2/2025 | 2 | Combo Fountain | In classroom 241 | WF-04022024-013075 | 2/19/2025 | FT-FY25-12262024-013075-A | <2 | FT-FY25-12262024-013075-B | <2 |

| | | | | | | | | | | | | |
|-----------|----------|----------|---|----------------|---|-----------|--------------------|-----------|---------------------------|----|---------------------------|----|
| WS-013077 | 4/2/2024 | 4/2/2025 | 2 | Combo Fountain | In workroom 239 | | WF-04022024-013077 | 2/19/2025 | FT-FY25-12262024-013077-A | <2 | FT-FY25-12262024-013077-B | <2 |
| WS-013079 | 4/2/2024 | 4/2/2025 | 2 | Combo Fountain | In room 237b inside reading learning center 237 | | WF-04022024-013079 | 2/19/2025 | FT-FY25-12262024-013079-A | <2 | FT-FY25-12262024-013079-B | <2 |
| WS-013080 | 4/2/2024 | 4/2/2025 | 2 | Cooler | In hallway across from classroom 234 | High Left | WF-04022024-013080 | 2/19/2025 | FT-FY25-12262024-013080-A | <2 | FT-FY25-12262024-013080-B | <2 |
| WS-013081 | 4/2/2024 | 4/2/2025 | 2 | Cooler | In hallway across from classroom 234 | Low Right | WF-04022024-013081 | 2/19/2025 | FT-FY25-12262024-013081-A | <2 | FT-FY25-12262024-013081-B | <2 |
| WS-013083 | 4/2/2024 | 4/2/2025 | 2 | Combo Fountain | In classroom 234 | | WF-04022024-013083 | 2/19/2025 | FT-FY25-12262024-013083-A | <2 | FT-FY25-12262024-013083-B | <2 |
| WS-013091 | 4/2/2024 | 4/2/2025 | 2 | Break Room | In staff lounge 209 | | WF-04022024-013091 | 2/19/2025 | FT-FY25-12262024-013091-A | <2 | FT-FY25-12262024-013091-B | <2 |
| WS-013094 | 4/2/2024 | 4/2/2025 | 2 | Cooler | In hallway adjacent to security room 212 | High Left | WF-04022024-013094 | 2/19/2025 | FT-FY25-12262024-013094-A | <2 | FT-FY25-12262024-013094-B | <2 |
| WS-013095 | 4/2/2024 | 4/2/2025 | 2 | Cooler | In hallway adjacent to security room 212 | Low Right | WF-04022024-013095 | 2/19/2025 | FT-FY25-12262024-013095-A | <2 | FT-FY25-12262024-013095-B | <2 |
| WS-013097 | 4/2/2024 | 4/2/2025 | 2 | Combo Fountain | In music room 214 | | WF-04022024-013097 | 2/19/2025 | FT-FY25-12262024-013097-A | <2 | FT-FY25-12262024-013097-B | <2 |
| WS-013098 | 4/2/2024 | 4/2/2025 | 2 | Cooler | In music room 214 | | WF-04022024-013098 | 2/19/2025 | FT-FY25-12262024-013098-A | <2 | FT-FY25-12262024-013098-B | <2 |
| WS-013100 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In classroom 318 | | WF-04022024-013100 | 2/19/2025 | FT-FY25-12262024-013100-A | <2 | FT-FY25-12262024-013100-B | <2 |
| WS-013102 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In classroom 317 | | WF-04022024-013102 | 2/19/2025 | FT-FY25-12262024-013102-A | <2 | FT-FY25-12262024-013102-B | <2 |
| WS-013104 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In classroom 316 | | WF-04022024-013104 | 2/19/2025 | FT-FY25-12262024-013104-A | <2 | FT-FY25-12262024-013104-B | <2 |
| WS-013106 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In classroom 315 | | WF-04022024-013106 | 2/19/2025 | FT-FY25-12262024-013106-A | <2 | FT-FY25-12262024-013106-B | <2 |
| WS-013108 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In classroom 314 | | WF-04022024-013108 | 2/19/2025 | FT-FY25-12262024-013108-A | <2 | FT-FY25-12262024-013108-B | <2 |
| WS-013110 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In classroom 313 | | WF-04022024-013110 | 2/19/2025 | FT-FY25-12262024-013110-A | <2 | FT-FY25-12262024-013110-B | <2 |
| WS-013111 | 4/2/2024 | 4/2/2025 | 3 | Break Room | In workroom 309 | | WF-04022024-013111 | 2/19/2025 | FT-FY25-12262024-013111-A | <2 | FT-FY25-12262024-013111-B | <2 |
| WS-013112 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In workroom 309 | | WF-04022024-013112 | 2/19/2025 | FT-FY25-12262024-013112-A | <2 | FT-FY25-12262024-013112-B | <2 |
| WS-013114 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In instructional coach room 308 | | WF-04022024-013114 | 2/19/2025 | FT-FY25-12262024-013114-A | <2 | FT-FY25-12262024-013114-B | <2 |
| WS-013116 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In classroom 310 | | WF-04022024-013116 | 2/19/2025 | FT-FY25-12262024-013116-A | <2 | FT-FY25-12262024-013116-B | <2 |
| WS-013117 | 4/2/2024 | 4/2/2025 | 3 | Cooler | In hallway across from classroom 310 | High Left | WF-04022024-013117 | 2/19/2025 | FT-FY25-12262024-013117-A | <2 | FT-FY25-12262024-013117-B | <2 |
| WS-013118 | 4/2/2024 | 4/2/2025 | 3 | Cooler | In hallway across from classroom 310 | Low Right | WF-04022024-013118 | 2/19/2025 | FT-FY25-12262024-013118-A | <2 | FT-FY25-12262024-013118-B | <2 |
| WS-013120 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In classroom 306 | | WF-04022024-013120 | 2/19/2025 | FT-FY25-12262024-013120-A | <2 | FT-FY25-12262024-013120-B | <2 |
| WS-013122 | 4/2/2024 | 4/2/2025 | 3 | Combo Fountain | In classroom 305 | | WF-04022024-013122 | 2/19/2025 | FT-FY25-12262024-013122-A | <2 | FT-FY25-12262024-013122-B | <2 |
| WS-013126 | 4/2/2024 | 4/2/2025 | 2 | Bottle Filler | In hallway adjacent to security room 212 | | WF-04022024-013126 | 2/19/2025 | FT-FY25-12262024-013126-A | <2 | FT-FY25-12262024-013126-B | <2 |
| WS-013128 | 4/2/2024 | 4/2/2025 | 3 | Bottle Filler | In hallway across from classroom 310 | | WF-04022024-013128 | 2/19/2025 | FT-FY25-12262024-013128-A | <2 | FT-FY25-12262024-013128-B | <2 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|----------------|--------------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS-013048 | 11/18/2024 | 11/18/2025 | 1 | Food Prep Sink | In rear of kitchen | WF-11182024-013048 | 2/19/2025 | FT-FY25-12262024-013048-A | <2 | FT-FY25-12262024-013048-B | <2 |

FY25 Filter Test

| Greater than 5ppb - Devices requiring remediation | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|--------------|------------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS-013006 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 137 | WF-09172024-013006 | 2/19/2025 | FT-FY25-12262024-013006-A | 5.2 | FT-FY25-12262024-013006-B | <2 |
| WS-013008 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 134 | WF-09172024-013008 | 2/19/2025 | FT-FY25-12262024-013008-A | 6.3 | FT-FY25-12262024-013008-B | <2 |
| WS-013010 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 134 | WF-09172024-013010 | 2/19/2025 | FT-FY25-12262024-013010-A | 5.3 | FT-FY25-12262024-013010-B | <2 |
| WS-013016 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 133 | WF-09172024-013016 | 2/19/2025 | FT-FY25-12262024-013016-A | 6.7 | FT-FY25-12262024-013016-B | <2 |
| WS-013018 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 133 | WF-09172024-013018 | 2/19/2025 | FT-FY25-12262024-013018-A | 5.6 | FT-FY25-12262024-013018-B | <2 |

| | | | | | | | | | | | | |
|-----------|-----------|-----------|---|--------------|------------------|------------|--------------------|-----------|---------------------------|-----|---------------------------|----|
| WS-013024 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 131 | Low Left | WF-09172024-013024 | 2/19/2025 | FT-FY25-12262024-013024-A | 6.5 | FT-FY25-12262024-013024-B | <2 |
| WS-013026 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 131 | High Right | WF-09172024-013026 | 2/19/2025 | FT-FY25-12262024-013026-A | 6.1 | FT-FY25-12262024-013026-B | <2 |
| WS-013028 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 128 | Low Left | WF-09172024-013028 | 2/19/2025 | FT-FY25-12262024-013028-A | 9.6 | FT-FY25-12262024-013028-B | <2 |
| WS-013030 | 9/17/2024 | 9/17/2025 | 1 | Combo Faucet | In classroom 128 | High Right | WF-09172024-013030 | 2/19/2025 | FT-FY25-12262024-013030-A | 5.0 | FT-FY25-12262024-013030-B | <2 |

After First Retest (Plumbing Check)

FY25 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|--------------|------------------|------------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS-013006 | 2/21/2025 | 2/21/2026 | 1 | Combo Faucet | In classroom 137 | Low Right | WF-02212025-013006 | 2/28/2025 | FT-FY25-02242025-013006-A | <2 | FT-FY25-02242025-013006-B | <2 |
| WS-013008 | 2/21/2025 | 2/21/2026 | 1 | Combo Faucet | In classroom 134 | High Left | WF-02212025-013008 | 2/28/2025 | FT-FY25-02242025-013008-A | <2 | FT-FY25-02242025-013008-B | <2 |
| WS-013010 | 2/21/2025 | 2/21/2026 | 1 | Combo Faucet | In classroom 134 | Low Right | WF-02212025-013010 | 2/28/2025 | FT-FY25-02242025-013010-A | <2 | FT-FY25-02242025-013010-B | <2 |
| WS-013016 | 2/21/2025 | 2/21/2026 | 1 | Combo Faucet | In classroom 133 | High Left | WF-02212025-013016 | 2/28/2025 | FT-FY25-02242025-013016-A | <2 | FT-FY25-02242025-013016-B | <2 |
| WS-013018 | 2/21/2025 | 2/21/2026 | 1 | Combo Faucet | In classroom 133 | Low Right | WF-02212025-013018 | 2/28/2025 | FT-FY25-02242025-013018-A | <2 | FT-FY25-02242025-013018-B | <2 |
| WS-013024 | 2/21/2025 | 2/21/2026 | 1 | Combo Faucet | In classroom 131 | Low Left | WF-02212025-013024 | 2/28/2025 | FT-FY25-02242025-013024-A | <2 | FT-FY25-02242025-013024-B | <2 |
| WS-013026 | 2/21/2025 | 2/21/2026 | 1 | Combo Faucet | In classroom 131 | High Right | WF-02212025-013026 | 2/28/2025 | FT-FY25-02242025-013026-A | <2 | FT-FY25-02242025-013026-B | <2 |
| WS-013028 | 2/21/2025 | 2/21/2026 | 1 | Combo Faucet | In classroom 128 | Low Left | WF-02212025-013028 | 2/28/2025 | FT-FY25-02242025-013028-A | <2 | FT-FY25-02242025-013028-B | <2 |
| WS-013030 | 2/21/2025 | 2/21/2026 | 1 | Combo Faucet | In classroom 128 | High Right | WF-02212025-013030 | 2/28/2025 | FT-FY25-02242025-013030-A | <2 | FT-FY25-02242025-013030-B | <2 |

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.