



Boone Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013000	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 136	Low Left	WF-09182023-013000	10/26/2023	FT-FY24-09282023-013000-A	1.2	FT-FY24-09282023-013000-B	<1
WS-013001	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 136	Low Left	WF-04102023-013001	10/26/2023	FT-FY24-09282023-013001-A	2.2	FT-FY24-09282023-013001-B	<1
WS-013002	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 136	High Right	WF-09182023-013002	10/26/2023	FT-FY24-09282023-013002-A	1.5	FT-FY24-09282023-013002-B	<1
WS-013003	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 136	High Right	WF-04102023-013003	10/26/2023	FT-FY24-09282023-013003-A	<1	FT-FY24-09282023-013003-B	<1
WS-013004	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 137	High Left	WF-09182023-013004	10/26/2023	FT-FY24-09282023-013004-A	1.7	FT-FY24-09282023-013004-B	<1
WS-013005	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 137	High Left	WF-04102023-013005	10/26/2023	FT-FY24-09282023-013005-A	<1	FT-FY24-09282023-013005-B	<1
WS-013006	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 137	Low Right	WF-09182023-013006	10/26/2023	FT-FY24-09282023-013006-A	1.6	FT-FY24-09282023-013006-B	<1
WS-013007	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 137	Low Right	WF-04102023-013007	10/26/2023	FT-FY24-09282023-013007-A	<1	FT-FY24-09282023-013007-B	<1
WS-013008	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 134	High Left	WF-09182023-013008	10/26/2023	FT-FY24-09282023-013008-A	1.1	FT-FY24-09282023-013008-B	<1
WS-013010	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 134	Low Right	WF-09182023-013010	10/26/2023	FT-FY24-09282023-013010-A	<1	FT-FY24-09282023-013010-B	<1
WS-013011	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 134	Low Right	WF-04102023-013011	10/26/2023	FT-FY24-09282023-013011-A	1.7	FT-FY24-09282023-013011-B	<1
WS-013012	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 135	Low Left	WF-09182023-013012	10/26/2023	FT-FY24-09282023-013012-A	1.6	FT-FY24-09282023-013012-B	<1
WS-013013	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 135	Low Left	WF-04102023-013013	10/26/2023	FT-FY24-09282023-013013-A	1.1	FT-FY24-09282023-013013-B	<1
WS-013014	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 135	High Right	WF-09182023-013014	10/26/2023	FT-FY24-09282023-013014-A	<1	FT-FY24-09282023-013014-B	1.4
WS-013015	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 135	High Right	WF-04102023-013015	10/26/2023	FT-FY24-09282023-013015-A	1.1	FT-FY24-09282023-013015-B	<1
WS-013016	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 133	High Left	WF-09182023-013016	10/26/2023	FT-FY24-09282023-013016-A	3.2	FT-FY24-09282023-013016-B	<1
WS-013018	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 133	Low Right	WF-09182023-013018	10/26/2023	FT-FY24-09282023-013018-A	2.0	FT-FY24-09282023-013018-B	<1
WS-013019	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 133	Low Right	WF-04102023-013019	10/26/2023	FT-FY24-09282023-013019-A	<1	FT-FY24-09282023-013019-B	<1
WS-013023	4/10/2023	4/10/2024	1	Combo Fountain	In academic resource room 139		WF-04102023-013023	10/26/2023	FT-FY24-09282023-013023-A	<1	FT-FY24-09282023-013023-B	<1
WS-013024	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 131	Low Left	WF-09182023-013024	10/26/2023	FT-FY24-09282023-013024-A	2.0	FT-FY24-09282023-013024-B	<1
WS-013025	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 131	Low Left	WF-04102023-013025	10/26/2023	FT-FY24-09282023-013025-A	<1	FT-FY24-09282023-013025-B	<1
WS-013026	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 131	High Right	WF-09182023-013026	10/26/2023	FT-FY24-09282023-013026-A	1.7	FT-FY24-09282023-013026-B	<1
WS-013027	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 131	High Right	WF-04102023-013027	10/26/2023	FT-FY24-09282023-013027-A	3.3	FT-FY24-09282023-013027-B	<1
WS-013028	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 128	Low Left	WF-09182023-013028	10/26/2023	FT-FY24-09282023-013028-A	1.2	FT-FY24-09282023-013028-B	<1
WS-013029	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 128	Low Left	WF-04102023-013029	10/26/2023	FT-FY24-09282023-013029-A	<1	FT-FY24-09282023-013029-B	<1
WS-013030	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 128	High Right	WF-09182023-013030	10/26/2023	FT-FY24-09282023-013030-A	1.8	FT-FY24-09282023-013030-B	<1
WS-013031	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 128	High Right	WF-04102023-013031	10/26/2023	FT-FY24-09282023-013031-A	<1	FT-FY24-09282023-013031-B	<1
WS-013032	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 126	High Left	WF-09182023-013032	10/26/2023	FT-FY24-09282023-013032-A	2.2	FT-FY24-09282023-013032-B	<1
WS-013033	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 126	High Left	WF-04102023-013033	10/26/2023	FT-FY24-09282023-013033-A	<1	FT-FY24-09282023-013033-B	<1
WS-013034	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 126	Low Right	WF-09182023-013034	10/26/2023	FT-FY24-09282023-013034-A	1.8	FT-FY24-09282023-013034-B	<1
WS-013035	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 126	Low Right	WF-04102023-013035	10/26/2023	FT-FY24-09282023-013035-A	<1	FT-FY24-09282023-013035-B	<1
WS-013036	4/10/2023	4/10/2024	1	Cooler	In hallway across from classroom 127	Low Right	WF-04102023-013036	10/26/2023	FT-FY24-09282023-013036-A	<1	FT-FY24-09282023-013036-B	<1
WS-013037	4/10/2023	4/10/2024	1	Cooler	In hallway across from classroom 127	High Left	WF-04102023-013037	10/26/2023	FT-FY24-09282023-013037-A	<1	FT-FY24-09282023-013037-B	<1
WS-013038	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 127	High Left	WF-09182023-013038	10/26/2023	FT-FY24-09282023-013038-A	2.0	FT-FY24-09282023-013038-B	<1
WS-013039	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 127	High Left	WF-04102023-013039	10/26/2023	FT-FY24-09282023-013039-A	2.2	FT-FY24-09282023-013039-B	<1

WS-013040	9/18/2023	9/18/2024	1	Combo Faucet	In classroom 127	Low Right	WF-09182023-013040	10/26/2023	FT-FY24-09282023-013040-A	1.3	FT-FY24-09282023-013040-B	<1
WS-013041	4/10/2023	4/10/2024	1	Combo Fountain	In classroom 127	Low Right	WF-04102023-013041	10/26/2023	FT-FY24-09282023-013041-A	<1	FT-FY24-09282023-013041-B	<1
WS-013054	4/10/2023	4/10/2024	1	Health Suite	In treatment room 110b		WF-04102023-013054	10/26/2023	FT-FY24-09282023-013054-A	<1	FT-FY24-09282023-013054-B	<1
WS-013055	4/10/2023	4/10/2024	1	Combo Fountain	In treatment room 110b		WF-04102023-013055	10/26/2023	FT-FY24-09282023-013055-A	1.3	FT-FY24-09282023-013055-B	<1
WS-013069	4/10/2023	4/10/2024	2	Combo Fountain	In classroom 243		WF-04102023-013069	10/26/2023	FT-FY24-09282023-013069-A	<1	FT-FY24-09282023-013069-B	<1
WS-013071	4/10/2023	4/10/2024	2	Combo Fountain	In classroom 244		WF-04102023-013071	10/26/2023	FT-FY24-09282023-013071-A	<1	FT-FY24-09282023-013071-B	<1
WS-013073	4/10/2023	4/10/2024	2	Combo Fountain	In classroom 242		WF-04102023-013073	10/26/2023	FT-FY24-09282023-013073-A	<1	FT-FY24-09282023-013073-B	<1
WS-013075	4/10/2023	4/10/2024	2	Combo Fountain	In classroom 241		WF-04102023-013075	10/26/2023	FT-FY24-09282023-013075-A	<1	FT-FY24-09282023-013075-B	<1
WS-013080	4/10/2023	4/10/2024	2	Cooler	In hallway across from classroom 234	High Left	WF-04102023-013080	10/26/2023	FT-FY24-09282023-013080-A	<1	FT-FY24-09282023-013080-B	<1
WS-013081	4/10/2023	4/10/2024	2	Cooler	In hallway across from classroom 234	Low Right	WF-04102023-013081	10/26/2023	FT-FY24-09282023-013081-A	<1	FT-FY24-09282023-013081-B	<1
WS-013083	4/10/2023	4/10/2024	2	Combo Fountain	In classroom 234		WF-04102023-013083	10/26/2023	FT-FY24-09282023-013083-A	<1	FT-FY24-09282023-013083-B	<1
WS-013091	4/10/2023	4/10/2024	2	Break Room	In staff lounge 209		WF-04102023-013091	10/26/2023	FT-FY24-09282023-013091-A	<1	FT-FY24-09282023-013091-B	<1
WS-013094	4/10/2023	4/10/2024	2	Cooler	In hallway adjacent to security room 212	High Left	WF-04102023-013094	10/26/2023	FT-FY24-09282023-013094-A	<1	FT-FY24-09282023-013094-B	<1
WS-013095	4/10/2023	4/10/2024	2	Cooler	In hallway adjacent to security room 212	Low Right	WF-04102023-013095	10/26/2023	FT-FY24-09282023-013095-A	<1	FT-FY24-09282023-013095-B	<1
WS-013097	4/10/2023	4/10/2024	2	Combo Fountain	In music room 214		WF-04102023-013097	10/26/2023	FT-FY24-09282023-013097-A	<1	FT-FY24-09282023-013097-B	<1
WS-013098	4/10/2023	4/10/2024	2	Cooler	In music room 214		WF-04102023-013098	10/26/2023	FT-FY24-09282023-013098-A	<1	FT-FY24-09282023-013098-B	<1
WS-013100	4/10/2023	4/10/2024	3	Combo Fountain	In classroom 318		WF-04102023-013100	10/26/2023	FT-FY24-09282023-013100-A	<1	FT-FY24-09282023-013100-B	<1
WS-013102	4/10/2023	4/10/2024	3	Combo Fountain	In classroom 317		WF-04102023-013102	10/26/2023	FT-FY24-09282023-013102-A	<1	FT-FY24-09282023-013102-B	<1
WS-013104	4/10/2023	4/10/2024	3	Combo Fountain	In classroom 316		WF-04102023-013104	10/26/2023	FT-FY24-09282023-013104-A	<1	FT-FY24-09282023-013104-B	<1
WS-013106	4/10/2023	4/10/2024	3	Combo Fountain	In classroom 315		WF-04102023-013106	10/26/2023	FT-FY24-09282023-013106-A	<1	FT-FY24-09282023-013106-B	<1
WS-013108	4/10/2023	4/10/2024	3	Combo Fountain	In classroom 314		WF-04102023-013108	10/26/2023	FT-FY24-09282023-013108-A	<1	FT-FY24-09282023-013108-B	<1
WS-013110	4/10/2023	4/10/2024	3	Combo Fountain	In classroom 313		WF-04102023-013110	10/26/2023	FT-FY24-09282023-013110-A	<1	FT-FY24-09282023-013110-B	<1
WS-013111	4/10/2023	4/10/2024	3	Break Room	In workroom 309		WF-04102023-013111	10/26/2023	FT-FY24-09282023-013111-A	<1	FT-FY24-09282023-013111-B	<1
WS-013114	4/10/2023	4/10/2024	3	Combo Fountain	In instructional coach room 308		WF-04102023-013114	10/26/2023	FT-FY24-09282023-013114-A	3.0	FT-FY24-09282023-013114-B	<1
WS-013116	4/10/2023	4/10/2024	3	Combo Fountain	In classroom 310		WF-04102023-013116	10/26/2023	FT-FY24-09282023-013116-A	<1	FT-FY24-09282023-013116-B	<1
WS-013117	4/10/2023	4/10/2024	3	Cooler	In hallway across from classroom 310	High Left	WF-04102023-013117	10/26/2023	FT-FY24-09282023-013117-A	<1	FT-FY24-09282023-013117-B	<1
WS-013118	4/10/2023	4/10/2024	3	Cooler	In hallway across from classroom 310	Low Right	WF-04102023-013118	10/26/2023	FT-FY24-09282023-013118-A	<1	FT-FY24-09282023-013118-B	<1
WS-013120	4/10/2023	4/10/2024	3	Combo Fountain	In classroom 306		WF-04102023-013120	10/26/2023	FT-FY24-09282023-013120-A	<1	FT-FY24-09282023-013120-B	<1
WS-013122	4/10/2023	4/10/2024	3	Combo Fountain	In classroom 305		WF-04102023-013122	10/26/2023	FT-FY24-09282023-013122-A	<1	FT-FY24-09282023-013122-B	<1
WS-013126	4/10/2023	4/10/2024	2	Bottle Filler	In hallway adjacent to security room 212		WF-04102023-013126	10/26/2023	FT-FY24-09282023-013126-A	<1	FT-FY24-09282023-013126-B	<1
WS-013128	4/10/2023	4/10/2024	3	Bottle Filler	In hallway across from classroom 310		WF-04102023-013128	10/26/2023	FT-FY24-09282023-013128-A	<1	FT-FY24-09282023-013128-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013048	12/21/2022	12/21/2023	1	Food Prep Sink	In rear of kitchen	WF-12212022-013048	10/26/2023	FT-FY24-09282023-013048-A	<1	FT-FY24-09282023-013048-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013021	4/10/2023	4/10/2024	1	Combo Fountain	In workroom 132	WF-04102023-013021	10/26/2023	FT-FY24-09282023-013021-A	14.9	FT-FY24-09282023-013021-B	<1
WS-013077	4/10/2023	4/10/2024	2	Combo Fountain	In workroom 239	WF-04102023-013077	10/26/2023	FT-FY24-09282023-013077-A	9.1	FT-FY24-09282023-013077-B	1.2
WS-013079	4/10/2023	4/10/2024	2	Combo Fountain	In room 237b inside reading learning center 237	WF-04102023-013079	10/26/2023	FT-FY24-09282023-013079-A	9.1	FT-FY24-09282023-013079-B	1.1
WS-013112	4/10/2023	4/10/2024	3	Combo Fountain	In workroom 309	WF-04102023-013112	10/26/2023	FT-FY24-09282023-013112-A	5.2	FT-FY24-09282023-013112-B	<1

First Re-test (After Plumbing Check)

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-013021	10/27/2023	10/27/2024	1	Combo Fountain	In workroom 132	WF-10272023-013021	11/15/2023	FT-FY24-10302023-013021-A	<1	FT-FY24-10302023-013021-B	<1
WS-013077	10/27/2023	10/27/2024	2	Combo Fountain	In workroom 239	WF-10272023-013077	11/15/2023	FT-FY24-10302023-013077-A	<1	FT-FY24-10302023-013077-B	<1
WS-013079	10/27/2023	10/27/2024	2	Combo Fountain	In room 237b inside reading learning center 237	WF-10272023-013079	11/15/2023	FT-FY24-10302023-013079-A	<1	FT-FY24-10302023-013079-B	<1
WS-013112	10/27/2023	10/27/2024	3	Combo Fountain	In workroom 309	WF-10272023-013112	11/15/2023	FT-FY24-10302023-013112-A	<1	FT-FY24-10302023-013112-B	<1