



Brent Elementary School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009308	4/27/2021	4/27/2022	1	Cooler	In hallway adjacent to room 111	WF-04272021-009308	2/14/2022	FT-FY22-12292021-009308-A	<1	FT-FY22-12292021-009308-B	<1
WS-009309	4/27/2021	4/27/2022	1	Health Suite	In health suite 112	WF-04272021-009309	2/14/2022	FT-FY22-12292021-009309-A	<1	FT-FY22-12292021-009309-B	<1
WS-009310	4/27/2021	4/27/2022	1	Cooler	In classroom 116	WF-04272021-009310	2/14/2022	FT-FY22-12292021-009310-A	<1	FT-FY22-12292021-009310-B	<1
WS-009311	9/8/2021	9/8/2022	1	Classroom Faucet	In classroom 116	WF-09082021-009311	2/14/2022	FT-FY22-12292021-009311-A	<1	FT-FY22-12292021-009311-B	<1
WS-009312	4/27/2021	4/27/2022	1	Cooler	In classroom 118	WF-04272021-009312	2/14/2022	FT-FY22-12292021-009312-A	<1	FT-FY22-12292021-009312-B	<1
WS-009313	9/8/2021	9/8/2022	1	Classroom Faucet	In classroom 118	WF-09082021-009313	2/14/2022	FT-FY22-12292021-009313-A	<1	FT-FY22-12292021-009313-B	<1
WS-009314	4/27/2021	4/27/2022	1	Cooler	In classroom 110	WF-04272021-009314	2/14/2022	FT-FY22-12292021-009314-A	<1	FT-FY22-12292021-009314-B	<1
WS-009315	9/8/2021	9/8/2022	1	Classroom Faucet	In classroom 110	WF-09082021-009315	2/14/2022	FT-FY22-12292021-009315-A	<1	FT-FY22-12292021-009315-B	1.5
WS-009316	4/27/2021	4/27/2022	1	Cooler	In classroom 108	WF-04272021-009316	2/14/2022	FT-FY22-12292021-009316-A	<1	FT-FY22-12292021-009316-B	<1
WS-009317	9/8/2021	9/8/2022	1	Classroom Faucet	In classroom 108	WF-09082021-009317	2/14/2022	FT-FY22-12292021-009317-A	<1	FT-FY22-12292021-009317-B	<1
WS-009318	4/27/2021	4/27/2022	1	Cooler	In classroom 104	WF-04272021-009318	2/14/2022	FT-FY22-12292021-009318-A	<1	FT-FY22-12292021-009318-B	<1
WS-009319	9/8/2021	9/8/2022	1	Classroom Faucet	In classroom 104	WF-09082021-009319	2/14/2022	FT-FY22-12292021-009319-A	<1	FT-FY22-12292021-009319-B	<1
WS-009320	4/27/2021	4/27/2022	1	Cooler	In classroom 102	WF-04272021-009320	2/14/2022	FT-FY22-12292021-009320-A	<1	FT-FY22-12292021-009320-B	<1
WS-009321	9/8/2021	9/8/2022	1	Classroom Faucet	In classroom 102	WF-09082021-009321	2/14/2022	FT-FY22-12292021-009321-A	<1	FT-FY22-12292021-009321-B	<1
WS-009322	4/27/2021	4/27/2022	1	Cooler	In multi-purpose room 120	WF-04272021-009322	2/14/2022	FT-FY22-12292021-009322-A	<1	FT-FY22-12292021-009322-B	<1
WS-009326	4/27/2021	4/27/2022	2	Cooler	In hallway across from room 210	WF-04272021-009326	2/14/2022	FT-FY22-12292021-009326-A	<1	FT-FY22-12292021-009326-B	<1
WS-009327	4/27/2021	4/27/2022	2	Break Room	In staff lounge 211	WF-04272021-009327	2/14/2022	FT-FY22-12292021-009327-A	<1	FT-FY22-12292021-009327-B	<1
WS-009331	4/27/2021	4/27/2022	2	Cooler	In hallway across from room 204	WF-04272021-009331	2/14/2022	FT-FY22-12292021-009331-A	<1	FT-FY22-12292021-009331-B	<1
WS-009332	4/27/2021	4/27/2022	2	Cooler	In classroom 204	WF-04272021-009332	2/14/2022	FT-FY22-12292021-009332-A	<1	FT-FY22-12292021-009332-B	<1
WS-009334	4/27/2021	4/27/2022	2	Cooler	In classroom 202	WF-04272021-009334	2/14/2022	FT-FY22-12292021-009334-A	<1	FT-FY22-12292021-009334-B	<1
WS-009336	4/27/2021	4/27/2022	3	Cooler	In hallway across from room 304	WF-04272021-009336	2/14/2022	FT-FY22-12292021-009336-A	<1	FT-FY22-12292021-009336-B	<1
WS-009337	4/27/2021	4/27/2022	3	Cooler	In hallway across from room 310	WF-04272021-009337	2/14/2022	FT-FY22-12292021-009337-A	<1	FT-FY22-12292021-009337-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009324	2/16/2021	2/16/2022	1	Food Prep Sink	In kitchen room 120D Right	WF-02162021-009324	2/14/2022	FT-FY22-12292021-009324-A	<1	FT-FY22-12292021-009324-B	<1