



Brent Elementary School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009308	5/27/2020	5/27/2021	1	Cooler	In hallway adjacent to room 111	WF-05272020-009308	3/6/2021	FT-FY21-022021-009308-A	<1	FT-FY21-022021-009308-B	<1
WS-009309	5/27/2020	5/27/2021	1	Health Suite	In health suite 112	WF-05272020-009309	3/6/2021	FT-FY21-022021-009309-A	<1	FT-FY21-022021-009309-B	<1
WS-009310	5/27/2020	5/27/2021	1	Cooler	In classroom 116	WF-05272020-009310	3/6/2021	FT-FY21-022021-009310-A	<1	FT-FY21-022021-009310-B	<1
WS-009311	9/16/2020	9/16/2021	1	Classroom Faucet	In classroom 116	WF-09162020-009311	3/6/2021	FT-FY21-022021-009311-A	<1	FT-FY21-022021-009311-B	<1
WS-009312	5/27/2020	5/27/2021	1	Cooler	In classroom 118	WF-05272020-009312	3/6/2021	FT-FY21-022021-009312-A	1.6	FT-FY21-022021-009312-B	<1
WS-009313	9/16/2020	9/16/2021	1	Classroom Faucet	In classroom 118	WF-09162020-009313	3/6/2021	FT-FY21-022021-009313-A	<1	FT-FY21-022021-009313-B	<1
WS-009314	5/27/2020	5/27/2021	1	Cooler	In classroom 110	WF-05272020-009314	3/6/2021	FT-FY21-022021-009314-A	<1	FT-FY21-022021-009314-B	<1
WS-009315	9/16/2020	9/16/2021	1	Classroom Faucet	In classroom 110	WF-09162020-009315	3/6/2021	FT-FY21-022021-009315-A	<1	FT-FY21-022021-009315-B	<1
WS-009316	5/27/2020	5/27/2021	1	Cooler	In classroom 108	WF-05272020-009316	3/6/2021	FT-FY21-022021-009316-A	<1	FT-FY21-022021-009316-B	<1
WS-009317	9/16/2020	9/16/2021	1	Classroom Faucet	In classroom 108	WF-09162020-009317	3/6/2021	FT-FY21-022021-009317-A	<1	FT-FY21-022021-009317-B	<1
WS-009318	5/27/2020	5/27/2021	1	Cooler	In classroom 104	WF-05272020-009318	3/6/2021	FT-FY21-022021-009318-A	<1	FT-FY21-022021-009318-B	<1
WS-009319	9/16/2020	9/16/2021	1	Classroom Faucet	In classroom 104	WF-09162020-009319	3/6/2021	FT-FY21-022021-009319-A	1.1	FT-FY21-022021-009319-B	<1
WS-009320	5/27/2020	5/27/2021	1	Cooler	In classroom 102	WF-05272020-009320	3/6/2021	FT-FY21-022021-009320-A	<1	FT-FY21-022021-009320-B	<1
WS-009321	9/16/2020	9/16/2021	1	Classroom Faucet	In classroom 102	WF-09162020-009321	3/6/2021	FT-FY21-022021-009321-A	<1	FT-FY21-022021-009321-B	<1
WS-009322	5/27/2020	5/27/2021	1	Cooler	In multi-purpose room 120	WF-05272020-009322	3/6/2021	FT-FY21-022021-009322-A	<1	FT-FY21-022021-009322-B	<1
WS-009326	5/27/2020	5/27/2021	2	Cooler	In hallway across from room 210	WF-05272020-009326	3/6/2021	FT-FY21-022021-009326-A	<1	FT-FY21-022021-009326-B	<1
WS-009327	5/27/2020	5/27/2021	2	Break Room	In staff lounge 211	WF-05272020-009327	3/6/2021	FT-FY21-022021-009327-A	<1	FT-FY21-022021-009327-B	<1
WS-009331	5/27/2020	5/27/2021	2	Cooler	In hallway across from room 204	WF-05272020-009331	3/6/2021	FT-FY21-022021-009331-A	<1	FT-FY21-022021-009331-B	<1
WS-009332	5/27/2020	5/27/2021	2	Cooler	In classroom 204	WF-05272020-009332	3/6/2021	FT-FY21-022021-009332-A	<1	FT-FY21-022021-009332-B	<1
WS-009334	5/27/2020	5/27/2021	2	Cooler	In classroom 202	WF-05272020-009334	3/6/2021	FT-FY21-022021-009334-A	<1	FT-FY21-022021-009334-B	<1
WS-009336	5/27/2020	5/27/2021	3	Cooler	In hallway across from room 304	WF-05272020-009336	3/6/2021	FT-FY21-022021-009336-A	<1	FT-FY21-022021-009336-B	<1
WS-009337	5/27/2020	5/27/2021	3	Cooler	In hallway across from room 310	WF-05272020-009337	3/6/2021	FT-FY21-022021-009337-A	<1	FT-FY21-022021-009337-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009324	2/16/2021	2/16/2022	1	Food Prep Sink	In kitchen room 120D Right	WF-02162021-009324	3/6/2021	FT-FY21-022021-009324-A	<1	FT-FY21-022021-009324-B	<1