



Brent ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009308	6/3/2019	6/3/2020	1	Cooler	In hallway adjacent to room 111	WF-06032019-009308	11/10/2019	FT-FY20-112019-009308-A	<1	FT-FY20-112019-009308-B	<1
WS- 009309	6/3/2019	6/3/2020	1	Health Suite	In health suite 112	WF-06032019-009309	11/10/2019	FT-FY20-112019-009309-A	<1	FT-FY20-112019-009309-B	<1
WS- 009310	6/3/2019	6/3/2020	1	Cooler	In classroom 116	WF-06032019-009310	11/10/2019	FT-FY20-112019-009310-A	<1	FT-FY20-112019-009310-B	<1
WS- 009311	9/24/2019	9/24/2020	1	Classroom Faucet	In classroom 116	WF-09242019-009311	11/10/2019	FT-FY20-112019-009311-A	<1	FT-FY20-112019-009311-B	<1
WS- 009312	6/3/2019	6/3/2020	1	Cooler	In classroom 118	WF-06032019-009312	11/10/2019	FT-FY20-112019-009312-A	<1	FT-FY20-112019-009312-B	<1
WS- 009313	9/24/2019	9/24/2020	1	Classroom Faucet	In classroom 118	WF-09242019-009313	11/10/2019	FT-FY20-112019-009313-A	2.5	FT-FY20-112019-009313-B	<1
WS- 009314	6/3/2019	6/3/2020	1	Cooler	In classroom 110	WF-06032019-009314	11/10/2019	FT-FY20-112019-009314-A	<1	FT-FY20-112019-009314-B	<1
WS- 009315	9/24/2019	9/24/2020	1	Classroom Faucet	In classroom 110	WF-09242019-009315	11/10/2019	FT-FY20-112019-009315-A	<1	FT-FY20-112019-009315-B	<1
WS- 009316	6/3/2019	6/3/2020	1	Cooler	In classroom 108	WF-06032019-009316	11/10/2019	FT-FY20-112019-009316-A	<1	FT-FY20-112019-009316-B	<1
WS- 009317	9/24/2019	9/24/2020	1	Classroom Faucet	In classroom 108	WF-09242019-009317	11/10/2019	FT-FY20-112019-009317-A	<1	FT-FY20-112019-009317-B	<1
WS- 009318	6/3/2019	6/3/2020	1	Cooler	In classroom 104	WF-06032019-009318	11/10/2019	FT-FY20-112019-009318-A	<1	FT-FY20-112019-009318-B	<1
WS- 009319	9/24/2019	9/24/2020	1	Classroom Faucet	In classroom 104	WF-09242019-009319	11/10/2019	FT-FY20-112019-009319-A	3.5	FT-FY20-112019-009319-B	<1
WS- 009320	6/3/2019	6/3/2020	1	Cooler	In classroom 102	WF-06032019-009320	11/10/2019	FT-FY20-112019-009320-A	<1	FT-FY20-112019-009320-B	<1
WS- 009321	9/24/2019	9/24/2020	1	Classroom Faucet	In classroom 102	WF-09242019-009321	11/10/2019	FT-FY20-112019-009321-A	3	FT-FY20-112019-009321-B	<1
WS- 009322	6/3/2019	6/3/2020	1	Cooler	In multi-purpose room 120	WF-06032019-009322	11/10/2019	FT-FY20-112019-009322-A	<1	FT-FY20-112019-009322-B	<1
WS- 009326	6/3/2019	6/3/2020	2	Cooler	In hallway across from room 210	WF-06032019-009326	11/10/2019	FT-FY20-112019-009326-A	<1	FT-FY20-112019-009326-B	<1
WS- 009327	6/3/2019	6/3/2020	2	Break Room	In staff lounge 211	WF-06032019-009327	11/10/2019	FT-FY20-112019-009327-A	<1	FT-FY20-112019-009327-B	<1
WS- 009331	6/3/2019	6/3/2020	2	Cooler	In hallway across from room 204	WF-06032019-009331	11/10/2019	FT-FY20-112019-009331-A	<1	FT-FY20-112019-009331-B	<1
WS- 009332	6/3/2019	6/3/2020	2	Cooler	In classroom 204	WF-06032019-009332	11/10/2019	FT-FY20-112019-009332-A	<1	FT-FY20-112019-009332-B	<1
WS- 009334	6/3/2019	6/3/2020	2	Cooler	In classroom 202	WF-06032019-009334	11/10/2019	FT-FY20-112019-009334-A	<1	FT-FY20-112019-009334-B	<1
WS- 009336	6/3/2019	6/3/2020	3	Cooler	In hallway across from room 304	WF-06032019-009336	11/10/2019	FT-FY20-112019-009336-A	<1	FT-FY20-112019-009336-B	<1
WS- 009337	6/3/2019	6/3/2020	3	Cooler	In hallway across from room 310	WF-06032019-009337	11/10/2019	FT-FY20-112019-009337-A	<1	FT-FY20-112019-009337-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009324	7/8/2019	7/8/2020	1	Food Prep Sink	In kitchen room 120D Right	WF-07082019-009324	11/10/2019	FT-FY20-112019-009324-A	<1	FT-FY20-112019-009324-B	<1