



Brent Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009308	4/19/2022	4/19/2023	1	Cooler	In hallway adjacent to room 111	WF-04192022-009308	11/21/2022	FT-FY23-11042022-009308-A	<1	FT-FY23-11042022-009308-B	<1
WS- 009309	4/19/2022	4/19/2023	1	Health Suite	In health suite 112	WF-04192022-009309	11/21/2022	FT-FY23-11042022-009309-A	<1	FT-FY23-11042022-009309-B	<1
WS- 009310	4/19/2022	4/19/2023	1	Cooler	In classroom 116	WF-04192022-009310	11/21/2022	FT-FY23-11042022-009310-A	<1	FT-FY23-11042022-009310-B	<1
WS- 009311	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 116	WF-09062022-009311	11/21/2022	FT-FY23-11042022-009311-A	<1	FT-FY23-11042022-009311-B	<1
WS- 009312	4/19/2022	4/19/2023	1	Cooler	In classroom 118	WF-04192022-009312	11/21/2022	FT-FY23-11042022-009312-A	<1	FT-FY23-11042022-009312-B	<1
WS- 009313	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 118	WF-09062022-009313	11/21/2022	FT-FY23-11042022-009313-A	<1	FT-FY23-11042022-009313-B	<1
WS- 009314	4/19/2022	4/19/2023	1	Cooler	In classroom 110	WF-04192022-009314	11/21/2022	FT-FY23-11042022-009314-A	<1	FT-FY23-11042022-009314-B	<1
WS- 009315	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 110	WF-09062022-009315	11/21/2022	FT-FY23-11042022-009315-A	<1	FT-FY23-11042022-009315-B	<1
WS- 009316	4/19/2022	4/19/2023	1	Cooler	In classroom 108	WF-04192022-009316	11/21/2022	FT-FY23-11042022-009316-A	<1	FT-FY23-11042022-009316-B	<1
WS- 009317	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 108	WF-09062022-009317	11/21/2022	FT-FY23-11042022-009317-A	<1	FT-FY23-11042022-009317-B	<1
WS- 009319	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 104	WF-09062022-009319	11/21/2022	FT-FY23-11042022-009319-A	<1	FT-FY23-11042022-009319-B	<1
WS- 009321	9/6/2022	9/6/2023	1	Classroom Faucet	In classroom 102	WF-09062022-009321	11/21/2022	FT-FY23-11042022-009321-A	<1	FT-FY23-11042022-009321-B	<1
WS- 009322	4/19/2022	4/19/2023	1	Cooler	In multi-purpose room 120	WF-04192022-009322	11/21/2022	FT-FY23-11042022-009322-A	<1	FT-FY23-11042022-009322-B	<1
WS- 009326	4/19/2022	4/19/2023	2	Cooler	In hallway across from room 210	WF-04192022-009326	11/21/2022	FT-FY23-11042022-009326-A	<1	FT-FY23-11042022-009326-B	<1
WS- 009327	4/19/2022	4/19/2023	2	Break Room	In staff lounge 211	WF-04192022-009327	11/21/2022	FT-FY23-11042022-009327-A	<1	FT-FY23-11042022-009327-B	<1
WS- 009331	4/19/2022	4/19/2023	2	Cooler	In hallway across from room 204	WF-04192022-009331	11/21/2022	FT-FY23-11042022-009331-A	<1	FT-FY23-11042022-009331-B	<1
WS- 010969	4/19/2022	4/19/2023	3	Bottle Filler	In hallway across from room 304	WF-04192022-010969	11/21/2022	FT-FY23-11042022-010969-A	<1	FT-FY23-11042022-010969-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009324	2/9/2022	2/9/2023	1	Food Prep Sink	In kitchen room 120D Right	WF-02092022-009324	11/21/2022	FT-FY23-11042022-009324-A	<1	FT-FY23-11042022-009324-B	<1