



# BRENT ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BRENT ELEMENTARY SCHOOL	WS- 009308	8/16/2016	1	Cooler	In hallway adjacent to room 111	FT-72016-009308-A	< 1	FT-72016-009308-B	< 1
2	BRENT ELEMENTARY SCHOOL	WS- 009309	8/16/2016	1	Health Suite	In health suite 112	FT-72016-009309-A	< 1	FT-72016-009309-B	< 1
3	BRENT ELEMENTARY SCHOOL	WS- 009310	8/16/2016	1	Cooler	In classroom 116	FT-72016-009310-A	< 1	FT-72016-009310-B	< 1
4	BRENT ELEMENTARY SCHOOL	WS- 009312	8/16/2016	1	Cooler	In classroom 118	FT-72016-009312-A	< 1	FT-72016-009312-B	< 1
5	BRENT ELEMENTARY SCHOOL	WS- 009314	8/16/2016	1	Cooler	In classroom 110	FT-72016-009314-A	< 1	FT-72016-009314-B	< 1
6	BRENT ELEMENTARY SCHOOL	WS- 009316	8/16/2016	1	Cooler	In classroom 108	FT-72016-009316-A	< 1	FT-72016-009316-B	< 1
7	BRENT ELEMENTARY SCHOOL	WS- 009318	8/16/2016	1	Cooler	In classroom 104	FT-72016-009318-A	< 1	FT-72016-009318-B	< 1
8	BRENT ELEMENTARY SCHOOL	WS- 009320	8/16/2016	1	Cooler	In classroom 102	FT-72016-009320-A	< 1	FT-72016-009320-B	< 1
9	BRENT ELEMENTARY SCHOOL	WS- 009322	8/16/2016	1	Cooler	In multi-purpose room 120	FT-72016-009322-A	< 1	FT-72016-009322-B	< 1
10	BRENT ELEMENTARY SCHOOL	WS- 009324	8/16/2016	1	Food Prep Sink	In kitchen room 120D Right	FT-72016-009324-A	< 1	FT-72016-009324-B	< 1
11	BRENT ELEMENTARY SCHOOL	WS- 009326	8/16/2016	2	Cooler	In hallway across from room 210	FT-72016-009326-A	< 1	FT-72016-009326-B	< 1
12	BRENT ELEMENTARY SCHOOL	WS- 009331	8/16/2016	2	Cooler	In hallway across from room 204	FT-72016-009331-A	< 1	FT-72016-009331-B	< 1
13	BRENT ELEMENTARY SCHOOL	WS- 009332	8/16/2016	2	Cooler	In classroom 204	FT-72016-009332-A	< 1	FT-72016-009332-B	< 1
14	BRENT ELEMENTARY SCHOOL	WS- 009334	8/16/2016	2	Cooler	In classroom 202	FT-72016-009334-A	< 1	FT-72016-009334-B	< 1
15	BRENT ELEMENTARY SCHOOL	WS- 009336	8/16/2016	3	Cooler	In hallway across from room 304	FT-72016-009336-A	< 1	FT-72016-009336-B	< 1
16	BRENT ELEMENTARY SCHOOL	WS- 009337	8/16/2016	3	Cooler	In hallway across from room 310	FT-72016-009337-A	< 1	FT-72016-009337-B	< 1