



BRENT LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009307	Utility	Ground Floor	In boiler room spicket off waterline	WT-042916-9324- A	6.8	WT-042916-9324- B	< 1				
2 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009308	Cooler	1	In hallway adjacent storage closet 111	WT-042916-9325- A	< 1	WT-042916-9325- B	< 1				
3 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009309	Health Suite	1	In health suite 112	WT-042916-9326- A	< 1	WT-042916-9326- B	< 1				
4 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009310	Cooler	1	In classroom 116	WT-042916-9327- A	< 1	WT-042916-9327- B	< 1				
5 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009311	Classroom	1	In classroom 116	WT-042916-9328- A	< 1	WT-042916-9328- B	< 1				
6 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009312	Cooler	1	In classroom 118	WT-042916-9329- A	< 1	WT-042916-9329- B	< 1				
7 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009313	Classroom	1	In classroom 118	WT-042916-9330- A	< 1	WT-042916-9330- B	1.4				
8 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009314	Cooler	1	In classroom 110	WT-042916-9331- A	< 1	WT-042916-9331- B	< 1				
9 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009315	Classroom	1	In classroom 110	WT-042916-9332- A	2.7	WT-042916-9332- B	< 1				
10 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009316	Cooler	1	In classroom 108	WT-042916-9333- A	< 1	WT-042916-9333- B	< 1				
11 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009317	Classroom	1	In classroom 108	WT-042916-9334- A	< 1	WT-042916-9334- B	< 1				
12 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009318	Cooler	1	In classroom 104	WT-042916-9335- A	< 1	WT-042916-9335- B	< 1				
13 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009319	Classroom	1	In classroom 104	WT-042916-9336- A	< 1	WT-042916-9336- B	< 1				
14 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009320	Cooler	1	In classroom 102	WT-042916-9337- A	< 1	WT-042916-9337- B	< 1				
15 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009321	Classroom	1	In classroom 102	WT-042916-9338- A	< 1	WT-042916-9338- B	< 1				
16 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009322	Cooler	1	In multi-purpose room 120	WT-042916-9339- A	< 1	WT-042916-9339- B	< 1				
17 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009323	Kitchen	1	In kitchen 120D Left	WT-042916-9340- A	< 1	WT-042916-9340- B	< 1				
18 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009324	Kitchen	1	In kitchen 120D Right	WT-042916-9341- A	1.1	WT-042916-9341- B	< 1				
19 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009325	Classroom	1	In classroom media 115 in room 115B	WT-042916-9342- A	1.1	WT-042916-9342- B	< 1				
20 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009326	Cooler	2	In hallway across classroom 210	WT-042916-9343- A	< 1	WT-042916-9343- B	< 1				
21 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009327	Break Room	2	In teachers lounge 211	WT-042916-9344- A	1	WT-042916-9344- B	< 1				
22 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009328	Classroom	2	In classroom 213	WT-042916-9345- A	1.3	WT-042916-9345- B	< 1				
23 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009329	Classroom	2	In second floor art room 208 Left	WT-042916-9346- A	< 1	WT-042916-9346- B	< 1				
24 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009330	Classroom	2	In art room 208 Right	WT-042916-9347- A	1.2	WT-042916-9347- B	< 1				
25 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009331	Cooler	2	In hallway across classroom 204	WT-042916-9348- A	< 1	WT-042916-9348- B	< 1				
26 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009332	Cooler	2	In classroom 204	WT-042916-9349- A	< 1	WT-042916-9349- B	< 1				
27 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009333	Classroom	2	In classroom 204	WT-042916-9350- A	< 1	WT-042916-9350- B	< 1				
28 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009334	Cooler	2	In classroom 202	WT-042916-9351- A	< 1	WT-042916-9351- B	< 1				
29 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009335	Classroom	2	In classroom 202	WT-042916-9352- A	< 1	WT-042916-9352- B	< 1				
30 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009336	Cooler	3	In hallway across 304	WT-042916-9353- A	< 1	WT-042916-9353- B	< 1				
31 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009337	Cooler	3	In hallway across classroom 310	WT-042916-9354- A	< 1	WT-042916-9354- B	< 1				
32 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009338	Classroom	3	In science lab 308	WT-042916-9355- A	< 1	WT-042916-9355- B	< 1				
33 BRENT ELEMENTARY SCHOOL	5/11/2016	WS- 009339	Kitchen	1	In kitchen in dish room 120K	WT-042916-9356- A	1.1	WT-042916-9356- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.