



Brent ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009308	6/7/2018	6/7/2019	1	Cooler	In hallway adjacent to room 111	WF-06072018-009308	11/19/2018	FT-FY19-112018-009308-A	< 1	FT-FY19-112018-009308-B	< 1
WS- 009309	6/7/2018	6/7/2019	1	Health Suite	In health suite 112	WF-06072018-009309	11/19/2018	FT-FY19-112018-009309-A	< 1	FT-FY19-112018-009309-B	< 1
WS- 009310	6/7/2018	6/7/2019	1	Cooler	In classroom 116	WF-06072018-009310	11/19/2018	FT-FY19-112018-009310-A	< 1	FT-FY19-112018-009310-B	< 1
WS- 009311	10/1/2018	10/1/2019	1	Classroom Faucet	In classroom 116	WF-10012018-009311	11/19/2018	FT-FY19-112018-009311-A	< 1	FT-FY19-112018-009311-B	< 1
WS- 009312	6/7/2018	6/7/2019	1	Cooler	In classroom 118	WF-06072018-009312	11/19/2018	FT-FY19-112018-009312-A	< 1	FT-FY19-112018-009312-B	< 1
WS- 009313	10/1/2018	10/1/2019	1	Classroom Faucet	In classroom 118	WF-10012018-009313	11/19/2018	FT-FY19-112018-009313-A	< 1	FT-FY19-112018-009313-B	< 1
WS- 009314	6/7/2018	6/7/2019	1	Cooler	In classroom 110	WF-06072018-009314	11/19/2018	FT-FY19-112018-009314-A	< 1	FT-FY19-112018-009314-B	< 1
WS- 009315	10/1/2018	10/1/2019	1	Classroom Faucet	In classroom 110	WF-10012018-009315	11/19/2018	FT-FY19-112018-009315-A	< 1	FT-FY19-112018-009315-B	< 1
WS- 009316	6/7/2018	6/7/2019	1	Cooler	In classroom 108	WF-06072018-009316	11/19/2018	FT-FY19-112018-009316-A	< 1	FT-FY19-112018-009316-B	< 1
WS- 009317	10/1/2018	10/1/2019	1	Classroom Faucet	In classroom 108	WF-10012018-009317	11/19/2018	FT-FY19-112018-009317-A	< 1	FT-FY19-112018-009317-B	< 1
WS- 009318	6/7/2018	6/7/2019	1	Cooler	In classroom 104	WF-06072018-009318	11/19/2018	FT-FY19-112018-009318-A	< 1	FT-FY19-112018-009318-B	< 1
WS- 009319	10/1/2018	10/1/2019	1	Classroom Faucet	In classroom 104	WF-10012018-009319	11/19/2018	FT-FY19-112018-009319-A	3.2	FT-FY19-112018-009319-B	< 1
WS- 009320	6/7/2018	6/7/2019	1	Cooler	In classroom 102	WF-06072018-009320	11/19/2018	FT-FY19-112018-009320-A	< 1	FT-FY19-112018-009320-B	< 1
WS- 009322	6/7/2018	6/7/2019	1	Cooler	In multi-purpose room 120	WF-06072018-009322	11/19/2018	FT-FY19-112018-009322-A	< 1	FT-FY19-112018-009322-B	< 1
WS- 009326	6/7/2018	6/7/2019	2	Cooler	In hallway across from room 210	WF-06072018-009326	11/19/2018	FT-FY19-112018-009326-A	< 1	FT-FY19-112018-009326-B	< 1
WS- 009327	6/7/2018	6/7/2019	2	Break Room	In staff lounge 211	WF-06072018-009327	11/19/2018	FT-FY19-112018-009327-A	< 1	FT-FY19-112018-009327-B	< 1
WS- 009331	6/7/2018	6/7/2019	2	Cooler	In hallway across from room 204	WF-06072018-009331	11/19/2018	FT-FY19-112018-009331-A	< 1	FT-FY19-112018-009331-B	< 1
WS- 009332	8/20/2018	8/20/2019	2	Cooler	In classroom 204	WF-08202018-009332	11/19/2018	FT-FY19-112018-009332-A	< 1	FT-FY19-112018-009332-B	< 1
WS- 009334	6/7/2018	6/7/2019	2	Cooler	In classroom 202	WF-06072018-009334	11/19/2018	FT-FY19-112018-009334-A	< 1	FT-FY19-112018-009334-B	< 1
WS- 009336	6/7/2018	6/7/2019	3	Cooler	In hallway across from room 304	WF-06072018-009336	11/19/2018	FT-FY19-112018-009336-A	< 1	FT-FY19-112018-009336-B	< 1
WS- 009337	6/7/2018	6/7/2019	3	Cooler	In hallway across from room 310	WF-06072018-009337	11/19/2018	FT-FY19-112018-009337-A	< 1	FT-FY19-112018-009337-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)			
WS- 009323	1	Food Prep Sink	In kitchen room 120D Left	11/19/2018	FT-FY19-112018-009323-A	< 1	FT-FY19-112018-009323-B	< 1			

FY19 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009321	10/1/2018	10/1/2019	1	Classroom Faucet	In classroom 102	WF-10012018-009321	11/19/2018	FT-FY19-112018-009321-A	6.4	FT-FY19-112018-009321-B	< 1