



Brightwood Education Campus Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003372	5/9/2023	5/9/2024	1	Bottle Filler	In hallway adjacent to room 123	WF-05092023-003372	11/10/2023	FT-FY24-10102023-003372-A	<1	FT-FY24-10102023-003372-B	<1	
WS- 003373	5/9/2023	5/9/2024	3	Bottle Filler	In hallway adjacent to room 307	WF-05092023-003373	11/10/2023	FT-FY24-10102023-003373-A	<1	FT-FY24-10102023-003373-B	<1	
WS- 003374	5/9/2023	5/9/2024	2	Bottle Filler	In hallway adjacent to room 211	WF-05092023-003374	11/10/2023	FT-FY24-10102023-003374-A	<1	FT-FY24-10102023-003374-B	1.5	
WS- 003382	8/21/2023	8/21/2024	1	Bathroom	In classroom 142 in bathroom	WF-08212023-003382	11/10/2023	FT-FY24-10102023-003382-A	2.5	FT-FY24-10102023-003382-B	<1	
WS- 003383	8/21/2023	8/21/2024	1	Bathroom	In classroom 143 in bathroom	WF-08212023-003383	11/10/2023	FT-FY24-10102023-003383-A	1.9	FT-FY24-10102023-003383-B	<1	
WS- 003384	8/21/2023	8/21/2024	1	Bathroom	In classroom 146 in bathroom	WF-08212023-003384	11/10/2023	FT-FY24-10102023-003384-A	1.5	FT-FY24-10102023-003384-B	<1	
WS- 003385	8/21/2023	8/21/2024	1	Bathroom	In classroom 147 in bathroom	WF-08212023-003385	11/10/2023	FT-FY24-10102023-003385-A	2.4	FT-FY24-10102023-003385-B	<1	
WS- 003386	8/21/2023	8/21/2024	1	Bathroom	In classroom 125 in bathroom	WF-08212023-003386	11/10/2023	FT-FY24-10102023-003386-A	2.6	FT-FY24-10102023-003386-B	<1	
WS- 003387	8/21/2023	8/21/2024	1	Bathroom	In classroom 130 in bathroom	WF-08212023-003387	11/10/2023	FT-FY24-10102023-003387-A	3.1	FT-FY24-10102023-003387-B	<1	
WS- 003388	8/21/2023	8/21/2024	1	Bathroom	In classroom 136 in bathroom	WF-08212023-003388	11/10/2023	FT-FY24-10102023-003388-A	1.7	FT-FY24-10102023-003388-B	<1	
WS- 003389	8/21/2023	8/21/2024	1	Bathroom	In classroom 137 in bathroom	WF-08212023-003389	11/10/2023	FT-FY24-10102023-003389-A	1.5	FT-FY24-10102023-003389-B	<1	
WS- 003390	8/21/2023	8/21/2024	1	Bathroom	In classroom 138 in bathroom	WF-08212023-003390	11/10/2023	FT-FY24-10102023-003390-A	1.5	FT-FY24-10102023-003390-B	<1	
WS- 003394	5/9/2023	5/9/2024	1	Cooler	In hallway adjacent to 106a	High Left	WF-05092023-003394	11/10/2023	FT-FY24-10102023-003394-A	<1	FT-FY24-10102023-003394-B	<1
WS- 003395	5/9/2023	5/9/2024	1	Cooler	In hallway adjacent to 106A	Low Right	WF-05092023-003395	11/10/2023	FT-FY24-10102023-003395-A	<1	FT-FY24-10102023-003395-B	<1
WS- 003396	5/9/2023	5/9/2024	1	Health Suite	In health suite in exam room 106D	WF-05092023-003396	11/10/2023	FT-FY24-10102023-003396-A	1.5	FT-FY24-10102023-003396-B	<1	
WS- 003399	5/9/2023	5/9/2024	1	Cooler	In hallway adjacent to room 123	Low Right	WF-05092023-003399	11/10/2023	FT-FY24-10102023-003399-A	<1	FT-FY24-10102023-003399-B	<1
WS- 003400	5/9/2023	5/9/2024	1	Cooler	In hallway adjacent to room 123	High Left	WF-05092023-003400	11/10/2023	FT-FY24-10102023-003400-A	<1	FT-FY24-10102023-003400-B	<1
WS- 003401	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 125	WF-05092023-003401	11/10/2023	FT-FY24-10102023-003401-A	1.3	FT-FY24-10102023-003401-B	<1	
WS- 003402	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 125	WF-08212023-003402	11/10/2023	FT-FY24-10102023-003402-A	1.2	FT-FY24-10102023-003402-B	<1	
WS- 003403	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 128	WF-05092023-003403	11/10/2023	FT-FY24-10102023-003403-A	1.7	FT-FY24-10102023-003403-B	<1	
WS- 003404	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 128	WF-08212023-003404	11/10/2023	FT-FY24-10102023-003404-A	<1	FT-FY24-10102023-003404-B	<1	
WS- 003405	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 130	WF-05092023-003405	11/10/2023	FT-FY24-10102023-003405-A	<1	FT-FY24-10102023-003405-B	<1	
WS- 003406	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 130	WF-08212023-003406	11/10/2023	FT-FY24-10102023-003406-A	<1	FT-FY24-10102023-003406-B	<1	
WS- 003407	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 136	WF-05092023-003407	11/10/2023	FT-FY24-10102023-003407-A	2.0	FT-FY24-10102023-003407-B	3.0	
WS- 003408	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 136	WF-08212023-003408	11/10/2023	FT-FY24-10102023-003408-A	<1	FT-FY24-10102023-003408-B	<1	
WS- 003409	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 137	WF-05092023-003409	11/10/2023	FT-FY24-10102023-003409-A	<1	FT-FY24-10102023-003409-B	<1	
WS- 003410	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 137	WF-08212023-003410	11/10/2023	FT-FY24-10102023-003410-A	1.3	FT-FY24-10102023-003410-B	<1	
WS- 003411	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 138	WF-05092023-003411	11/10/2023	FT-FY24-10102023-003411-A	<1	FT-FY24-10102023-003411-B	<1	
WS- 003412	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 138	WF-08212023-003412	11/10/2023	FT-FY24-10102023-003412-A	1.4	FT-FY24-10102023-003412-B	<1	
WS- 003413	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 142	WF-05092023-003413	11/10/2023	FT-FY24-10102023-003413-A	<1	FT-FY24-10102023-003413-B	<1	
WS- 003414	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 142	WF-08212023-003414	11/10/2023	FT-FY24-10102023-003414-A	2.5	FT-FY24-10102023-003414-B	<1	
WS- 003415	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 143	WF-05092023-003415	11/10/2023	FT-FY24-10102023-003415-A	<1	FT-FY24-10102023-003415-B	<1	
WS- 003416	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 143	WF-08212023-003416	11/10/2023	FT-FY24-10102023-003416-A	3.0	FT-FY24-10102023-003416-B	<1	
WS- 003417	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 145	WF-05092023-003417	11/10/2023	FT-FY24-10102023-003417-A	<1	FT-FY24-10102023-003417-B	<1	
WS- 003418	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 145	WF-08212023-003418	11/10/2023	FT-FY24-10102023-003418-A	3.5	FT-FY24-10102023-003418-B	<1	

WS-003419	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 147		WF-05092023-003419	11/10/2023	FT-FY24-10102023-003419-A	<1	FT-FY24-10102023-003419-B	<1
WS-003420	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 147		WF-08212023-003420	11/10/2023	FT-FY24-10102023-003420-A	1.4	FT-FY24-10102023-003420-B	<1
WS-003421	5/9/2023	5/9/2024	1	Combo Fountain	In classroom 146		WF-05092023-003421	11/10/2023	FT-FY24-10102023-003421-A	1.2	FT-FY24-10102023-003421-B	<1
WS-003422	8/21/2023	8/21/2024	1	Combo Faucet	In classroom 146		WF-08212023-003422	11/10/2023	FT-FY24-10102023-003422-A	<1	FT-FY24-10102023-003422-B	<1
WS-003423	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 228		WF-05092023-003423	11/10/2023	FT-FY24-10102023-003423-A	<1	FT-FY24-10102023-003423-B	<1
WS-003424	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 228		WF-08212023-003424	11/10/2023	FT-FY24-10102023-003424-A	3.0	FT-FY24-10102023-003424-B	4.2
WS-003425	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 239		WF-05092023-003425	11/10/2023	FT-FY24-10102023-003425-A	4.0	FT-FY24-10102023-003425-B	1.6
WS-003426	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 239		WF-08212023-003426	11/10/2023	FT-FY24-10102023-003426-A	2.8	FT-FY24-10102023-003426-B	1.1
WS-003427	5/9/2023	5/9/2024	2	Combo Fountain	In staff workroom 237		WF-05092023-003427	11/10/2023	FT-FY24-10102023-003427-A	<1	FT-FY24-10102023-003427-B	<1
WS-003428	5/9/2023	5/9/2024	2	Break Room	In staff workroom 237		WF-05092023-003428	11/10/2023	FT-FY24-10102023-003428-A	1.4	FT-FY24-10102023-003428-B	<1
WS-003429	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 235		WF-05092023-003429	11/10/2023	FT-FY24-10102023-003429-A	<1	FT-FY24-10102023-003429-B	<1
WS-003431	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 224		WF-05092023-003431	11/10/2023	FT-FY24-10102023-003431-A	<1	FT-FY24-10102023-003431-B	<1
WS-003432	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 224		WF-08212023-003432	11/10/2023	FT-FY24-10102023-003432-A	2.2	FT-FY24-10102023-003432-B	<1
WS-003433	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 231		WF-05092023-003433	11/10/2023	FT-FY24-10102023-003433-A	<1	FT-FY24-10102023-003433-B	<1
WS-003434	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 231		WF-08212023-003434	11/10/2023	FT-FY24-10102023-003434-A	1.1	FT-FY24-10102023-003434-B	<1
WS-003435	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 218		WF-05092023-003435	11/10/2023	FT-FY24-10102023-003435-A	<1	FT-FY24-10102023-003435-B	<1
WS-003436	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 218		WF-08212023-003436	11/10/2023	FT-FY24-10102023-003436-A	1.6	FT-FY24-10102023-003436-B	<1
WS-003437	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 216		WF-05092023-003437	11/10/2023	FT-FY24-10102023-003437-A	<1	FT-FY24-10102023-003437-B	<1
WS-003439	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 214		WF-05092023-003439	11/10/2023	FT-FY24-10102023-003439-A	<1	FT-FY24-10102023-003439-B	<1
WS-003440	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 214		WF-08212023-003440	11/10/2023	FT-FY24-10102023-003440-A	2.0	FT-FY24-10102023-003440-B	<1
WS-003441	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 212		WF-05092023-003441	11/10/2023	FT-FY24-10102023-003441-A	<1	FT-FY24-10102023-003441-B	<1
WS-003442	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 212		WF-08212023-003442	11/10/2023	FT-FY24-10102023-003442-A	1.6	FT-FY24-10102023-003442-B	<1
WS-003443	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 213		WF-05092023-003443	11/10/2023	FT-FY24-10102023-003443-A	<1	FT-FY24-10102023-003443-B	<1
WS-003444	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 213		WF-08212023-003444	11/10/2023	FT-FY24-10102023-003444-A	2.0	FT-FY24-10102023-003444-B	<1
WS-003445	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 210		WF-05092023-003445	11/10/2023	FT-FY24-10102023-003445-A	<1	FT-FY24-10102023-003445-B	<1
WS-003446	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 210		WF-08212023-003446	11/10/2023	FT-FY24-10102023-003446-A	1.7	FT-FY24-10102023-003446-B	<1
WS-003450	5/9/2023	5/9/2024	2	Combo Fountain	In classroom 206		WF-05092023-003450	11/10/2023	FT-FY24-10102023-003450-A	<1	FT-FY24-10102023-003450-B	<1
WS-003452	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 206		WF-08212023-003452	11/10/2023	FT-FY24-10102023-003452-A	2.1	FT-FY24-10102023-003452-B	<1
WS-003453	5/9/2023	5/9/2024	2	Cooler	In hallway adjacent to room 211	Low Right	WF-05092023-003453	11/10/2023	FT-FY24-10102023-003453-A	<1	FT-FY24-10102023-003453-B	<1
WS-003454	5/9/2023	5/9/2024	2	Cooler	In hallway adjacent to room 211	High Left	WF-05092023-003454	11/10/2023	FT-FY24-10102023-003454-A	<1	FT-FY24-10102023-003454-B	<1
WS-003456	5/9/2023	5/9/2024	3	Combo Fountain	In classroom 309		WF-05092023-003456	11/10/2023	FT-FY24-10102023-003456-A	1.9	FT-FY24-10102023-003456-B	<1
WS-003457	8/21/2023	8/21/2024	3	Combo Faucet	In classroom 309		WF-08212023-003457	11/10/2023	FT-FY24-10102023-003457-A	1.4	FT-FY24-10102023-003457-B	<1
WS-003458	5/9/2023	5/9/2024	3	Combo Fountain	In classroom 308		WF-05092023-003458	11/10/2023	FT-FY24-10102023-003458-A	<1	FT-FY24-10102023-003458-B	<1
WS-003459	8/21/2023	8/21/2024	3	Combo Faucet	In classroom 308		WF-08212023-003459	11/10/2023	FT-FY24-10102023-003459-A	1.3	FT-FY24-10102023-003459-B	<1
WS-003460	5/9/2023	5/9/2024	3	Combo Fountain	In classroom 310		WF-05092023-003460	11/10/2023	FT-FY24-10102023-003460-A	<1	FT-FY24-10102023-003460-B	<1
WS-003461	8/21/2023	8/21/2024	3	Combo Faucet	In classroom 310		WF-08212023-003461	11/10/2023	FT-FY24-10102023-003461-A	1.5	FT-FY24-10102023-003461-B	<1
WS-003462	5/9/2023	5/9/2024	3	Combo Fountain	In classroom 312		WF-05092023-003462	11/10/2023	FT-FY24-10102023-003462-A	<1	FT-FY24-10102023-003462-B	<1
WS-003463	8/21/2023	8/21/2024	3	Combo Faucet	In classroom 312		WF-08212023-003463	11/10/2023	FT-FY24-10102023-003463-A	1.7	FT-FY24-10102023-003463-B	<1
WS-003464	5/9/2023	5/9/2024	3	Combo Fountain	In classroom 314		WF-05092023-003464	11/10/2023	FT-FY24-10102023-003464-A	<1	FT-FY24-10102023-003464-B	<1
WS-003465	8/21/2023	8/21/2024	3	Combo Faucet	In classroom 314		WF-08212023-003465	11/10/2023	FT-FY24-10102023-003465-A	1.4	FT-FY24-10102023-003465-B	<1
WS-003466	5/9/2023	5/9/2024	3	Combo Fountain	In classroom 316		WF-05092023-003466	11/10/2023	FT-FY24-10102023-003466-A	<1	FT-FY24-10102023-003466-B	<1

WS- 003467	8/21/2023	8/21/2024	3	Combo Faucet	In classroom 316		WF-08212023-003467	11/10/2023	FT-FY24-10102023-003467-A	4.1	FT-FY24-10102023-003467-B	<1
WS- 003468	5/9/2023	5/9/2024	3	Combo Fountain	In classroom 331		WF-05092023-003468	11/10/2023	FT-FY24-10102023-003468-A	<1	FT-FY24-10102023-003468-B	<1
WS- 003470	5/9/2023	5/9/2024	3	Combo Fountain	In classroom 325		WF-05092023-003470	11/10/2023	FT-FY24-10102023-003470-A	<1	FT-FY24-10102023-003470-B	<1
WS- 003471	8/21/2023	8/21/2024	3	Combo Faucet	In classroom 325		WF-08212023-003471	11/10/2023	FT-FY24-10102023-003471-A	2.8	FT-FY24-10102023-003471-B	<1
WS- 003472	5/9/2023	5/9/2024	3	Cooler	In hallway adjacent to room 307	Low Right	WF-05092023-003472	11/10/2023	FT-FY24-10102023-003472-A	<1	FT-FY24-10102023-003472-B	<1
WS- 003473	5/9/2023	5/9/2024	3	Cooler	In hallway adjacent to room 307	High Left	WF-05092023-003473	11/10/2023	FT-FY24-10102023-003473-A	<1	FT-FY24-10102023-003473-B	<1
WS- 003474	8/21/2023	8/21/2024	3	Combo Faucet	In classroom 331		WF-08212023-003474	11/10/2023	FT-FY24-10102023-003474-A	1.3	FT-FY24-10102023-003474-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003392	1/3/2023	1/3/2024	1	Food Prep Sink	In kitchen on south wall	Left	WF-01032023-003392	11/10/2023	FT-FY24-10102023-003392-A	<1	FT-FY24-10102023-003392-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003430	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 235		WF-08212023-003430	11/10/2023	FT-FY24-10102023-003430-A	6.3	FT-FY24-10102023-003430-B	<1
WS- 003438	8/21/2023	8/21/2024	2	Combo Faucet	In classroom 216		WF-08212023-003438	11/10/2023	FT-FY24-10102023-003438-A	5.7	FT-FY24-10102023-003438-B	<1

First Re-test (After Plumbing Check)

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003438	11/15/2023	11/15/2024	2	Combo Faucet	In classroom 216		WF-11152023-003438	11/28/2023	FT-FY24-11152023-003438-A	3.3	FT-FY24-11152023-003438-B	<1

First Re-test (After Plumbing Check)

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003430	11/15/2023	11/15/2024	2	Combo Faucet	In classroom 235		WF-11152023-003430	11/28/2023	FT-FY24-11152023-003430-A	6.1	FT-FY24-11152023-003430-B	<1

Second Re-test (After Device Replacement)

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003430	11/30/2023	11/30/2024	2	Combo Faucet	In classroom 235		WF-11302023-003430	12/12/2023	FT-FY24-12012023-003430-A	1.3	FT-FY24-12012023-003430-B	<1