



Brightwood EC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003382	9/24/2019	9/24/2020	1	Bathroom	In classroom 142 in bathroom	WF-09242019-003382	12/30/2019	FT-FY20-122019-003382-A	<1	FT-FY20-122019-003382-B	<1	
WS- 003383	9/24/2019	9/24/2020	1	Bathroom	In classroom 143 in bathroom	WF-09242019-003383	12/30/2019	FT-FY20-122019-003383-A	<1	FT-FY20-122019-003383-B	<1	
WS- 003384	9/24/2019	9/24/2020	1	Bathroom	In classroom 146 in bathroom	WF-09242019-003384	12/30/2019	FT-FY20-122019-003384-A	<1	FT-FY20-122019-003384-B	<1	
WS- 003385	9/24/2019	9/24/2020	1	Bathroom	In classroom 147 in bathroom	WF-09242019-003385	12/30/2019	FT-FY20-122019-003385-A	<1	FT-FY20-122019-003385-B	<1	
WS- 003386	9/24/2019	9/24/2020	1	Bathroom	In classroom 125 in bathroom	WF-09242019-003386	12/30/2019	FT-FY20-122019-003386-A	<1	FT-FY20-122019-003386-B	<1	
WS- 003387	9/24/2019	9/24/2020	1	Bathroom	In classroom 130 in bathroom	WF-09242019-003387	12/30/2019	FT-FY20-122019-003387-A	<1	FT-FY20-122019-003387-B	<1	
WS- 003388	9/24/2019	9/24/2020	1	Bathroom	In classroom 136 in bathroom	WF-09242019-003388	12/30/2019	FT-FY20-122019-003388-A	<1	FT-FY20-122019-003388-B	<1	
WS- 003389	9/24/2019	9/24/2020	1	Bathroom	In classroom 137 in bathroom	WF-09242019-003389	12/30/2019	FT-FY20-122019-003389-A	<1	FT-FY20-122019-003389-B	<1	
WS- 003390	9/24/2019	9/24/2020	1	Bathroom	In classroom 138 in bathroom	WF-09242019-003390	12/30/2019	FT-FY20-122019-003390-A	<1	FT-FY20-122019-003390-B	<1	
WS- 003394	5/6/2019	5/6/2020	1	Cooler	In hallway adjacent to 106a	High Left	WF-05062019-003394	12/30/2019	FT-FY20-122019-003394-A	<1	FT-FY20-122019-003394-B	<1
WS- 003395	5/6/2019	5/6/2020	1	Cooler	In hallway adjacent to 106A	Low Right	WF-05062019-003395	12/30/2019	FT-FY20-122019-003395-A	<1	FT-FY20-122019-003395-B	<1
WS- 003396	5/6/2019	5/6/2020	1	Health Suite	In health suite in exam room 106D		WF-05062019-003396	12/30/2019	FT-FY20-122019-003396-A	<1	FT-FY20-122019-003396-B	<1
WS- 003399	5/6/2019	5/6/2020	1	Cooler	In hallway adjacent to room 123	Low Right	WF-05062019-003399	12/30/2019	FT-FY20-122019-003399-A	<1	FT-FY20-122019-003399-B	<1
WS- 003400	5/6/2019	5/6/2020	1	Cooler	In hallway adjacent to room 123	High Left	WF-05062019-003400	12/30/2019	FT-FY20-122019-003400-A	<1	FT-FY20-122019-003400-B	<1
WS- 003401	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 125		WF-05062019-003401	12/30/2019	FT-FY20-122019-003401-A	<1	FT-FY20-122019-003401-B	<1
WS- 003402	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 125		WF-09242019-003402	12/30/2019	FT-FY20-122019-003402-A	<1	FT-FY20-122019-003402-B	<1
WS- 003403	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 128		WF-05062019-003403	12/30/2019	FT-FY20-122019-003403-A	<1	FT-FY20-122019-003403-B	<1
WS- 003404	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 128		WF-09242019-003404	12/30/2019	FT-FY20-122019-003404-A	<1	FT-FY20-122019-003404-B	<1
WS- 003405	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 130		WF-05062019-003405	12/30/2019	FT-FY20-122019-003405-A	<1	FT-FY20-122019-003405-B	<1
WS- 003406	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 130		WF-09242019-003406	12/30/2019	FT-FY20-122019-003406-A	<1	FT-FY20-122019-003406-B	<1
WS- 003407	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 136		WF-05062019-003407	12/30/2019	FT-FY20-122019-003407-A	<1	FT-FY20-122019-003407-B	<1
WS- 003408	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 136		WF-09242019-003408	12/30/2019	FT-FY20-122019-003408-A	<1	FT-FY20-122019-003408-B	<1
WS- 003409	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 137		WF-05062019-003409	12/30/2019	FT-FY20-122019-003409-A	<1	FT-FY20-122019-003409-B	<1
WS- 003410	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 137		WF-09242019-003410	12/30/2019	FT-FY20-122019-003410-A	<1	FT-FY20-122019-003410-B	<1
WS- 003411	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 138		WF-05062019-003411	12/30/2019	FT-FY20-122019-003411-A	<1	FT-FY20-122019-003411-B	<1
WS- 003412	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 138		WF-09242019-003412	12/30/2019	FT-FY20-122019-003412-A	<1	FT-FY20-122019-003412-B	<1
WS- 003413	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 142		WF-05062019-003413	12/30/2019	FT-FY20-122019-003413-A	<1	FT-FY20-122019-003413-B	<1
WS- 003414	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 142		WF-09242019-003414	12/30/2019	FT-FY20-122019-003414-A	<1	FT-FY20-122019-003414-B	<1
WS- 003415	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 143		WF-05062019-003415	12/30/2019	FT-FY20-122019-003415-A	<1	FT-FY20-122019-003415-B	<1
WS- 003416	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 143		WF-09242019-003416	12/30/2019	FT-FY20-122019-003416-A	<1	FT-FY20-122019-003416-B	<1
WS- 003417	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 145		WF-05062019-003417	12/30/2019	FT-FY20-122019-003417-A	<1	FT-FY20-122019-003417-B	<1
WS- 003418	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 145		WF-09242019-003418	12/30/2019	FT-FY20-122019-003418-A	<1	FT-FY20-122019-003418-B	<1
WS- 003419	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 147		WF-05062019-003419	12/30/2019	FT-FY20-122019-003419-A	<1	FT-FY20-122019-003419-B	<1

WS- 003420	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 147		WF-09242019-003420	12/30/2019	FT-FY20-122019-003420-A	<1	FT-FY20-122019-003420-B	<1
WS- 003421	5/6/2019	5/6/2020	1	Combo Fountain	In classroom 146		WF-05062019-003421	12/30/2019	FT-FY20-122019-003421-A	<1	FT-FY20-122019-003421-B	<1
WS- 003422	9/24/2019	9/24/2020	1	Combo Faucet	In classroom 146		WF-09242019-003422	12/30/2019	FT-FY20-122019-003422-A	<1	FT-FY20-122019-003422-B	<1
WS- 003423	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 228		WF-05062019-003423	12/30/2019	FT-FY20-122019-003423-A	<1	FT-FY20-122019-003423-B	<1
WS- 003424	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 228		WF-09242019-003424	12/30/2019	FT-FY20-122019-003424-A	<1	FT-FY20-122019-003424-B	<1
WS- 003425	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 239		WF-05062019-003425	12/30/2019	FT-FY20-122019-003425-A	<1	FT-FY20-122019-003425-B	<1
WS- 003426	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 239		WF-09242019-003426	12/30/2019	FT-FY20-122019-003426-A	<1	FT-FY20-122019-003426-B	<1
WS- 003427	5/6/2019	5/6/2020	2	Combo Fountain	In staff workroom 237		WF-05062019-003427	12/30/2019	FT-FY20-122019-003427-A	<1	FT-FY20-122019-003427-B	<1
WS- 003428	5/6/2019	5/6/2020	2	Break Room	In staff workroom 237		WF-05062019-003428	12/30/2019	FT-FY20-122019-003428-A	<1	FT-FY20-122019-003428-B	<1
WS- 003429	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 235		WF-05062019-003429	12/30/2019	FT-FY20-122019-003429-A	3.6	FT-FY20-122019-003429-B	<1
WS- 003430	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 235		WF-09242019-003430	12/30/2019	FT-FY20-122019-003430-A	<1	FT-FY20-122019-003430-B	<1
WS- 003431	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 224		WF-05062019-003431	12/30/2019	FT-FY20-122019-003431-A	<1	FT-FY20-122019-003431-B	<1
WS- 003432	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 224		WF-09242019-003432	12/30/2019	FT-FY20-122019-003432-A	<1	FT-FY20-122019-003432-B	<1
WS- 003433	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 231		WF-05062019-003433	12/30/2019	FT-FY20-122019-003433-A	<1	FT-FY20-122019-003433-B	<1
WS- 003434	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 231		WF-09242019-003434	12/30/2019	FT-FY20-122019-003434-A	<1	FT-FY20-122019-003434-B	<1
WS- 003435	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 218		WF-05062019-003435	12/30/2019	FT-FY20-122019-003435-A	<1	FT-FY20-122019-003435-B	<1
WS- 003436	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 218		WF-09242019-003436	12/30/2019	FT-FY20-122019-003436-A	<1	FT-FY20-122019-003436-B	<1
WS- 003437	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 216		WF-05062019-003437	12/30/2019	FT-FY20-122019-003437-A	<1	FT-FY20-122019-003437-B	<1
WS- 003438	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 216		WF-09242019-003438	12/30/2019	FT-FY20-122019-003438-A	<1	FT-FY20-122019-003438-B	<1
WS- 003439	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 214		WF-05062019-003439	12/30/2019	FT-FY20-122019-003439-A	<1	FT-FY20-122019-003439-B	<1
WS- 003440	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 214		WF-09242019-003440	12/30/2019	FT-FY20-122019-003440-A	<1	FT-FY20-122019-003440-B	<1
WS- 003441	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 212		WF-05062019-003441	12/30/2019	FT-FY20-122019-003441-A	<1	FT-FY20-122019-003441-B	<1
WS- 003442	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 212		WF-09242019-003442	12/30/2019	FT-FY20-122019-003442-A	<1	FT-FY20-122019-003442-B	<1
WS- 003443	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 213		WF-05062019-003443	12/30/2019	FT-FY20-122019-003443-A	<1	FT-FY20-122019-003443-B	<1
WS- 003444	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 213		WF-09242019-003444	12/30/2019	FT-FY20-122019-003444-A	<1	FT-FY20-122019-003444-B	<1
WS- 003445	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 210		WF-05062019-003445	12/30/2019	FT-FY20-122019-003445-A	<1	FT-FY20-122019-003445-B	<1
WS- 003446	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 210		WF-09242019-003446	12/30/2019	FT-FY20-122019-003446-A	<1	FT-FY20-122019-003446-B	<1
WS- 003448	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 208 on south wall		WF-09242019-003448	12/30/2019	FT-FY20-122019-003448-A	<1	FT-FY20-122019-003448-B	<1
WS- 003449	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 208 on south wall		WF-05062019-003449	12/30/2019	FT-FY20-122019-003449-A	<1	FT-FY20-122019-003449-B	<1
WS- 003450	5/6/2019	5/6/2020	2	Combo Fountain	In classroom 206		WF-05062019-003450	12/30/2019	FT-FY20-122019-003450-A	<1	FT-FY20-122019-003450-B	<1
WS- 003452	9/24/2019	9/24/2020	2	Combo Faucet	In classroom 206		WF-09242019-003452	12/30/2019	FT-FY20-122019-003452-A	<1	FT-FY20-122019-003452-B	<1
WS- 003453	5/6/2019	5/6/2020	2	Cooler	In hallway adjacent to room 211	Low Right	WF-05062019-003453	12/30/2019	FT-FY20-122019-003453-A	<1	FT-FY20-122019-003453-B	<1
WS- 003454	5/6/2019	5/6/2020	2	Cooler	In hallway adjacent to room 211	High Left	WF-05062019-003454	12/30/2019	FT-FY20-122019-003454-A	<1	FT-FY20-122019-003454-B	<1
WS- 003456	5/6/2019	5/6/2020	3	Combo Fountain	In classroom 309		WF-05062019-003456	12/30/2019	FT-FY20-122019-003456-A	<1	FT-FY20-122019-003456-B	<1
WS- 003457	9/24/2019	9/24/2020	3	Combo Faucet	In classroom 309		WF-09242019-003457	12/30/2019	FT-FY20-122019-003457-A	<1	FT-FY20-122019-003457-B	<1
WS- 003458	5/6/2019	5/6/2020	3	Combo Fountain	In classroom 308		WF-05062019-003458	12/30/2019	FT-FY20-122019-003458-A	<1	FT-FY20-122019-003458-B	<1
WS- 003459	9/24/2019	9/24/2020	3	Combo Faucet	In classroom 308		WF-09242019-003459	12/30/2019	FT-FY20-122019-003459-A	<1	FT-FY20-122019-003459-B	<1
WS- 003460	5/6/2019	5/6/2020	3	Combo Fountain	In classroom 310		WF-05062019-003460	12/30/2019	FT-FY20-122019-003460-A	<1	FT-FY20-122019-003460-B	<1
WS- 003461	9/24/2019	9/24/2020	3	Combo Faucet	In classroom 310		WF-09242019-003461	12/30/2019	FT-FY20-122019-003461-A	<1	FT-FY20-122019-003461-B	<1

WS- 003462	5/6/2019	5/6/2020	3	Combo Fountain	In classroom 312		WF-05062019-003462	12/30/2019	FT-FY20-122019-003462-A	<1	FT-FY20-122019-003462-B	<1
WS- 003463	9/24/2019	9/24/2020	3	Combo Faucet	In classroom 312		WF-09242019-003463	12/30/2019	FT-FY20-122019-003463-A	<1	FT-FY20-122019-003463-B	<1
WS- 003464	5/6/2019	5/6/2020	3	Combo Fountain	In classroom 314		WF-05062019-003464	12/30/2019	FT-FY20-122019-003464-A	<1	FT-FY20-122019-003464-B	<1
WS- 003465	9/24/2019	9/24/2020	3	Combo Faucet	In classroom 314		WF-09242019-003465	12/30/2019	FT-FY20-122019-003465-A	<1	FT-FY20-122019-003465-B	<1
WS- 003466	5/6/2019	5/6/2020	3	Combo Fountain	In classroom 316		WF-05062019-003466	12/30/2019	FT-FY20-122019-003466-A	<1	FT-FY20-122019-003466-B	<1
WS- 003467	9/24/2019	9/24/2020	3	Combo Faucet	In classroom 316		WF-09242019-003467	12/30/2019	FT-FY20-122019-003467-A	2.8	FT-FY20-122019-003467-B	<1
WS- 003468	5/6/2019	5/6/2020	3	Combo Fountain	In classroom 331		WF-05062019-003468	12/30/2019	FT-FY20-122019-003468-A	<1	FT-FY20-122019-003468-B	<1
WS- 003470	5/6/2019	5/6/2020	3	Combo Fountain	In classroom 325		WF-05062019-003470	12/30/2019	FT-FY20-122019-003470-A	<1	FT-FY20-122019-003470-B	<1
WS- 003471	9/24/2019	9/24/2020	3	Combo Faucet	In classroom 325		WF-09242019-003471	12/30/2019	FT-FY20-122019-003471-A	<1	FT-FY20-122019-003471-B	<1
WS- 003472	5/6/2019	5/6/2020	3	Cooler	In hallway adjacent to room 307	Low Right	WF-05062019-003472	12/30/2019	FT-FY20-122019-003472-A	<1	FT-FY20-122019-003472-B	<1
WS- 003473	5/6/2019	5/6/2020	3	Cooler	In hallway adjacent to room 307	High Left	WF-05062019-003473	12/30/2019	FT-FY20-122019-003473-A	<1	FT-FY20-122019-003473-B	<1
WS- 003474	9/24/2019	9/24/2020	3	Combo Faucet	In classroom 331		WF-09242019-003474	12/30/2019	FT-FY20-122019-003474-A	<1	FT-FY20-122019-003474-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003392	7/2/2019	7/2/2020	1	Food Prep Sink	In kitchen on south wall	Left	WF-07022019-003392	12/30/2019	FT-FY20-122019-003392-A	<1	FT-FY20-122019-003392-B	<1