



Brightwood Education Campus Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003371	5/25/2021	5/25/2022	1	Bottle Filler	In hallway adjacent to 106A	WF-05252021-003371	12/15/2021	FT-FY22-12012021-003371-A	<1	FT-FY22-12012021-003371-B	<1
WS- 003372	5/25/2021	5/25/2022	1	Bottle Filler	In hallway adjacent to room 123	WF-05252021-003372	12/15/2021	FT-FY22-12012021-003372-A	<1	FT-FY22-12012021-003372-B	<1
WS- 003373	5/25/2021	5/25/2022	3	Bottle Filler	In hallway adjacent to room 307	WF-05252021-003373	12/15/2021	FT-FY22-12012021-003373-A	<1	FT-FY22-12012021-003373-B	<1
WS- 003374	5/25/2021	5/25/2022	2	Bottle Filler	In hallway adjacent to room 211	WF-05252021-003374	12/15/2021	FT-FY22-12012021-003374-A	<1	FT-FY22-12012021-003374-B	<1
WS- 003382	9/5/2021	9/5/2022	1	Bathroom	In classroom 142 in bathroom	WF-09052021-003382	12/15/2021	FT-FY22-12012021-003382-A	<1	FT-FY22-12012021-003382-B	<1
WS- 003383	9/5/2021	9/5/2022	1	Bathroom	In classroom 143 in bathroom	WF-09052021-003383	12/15/2021	FT-FY22-12012021-003383-A	<1	FT-FY22-12012021-003383-B	<1
WS- 003384	9/5/2021	9/5/2022	1	Bathroom	In classroom 146 in bathroom	WF-09052021-003384	12/15/2021	FT-FY22-12012021-003384-A	<1	FT-FY22-12012021-003384-B	<1
WS- 003385	9/5/2021	9/5/2022	1	Bathroom	In classroom 147 in bathroom	WF-09052021-003385	12/15/2021	FT-FY22-12012021-003385-A	<1	FT-FY22-12012021-003385-B	<1
WS- 003386	9/5/2021	9/5/2022	1	Bathroom	In classroom 125 in bathroom	WF-09052021-003386	12/15/2021	FT-FY22-12012021-003386-A	<1	FT-FY22-12012021-003386-B	<1
WS- 003387	9/5/2021	9/5/2022	1	Bathroom	In classroom 130 in bathroom	WF-09052021-003387	12/15/2021	FT-FY22-12012021-003387-A	<1	FT-FY22-12012021-003387-B	<1
WS- 003388	9/5/2021	9/5/2022	1	Bathroom	In classroom 136 in bathroom	WF-09052021-003388	12/15/2021	FT-FY22-12012021-003388-A	<1	FT-FY22-12012021-003388-B	<1
WS- 003389	9/5/2021	9/5/2022	1	Bathroom	In classroom 137 in bathroom	WF-09052021-003389	12/15/2021	FT-FY22-12012021-003389-A	<1	FT-FY22-12012021-003389-B	<1
WS- 003390	9/5/2021	9/5/2022	1	Bathroom	In classroom 138 in bathroom	WF-09052021-003390	12/15/2021	FT-FY22-12012021-003390-A	<1	FT-FY22-12012021-003390-B	<1
WS- 003394	5/25/2021	5/25/2022	1	Cooler	In hallway adjacent to 106a High Left	WF-05252021-003394	12/15/2021	FT-FY22-12012021-003394-A	<1	FT-FY22-12012021-003394-B	<1
WS- 003395	5/25/2021	5/25/2022	1	Cooler	In hallway adjacent to 106A Low Right	WF-05252021-003395	12/15/2021	FT-FY22-12012021-003395-A	<1	FT-FY22-12012021-003395-B	<1
WS- 003396	5/25/2021	5/25/2022	1	Health Suite	In health suite in exam room 106D	WF-05252021-003396	12/15/2021	FT-FY22-12012021-003396-A	<1	FT-FY22-12012021-003396-B	<1
WS- 003399	5/25/2021	5/25/2022	1	Cooler	In hallway adjacent to room 123 Low Right	WF-05252021-003399	12/15/2021	FT-FY22-12012021-003399-A	<1	FT-FY22-12012021-003399-B	<1
WS- 003400	5/25/2021	5/25/2022	1	Cooler	In hallway adjacent to room 123 High Left	WF-05252021-003400	12/15/2021	FT-FY22-12012021-003400-A	<1	FT-FY22-12012021-003400-B	<1
WS- 003401	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 125	WF-05252021-003401	12/15/2021	FT-FY22-12012021-003401-A	<1	FT-FY22-12012021-003401-B	<1
WS- 003402	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 125	WF-09052021-003402	12/15/2021	FT-FY22-12012021-003402-A	<1	FT-FY22-12012021-003402-B	<1
WS- 003403	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 128	WF-05252021-003403	12/15/2021	FT-FY22-12012021-003403-A	<1	FT-FY22-12012021-003403-B	<1
WS- 003404	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 128	WF-09052021-003404	12/15/2021	FT-FY22-12012021-003404-A	<1	FT-FY22-12012021-003404-B	<1
WS- 003405	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 130	WF-05252021-003405	12/15/2021	FT-FY22-12012021-003405-A	<1	FT-FY22-12012021-003405-B	<1
WS- 003406	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 130	WF-09052021-003406	12/15/2021	FT-FY22-12012021-003406-A	<1	FT-FY22-12012021-003406-B	<1
WS- 003407	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 136	WF-05252021-003407	12/15/2021	FT-FY22-12012021-003407-A	<1	FT-FY22-12012021-003407-B	<1
WS- 003408	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 136	WF-09052021-003408	12/15/2021	FT-FY22-12012021-003408-A	<1	FT-FY22-12012021-003408-B	<1
WS- 003409	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 137	WF-05252021-003409	12/15/2021	FT-FY22-12012021-003409-A	<1	FT-FY22-12012021-003409-B	<1
WS- 003410	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 137	WF-09052021-003410	12/15/2021	FT-FY22-12012021-003410-A	<1	FT-FY22-12012021-003410-B	<1
WS- 003411	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 138	WF-05252021-003411	12/15/2021	FT-FY22-12012021-003411-A	<1	FT-FY22-12012021-003411-B	<1
WS- 003412	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 138	WF-09052021-003412	12/15/2021	FT-FY22-12012021-003412-A	<1	FT-FY22-12012021-003412-B	<1
WS- 003413	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 142	WF-05252021-003413	12/15/2021	FT-FY22-12012021-003413-A	<1	FT-FY22-12012021-003413-B	<1
WS- 003414	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 142	WF-09052021-003414	12/15/2021	FT-FY22-12012021-003414-A	<1	FT-FY22-12012021-003414-B	<1
WS- 003415	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 143	WF-05252021-003415	12/15/2021	FT-FY22-12012021-003415-A	<1	FT-FY22-12012021-003415-B	<1
WS- 003416	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 143	WF-09052021-003416	12/15/2021	FT-FY22-12012021-003416-A	<1	FT-FY22-12012021-003416-B	<1
WS- 003417	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 145	WF-05252021-003417	12/15/2021	FT-FY22-12012021-003417-A	<1	FT-FY22-12012021-003417-B	<1

WS-003418	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 145			WF-09052021-003418	12/15/2021	FT-FY22-12012021-003418-A	<1	FT-FY22-12012021-003418-B	<1
WS-003419	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 147			WF-05252021-003419	12/15/2021	FT-FY22-12012021-003419-A	<1	FT-FY22-12012021-003419-B	<1
WS-003420	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 147			WF-09052021-003420	12/15/2021	FT-FY22-12012021-003420-A	<1	FT-FY22-12012021-003420-B	<1
WS-003421	5/25/2021	5/25/2022	1	Combo Fountain	In classroom 146			WF-05252021-003421	12/15/2021	FT-FY22-12012021-003421-A	<1	FT-FY22-12012021-003421-B	<1
WS-003422	9/5/2021	9/5/2022	1	Combo Faucet	In classroom 146			WF-09052021-003422	12/15/2021	FT-FY22-12012021-003422-A	<1	FT-FY22-12012021-003422-B	<1
WS-003423	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 228			WF-05252021-003423	12/15/2021	FT-FY22-12012021-003423-A	<1	FT-FY22-12012021-003423-B	<1
WS-003424	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 228			WF-09052021-003424	12/15/2021	FT-FY22-12012021-003424-A	<1	FT-FY22-12012021-003424-B	<1
WS-003425	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 239			WF-05252021-003425	12/15/2021	FT-FY22-12012021-003425-A	<1	FT-FY22-12012021-003425-B	<1
WS-003426	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 239			WF-09052021-003426	12/15/2021	FT-FY22-12012021-003426-A	<1	FT-FY22-12012021-003426-B	<1
WS-003427	5/25/2021	5/25/2022	2	Combo Fountain	In staff workroom 237			WF-05252021-003427	12/15/2021	FT-FY22-12012021-003427-A	<1	FT-FY22-12012021-003427-B	<1
WS-003428	5/25/2021	5/25/2022	2	Break Room	In staff workroom 237			WF-05252021-003428	12/15/2021	FT-FY22-12012021-003428-A	<1	FT-FY22-12012021-003428-B	<1
WS-003429	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 235			WF-05252021-003429	12/15/2021	FT-FY22-12012021-003429-A	<1	FT-FY22-12012021-003429-B	<1
WS-003430	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 235			WF-09052021-003430	12/15/2021	FT-FY22-12012021-003430-A	<1	FT-FY22-12012021-003430-B	<1
WS-003431	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 224			WF-05252021-003431	12/15/2021	FT-FY22-12012021-003431-A	<1	FT-FY22-12012021-003431-B	<1
WS-003432	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 224			WF-09052021-003432	12/15/2021	FT-FY22-12012021-003432-A	<1	FT-FY22-12012021-003432-B	<1
WS-003433	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 231			WF-05252021-003433	12/15/2021	FT-FY22-12012021-003433-A	<1	FT-FY22-12012021-003433-B	<1
WS-003434	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 231			WF-09052021-003434	12/15/2021	FT-FY22-12012021-003434-A	<1	FT-FY22-12012021-003434-B	<1
WS-003435	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 218			WF-05252021-003435	12/15/2021	FT-FY22-12012021-003435-A	<1	FT-FY22-12012021-003435-B	<1
WS-003436	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 218			WF-09052021-003436	12/15/2021	FT-FY22-12012021-003436-A	<1	FT-FY22-12012021-003436-B	<1
WS-003437	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 216			WF-05252021-003437	12/15/2021	FT-FY22-12012021-003437-A	<1	FT-FY22-12012021-003437-B	<1
WS-003438	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 216			WF-09052021-003438	12/15/2021	FT-FY22-12012021-003438-A	<1	FT-FY22-12012021-003438-B	<1
WS-003439	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 214			WF-05252021-003439	12/15/2021	FT-FY22-12012021-003439-A	<1	FT-FY22-12012021-003439-B	<1
WS-003440	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 214			WF-09052021-003440	12/15/2021	FT-FY22-12012021-003440-A	<1	FT-FY22-12012021-003440-B	<1
WS-003441	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 212			WF-05252021-003441	12/15/2021	FT-FY22-12012021-003441-A	<1	FT-FY22-12012021-003441-B	<1
WS-003442	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 212			WF-09052021-003442	12/15/2021	FT-FY22-12012021-003442-A	<1	FT-FY22-12012021-003442-B	<1
WS-003443	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 213			WF-05252021-003443	12/15/2021	FT-FY22-12012021-003443-A	<1	FT-FY22-12012021-003443-B	<1
WS-003444	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 213			WF-09052021-003444	12/15/2021	FT-FY22-12012021-003444-A	<1	FT-FY22-12012021-003444-B	<1
WS-003445	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 210			WF-05252021-003445	12/15/2021	FT-FY22-12012021-003445-A	<1	FT-FY22-12012021-003445-B	<1
WS-003446	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 210			WF-09052021-003446	12/15/2021	FT-FY22-12012021-003446-A	<1	FT-FY22-12012021-003446-B	<1
WS-003448	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 208 on south wall			WF-09052021-003448	12/15/2021	FT-FY22-12012021-003448-A	<1	FT-FY22-12012021-003448-B	<1
WS-003449	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 208 on south wall			WF-05252021-003449	12/15/2021	FT-FY22-12012021-003449-A	<1	FT-FY22-12012021-003449-B	<1
WS-003450	5/25/2021	5/25/2022	2	Combo Fountain	In classroom 206			WF-05252021-003450	12/15/2021	FT-FY22-12012021-003450-A	<1	FT-FY22-12012021-003450-B	<1
WS-003452	9/5/2021	9/5/2022	2	Combo Faucet	In classroom 206			WF-09052021-003452	12/15/2021	FT-FY22-12012021-003452-A	<1	FT-FY22-12012021-003452-B	<1
WS-003453	5/25/2021	5/25/2022	2	Cooler	In hallway adjacent to room 211	Low	Right	WF-05252021-003453	12/15/2021	FT-FY22-12012021-003453-A	<1	FT-FY22-12012021-003453-B	<1
WS-003454	5/25/2021	5/25/2022	2	Cooler	In hallway adjacent to room 211	High	Left	WF-05252021-003454	12/15/2021	FT-FY22-12012021-003454-A	<1	FT-FY22-12012021-003454-B	<1
WS-003456	5/25/2021	5/25/2022	3	Combo Fountain	In classroom 309			WF-05252021-003456	12/15/2021	FT-FY22-12012021-003456-A	<1	FT-FY22-12012021-003456-B	<1
WS-003457	9/5/2021	9/5/2022	3	Combo Faucet	In classroom 309			WF-09052021-003457	12/15/2021	FT-FY22-12012021-003457-A	<1	FT-FY22-12012021-003457-B	<1
WS-003458	5/25/2021	5/25/2022	3	Combo Fountain	In classroom 308			WF-05252021-003458	12/15/2021	FT-FY22-12012021-003458-A	<1	FT-FY22-12012021-003458-B	<1
WS-003459	9/5/2021	9/5/2022	3	Combo Faucet	In classroom 308			WF-09052021-003459	12/15/2021	FT-FY22-12012021-003459-A	<1	FT-FY22-12012021-003459-B	<1
WS-003460	5/25/2021	5/25/2022	3	Combo Fountain	In classroom 310			WF-05252021-003460	12/15/2021	FT-FY22-12012021-003460-A	<1	FT-FY22-12012021-003460-B	<1
WS-003461	9/5/2021	9/5/2022	3	Combo Faucet	In classroom 310			WF-09052021-003461	12/15/2021	FT-FY22-12012021-003461-A	<1	FT-FY22-12012021-003461-B	<1

WS- 003462	5/25/2021	5/25/2022	3	Combo Fountain	In classroom 312		WF-05252021-003462	12/15/2021	FT-FY22-12012021-003462-A	<1	FT-FY22-12012021-003462-B	<1
WS- 003463	9/5/2021	9/5/2022	3	Combo Faucet	In classroom 312		WF-09052021-003463	12/15/2021	FT-FY22-12012021-003463-A	<1	FT-FY22-12012021-003463-B	<1
WS- 003464	5/25/2021	5/25/2022	3	Combo Fountain	In classroom 314		WF-05252021-003464	12/15/2021	FT-FY22-12012021-003464-A	<1	FT-FY22-12012021-003464-B	<1
WS- 003465	9/5/2021	9/5/2022	3	Combo Faucet	In classroom 314		WF-09052021-003465	12/15/2021	FT-FY22-12012021-003465-A	<1	FT-FY22-12012021-003465-B	<1
WS- 003466	5/25/2021	5/25/2022	3	Combo Fountain	In classroom 316		WF-05252021-003466	12/15/2021	FT-FY22-12012021-003466-A	<1	FT-FY22-12012021-003466-B	<1
WS- 003467	9/5/2021	9/5/2022	3	Combo Faucet	In classroom 316		WF-09052021-003467	12/15/2021	FT-FY22-12012021-003467-A	<1	FT-FY22-12012021-003467-B	<1
WS- 003468	5/25/2021	5/25/2022	3	Combo Fountain	In classroom 331		WF-05252021-003468	12/15/2021	FT-FY22-12012021-003468-A	<1	FT-FY22-12012021-003468-B	<1
WS- 003470	5/25/2021	5/25/2022	3	Combo Fountain	In classroom 325		WF-05252021-003470	12/15/2021	FT-FY22-12012021-003470-A	<1	FT-FY22-12012021-003470-B	<1
WS- 003471	9/5/2021	9/5/2022	3	Combo Faucet	In classroom 325		WF-09052021-003471	12/15/2021	FT-FY22-12012021-003471-A	<1	FT-FY22-12012021-003471-B	<1
WS- 003472	5/25/2021	5/25/2022	3	Cooler	In hallway adjacent to room 307	Low Right	WF-05252021-003472	12/15/2021	FT-FY22-12012021-003472-A	<1	FT-FY22-12012021-003472-B	<1
WS- 003473	5/25/2021	5/25/2022	3	Cooler	In hallway adjacent to room 307	High Left	WF-05252021-003473	12/15/2021	FT-FY22-12012021-003473-A	<1	FT-FY22-12012021-003473-B	<1
WS- 003474	9/5/2021	9/5/2022	3	Combo Faucet	In classroom 331		WF-09052021-003474	12/15/2021	FT-FY22-12012021-003474-A	<1	FT-FY22-12012021-003474-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003392	2/3/2021	2/3/2022	1	Food Prep Sink	In kitchen on south wall	Left	WF-02032021-003392	12/15/2021	FT-FY22-12012021-003392-A	<1	FT-FY22-12012021-003392-B	<1