



Brightwood Education Campus Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003371	5/18/2022	5/18/2023	1	Bottle Filler	In hallway adjacent to 106A	WF-05182022-003371	1/9/2023	FT-FY23-11182022-003371-A	<1	FT-FY23-11182022-003371-B	<1
WS- 003372	5/18/2022	5/18/2023	1	Bottle Filler	In hallway adjacent to room 123	WF-05182022-003372	1/9/2023	FT-FY23-11182022-003372-A	<1	FT-FY23-11182022-003372-B	<1
WS- 003374	5/18/2022	5/18/2023	2	Bottle Filler	In hallway adjacent to room 211	WF-05182022-003374	1/9/2023	FT-FY23-11182022-003374-A	<1	FT-FY23-11182022-003374-B	<1
WS- 003382	8/31/2022	8/31/2023	1	Bathroom	In classroom 142 in bathroom	WF-08312022-003382	1/9/2023	FT-FY23-11182022-003382-A	<1	FT-FY23-11182022-003382-B	<1
WS- 003383	8/31/2022	8/31/2023	1	Bathroom	In classroom 143 in bathroom	WF-08312022-003383	1/9/2023	FT-FY23-11182022-003383-A	<1	FT-FY23-11182022-003383-B	<1
WS- 003384	8/31/2022	8/31/2023	1	Bathroom	In classroom 146 in bathroom	WF-08312022-003384	1/9/2023	FT-FY23-11182022-003384-A	<1	FT-FY23-11182022-003384-B	<1
WS- 003385	8/31/2022	8/31/2023	1	Bathroom	In classroom 147 in bathroom	WF-08312022-003385	1/9/2023	FT-FY23-11182022-003385-A	<1	FT-FY23-11182022-003385-B	<1
WS- 003386	8/31/2022	8/31/2023	1	Bathroom	In classroom 125 in bathroom	WF-08312022-003386	1/9/2023	FT-FY23-11182022-003386-A	<1	FT-FY23-11182022-003386-B	<1
WS- 003387	8/31/2022	8/31/2023	1	Bathroom	In classroom 130 in bathroom	WF-08312022-003387	1/9/2023	FT-FY23-11182022-003387-A	<1	FT-FY23-11182022-003387-B	<1
WS- 003388	8/31/2022	8/31/2023	1	Bathroom	In classroom 136 in bathroom	WF-08312022-003388	1/9/2023	FT-FY23-11182022-003388-A	<1	FT-FY23-11182022-003388-B	<1
WS- 003389	8/31/2022	8/31/2023	1	Bathroom	In classroom 137 in bathroom	WF-08312022-003389	1/9/2023	FT-FY23-11182022-003389-A	<1	FT-FY23-11182022-003389-B	<1
WS- 003390	8/31/2022	8/31/2023	1	Bathroom	In classroom 138 in bathroom	WF-08312022-003390	1/9/2023	FT-FY23-11182022-003390-A	<1	FT-FY23-11182022-003390-B	<1
WS- 003394	5/18/2022	5/18/2023	1	Cooler	In hallway adjacent to 106a High Left	WF-05182022-003394	1/9/2023	FT-FY23-11182022-003394-A	<1	FT-FY23-11182022-003394-B	<1
WS- 003395	5/18/2022	5/18/2023	1	Cooler	In hallway adjacent to 106A Low Right	WF-05182022-003395	1/9/2023	FT-FY23-11182022-003395-A	<1	FT-FY23-11182022-003395-B	<1
WS- 003396	5/18/2022	5/18/2023	1	Health Suite	In health suite in exam room 106D	WF-05182022-003396	1/9/2023	FT-FY23-11182022-003396-A	<1	FT-FY23-11182022-003396-B	<1
WS- 003399	5/18/2022	5/18/2023	1	Cooler	In hallway adjacent to room 123 Low Right	WF-05182022-003399	1/9/2023	FT-FY23-11182022-003399-A	<1	FT-FY23-11182022-003399-B	<1
WS- 003400	5/18/2022	5/18/2023	1	Cooler	In hallway adjacent to room 123 High Left	WF-05182022-003400	1/9/2023	FT-FY23-11182022-003400-A	<1	FT-FY23-11182022-003400-B	<1
WS- 003401	5/18/2022	5/18/2023	1	Combo Fountain	In classroom 125	WF-05182022-003401	1/9/2023	FT-FY23-11182022-003401-A	<1	FT-FY23-11182022-003401-B	<1
WS- 003402	8/31/2022	8/31/2023	1	Combo Faucet	In classroom 125	WF-08312022-003402	1/9/2023	FT-FY23-11182022-003402-A	<1	FT-FY23-11182022-003402-B	<1
WS- 003403	5/18/2022	5/18/2023	1	Combo Fountain	In classroom 128	WF-05182022-003403	1/9/2023	FT-FY23-11182022-003403-A	<1	FT-FY23-11182022-003403-B	<1
WS- 003404	8/31/2022	8/31/2023	1	Combo Faucet	In classroom 128	WF-08312022-003404	1/9/2023	FT-FY23-11182022-003404-A	<1	FT-FY23-11182022-003404-B	<1
WS- 003405	5/18/2022	5/18/2023	1	Combo Fountain	In classroom 130	WF-05182022-003405	1/9/2023	FT-FY23-11182022-003405-A	<1	FT-FY23-11182022-003405-B	<1
WS- 003406	8/31/2022	8/31/2023	1	Combo Faucet	In classroom 130	WF-08312022-003406	1/9/2023	FT-FY23-11182022-003406-A	<1	FT-FY23-11182022-003406-B	<1
WS- 003407	5/18/2022	5/18/2023	1	Combo Fountain	In classroom 136	WF-05182022-003407	1/9/2023	FT-FY23-11182022-003407-A	<1	FT-FY23-11182022-003407-B	<1
WS- 003408	8/31/2022	8/31/2023	1	Combo Faucet	In classroom 136	WF-08312022-003408	1/9/2023	FT-FY23-11182022-003408-A	<1	FT-FY23-11182022-003408-B	<1
WS- 003411	5/18/2022	5/18/2023	1	Combo Fountain	In classroom 138	WF-05182022-003411	1/9/2023	FT-FY23-11182022-003411-A	<1	FT-FY23-11182022-003411-B	<1
WS- 003412	8/31/2022	8/31/2023	1	Combo Faucet	In classroom 138	WF-08312022-003412	1/9/2023	FT-FY23-11182022-003412-A	<1	FT-FY23-11182022-003412-B	<1
WS- 003413	5/18/2022	5/18/2023	1	Combo Fountain	In classroom 142	WF-05182022-003413	1/9/2023	FT-FY23-11182022-003413-A	<1	FT-FY23-11182022-003413-B	<1
WS- 003415	5/18/2022	5/18/2023	1	Combo Fountain	In classroom 143	WF-05182022-003415	1/9/2023	FT-FY23-11182022-003415-A	<1	FT-FY23-11182022-003415-B	<1
WS- 003416	8/31/2022	8/31/2023	1	Combo Faucet	In classroom 143	WF-08312022-003416	1/9/2023	FT-FY23-11182022-003416-A	<1	FT-FY23-11182022-003416-B	<1
WS- 003419	5/18/2022	5/18/2023	1	Combo Fountain	In classroom 147	WF-05182022-003419	1/9/2023	FT-FY23-11182022-003419-A	<1	FT-FY23-11182022-003419-B	<1
WS- 003420	8/31/2022	8/31/2023	1	Combo Faucet	In classroom 147	WF-08312022-003420	1/9/2023	FT-FY23-11182022-003420-A	<1	FT-FY23-11182022-003420-B	<1
WS- 003421	5/18/2022	5/18/2023	1	Combo Fountain	In classroom 146	WF-05182022-003421	1/9/2023	FT-FY23-11182022-003421-A	<1	FT-FY23-11182022-003421-B	<1
WS- 003422	8/31/2022	8/31/2023	1	Combo Faucet	In classroom 146	WF-08312022-003422	1/9/2023	FT-FY23-11182022-003422-A	<1	FT-FY23-11182022-003422-B	<1
WS- 003423	5/18/2022	5/18/2023	2	Combo Fountain	In classroom 228	WF-05182022-003423	1/9/2023	FT-FY23-11182022-003423-A	<1	FT-FY23-11182022-003423-B	<1

WS-003424	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 228		WF-08312022-003424	1/9/2023	FT-FY23-11182022-003424-A	<1	FT-FY23-11182022-003424-B	<1
WS-003427	5/18/2022	5/18/2023	2	Combo Fountain	In staff workroom 237		WF-05182022-003427	1/9/2023	FT-FY23-11182022-003427-A	<1	FT-FY23-11182022-003427-B	<1
WS-003428	5/18/2022	5/18/2023	2	Break Room	In staff workroom 237		WF-05182022-003428	1/9/2023	FT-FY23-11182022-003428-A	<1	FT-FY23-11182022-003428-B	<1
WS-003429	5/18/2022	5/18/2023	2	Combo Fountain	In classroom 235		WF-05182022-003429	1/9/2023	FT-FY23-11182022-003429-A	<1	FT-FY23-11182022-003429-B	<1
WS-003430	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 235		WF-08312022-003430	1/9/2023	FT-FY23-11182022-003430-A	<1	FT-FY23-11182022-003430-B	<1
WS-003431	5/18/2022	5/18/2023	2	Combo Fountain	In classroom 224		WF-05182022-003431	1/9/2023	FT-FY23-11182022-003431-A	<1	FT-FY23-11182022-003431-B	<1
WS-003432	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 224		WF-08312022-003432	1/9/2023	FT-FY23-11182022-003432-A	<1	FT-FY23-11182022-003432-B	<1
WS-003433	5/18/2022	5/18/2023	2	Combo Fountain	In classroom 231		WF-05182022-003433	1/9/2023	FT-FY23-11182022-003433-A	<1	FT-FY23-11182022-003433-B	<1
WS-003434	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 231		WF-08312022-003434	1/9/2023	FT-FY23-11182022-003434-A	<1	FT-FY23-11182022-003434-B	<1
WS-003435	5/18/2022	5/18/2023	2	Combo Fountain	In classroom 218		WF-05182022-003435	1/9/2023	FT-FY23-11182022-003435-A	<1	FT-FY23-11182022-003435-B	<1
WS-003436	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 218		WF-08312022-003436	1/9/2023	FT-FY23-11182022-003436-A	<1	FT-FY23-11182022-003436-B	<1
WS-003438	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 216		WF-08312022-003438	1/9/2023	FT-FY23-11182022-003438-A	<1	FT-FY23-11182022-003438-B	<1
WS-003439	5/18/2022	5/18/2023	2	Combo Fountain	In classroom 214		WF-05182022-003439	1/9/2023	FT-FY23-11182022-003439-A	<1	FT-FY23-11182022-003439-B	<1
WS-003440	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 214		WF-08312022-003440	1/9/2023	FT-FY23-11182022-003440-A	<1	FT-FY23-11182022-003440-B	<1
WS-003441	5/18/2022	5/18/2023	2	Combo Fountain	In classroom 212		WF-05182022-003441	1/9/2023	FT-FY23-11182022-003441-A	<1	FT-FY23-11182022-003441-B	<1
WS-003442	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 212		WF-08312022-003442	1/9/2023	FT-FY23-11182022-003442-A	<1	FT-FY23-11182022-003442-B	<1
WS-003444	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 213		WF-08312022-003444	1/9/2023	FT-FY23-11182022-003444-A	<1	FT-FY23-11182022-003444-B	<1
WS-003448	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 208 on south wall		WF-08312022-003448	1/9/2023	FT-FY23-11182022-003448-A	<1	FT-FY23-11182022-003448-B	<1
WS-003449	5/18/2022	5/18/2023	2	Combo Fountain	In classroom 208 on south wall		WF-05182022-003449	1/9/2023	FT-FY23-11182022-003449-A	<1	FT-FY23-11182022-003449-B	<1
WS-003450	5/18/2022	5/18/2023	2	Combo Fountain	In classroom 206		WF-05182022-003450	1/9/2023	FT-FY23-11182022-003450-A	<1	FT-FY23-11182022-003450-B	<1
WS-003452	8/31/2022	8/31/2023	2	Combo Faucet	In classroom 206		WF-08312022-003452	1/9/2023	FT-FY23-11182022-003452-A	<1	FT-FY23-11182022-003452-B	<1
WS-003453	5/18/2022	5/18/2023	2	Cooler	In hallway adjacent to room 211	Low Right	WF-05182022-003453	1/9/2023	FT-FY23-11182022-003453-A	<1	FT-FY23-11182022-003453-B	<1
WS-003456	5/18/2022	5/18/2023	3	Combo Fountain	In classroom 309		WF-05182022-003456	1/9/2023	FT-FY23-11182022-003456-A	<1	FT-FY23-11182022-003456-B	<1
WS-003457	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 309		WF-08312022-003457	1/9/2023	FT-FY23-11182022-003457-A	<1	FT-FY23-11182022-003457-B	<1
WS-003458	5/18/2022	5/18/2023	3	Combo Fountain	In classroom 308		WF-05182022-003458	1/9/2023	FT-FY23-11182022-003458-A	<1	FT-FY23-11182022-003458-B	<1
WS-003459	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 308		WF-08312022-003459	1/9/2023	FT-FY23-11182022-003459-A	<1	FT-FY23-11182022-003459-B	<1
WS-003460	5/18/2022	5/18/2023	3	Combo Fountain	In classroom 310		WF-05182022-003460	1/9/2023	FT-FY23-11182022-003460-A	<1	FT-FY23-11182022-003460-B	<1
WS-003461	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 310		WF-08312022-003461	1/9/2023	FT-FY23-11182022-003461-A	<1	FT-FY23-11182022-003461-B	<1
WS-003462	5/18/2022	5/18/2023	3	Combo Fountain	In classroom 312		WF-05182022-003462	1/9/2023	FT-FY23-11182022-003462-A	<1	FT-FY23-11182022-003462-B	<1
WS-003463	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 312		WF-08312022-003463	1/9/2023	FT-FY23-11182022-003463-A	<1	FT-FY23-11182022-003463-B	<1
WS-003465	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 314		WF-08312022-003465	1/9/2023	FT-FY23-11182022-003465-A	<1	FT-FY23-11182022-003465-B	<1
WS-003467	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 316		WF-08312022-003467	1/9/2023	FT-FY23-11182022-003467-A	<1	FT-FY23-11182022-003467-B	<1
WS-003470	5/18/2022	5/18/2023	3	Combo Fountain	In classroom 325		WF-05182022-003470	1/9/2023	FT-FY23-11182022-003470-A	<1	FT-FY23-11182022-003470-B	<1
WS-003471	8/31/2022	8/31/2023	3	Combo Faucet	In classroom 325		WF-08312022-003471	1/9/2023	FT-FY23-11182022-003471-A	<1	FT-FY23-11182022-003471-B	<1
WS-003473	5/18/2022	5/18/2023	3	Cooler	In hallway adjacent to room 307	High Left	WF-05182022-003473	1/9/2023	FT-FY23-11182022-003473-A	<1	FT-FY23-11182022-003473-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003392	1/25/2022	1/25/2023	1	Food Prep Sink	In kitchen on south wall	Left	WF-01252022-003392	1/9/2023	FT-FY23-11182022-003392-A	<1	FT-FY23-11182022-003392-B	<1