



Brightwood Education Campus Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003371	10/12/2020	10/12/2021	1	Bottle Filler	In hallway adjacent to 106A	WF-10122020-003371	3/18/2021	FT-FY21-032021-003371-A	<1	FT-FY21-032021-003371-B	<1
WS-003372	10/12/2020	10/12/2021	1	Bottle Filler	In hallway adjacent to room 123	WF-10122020-003372	3/18/2021	FT-FY21-032021-003372-A	<1	FT-FY21-032021-003372-B	<1
WS-003373	10/12/2020	10/12/2021	3	Bottle Filler	In hallway adjacent to room 307	WF-10122020-003373	3/18/2021	FT-FY21-032021-003373-A	<1	FT-FY21-032021-003373-B	<1
WS-003374	10/12/2020	10/12/2021	2	Bottle Filler	In hallway adjacent to room 211	WF-10122020-003374	3/18/2021	FT-FY21-032021-003374-A	<1	FT-FY21-032021-003374-B	<1
WS-003382	9/15/2020	9/15/2021	1	Bathroom	In classroom 142 in bathroom	WF-09152020-003382	3/18/2021	FT-FY21-032021-003382-A	<1	FT-FY21-032021-003382-B	<1
WS-003383	9/15/2020	9/15/2021	1	Bathroom	In classroom 143 in bathroom	WF-09152020-003383	3/18/2021	FT-FY21-032021-003383-A	<1	FT-FY21-032021-003383-B	<1
WS-003384	9/15/2020	9/15/2021	1	Bathroom	In classroom 146 in bathroom	WF-09152020-003384	3/18/2021	FT-FY21-032021-003384-A	<1	FT-FY21-032021-003384-B	<1
WS-003385	9/15/2020	9/15/2021	1	Bathroom	In classroom 147 in bathroom	WF-09152020-003385	3/18/2021	FT-FY21-032021-003385-A	<1	FT-FY21-032021-003385-B	<1
WS-003386	9/15/2020	9/15/2021	1	Bathroom	In classroom 125 in bathroom	WF-09152020-003386	3/18/2021	FT-FY21-032021-003386-A	<1	FT-FY21-032021-003386-B	<1
WS-003387	9/15/2020	9/15/2021	1	Bathroom	In classroom 130 in bathroom	WF-09152020-003387	3/18/2021	FT-FY21-032021-003387-A	<1	FT-FY21-032021-003387-B	<1
WS-003388	9/15/2020	9/15/2021	1	Bathroom	In classroom 136 in bathroom	WF-09152020-003388	3/18/2021	FT-FY21-032021-003388-A	<1	FT-FY21-032021-003388-B	<1
WS-003389	9/15/2020	9/15/2021	1	Bathroom	In classroom 137 in bathroom	WF-09152020-003389	3/18/2021	FT-FY21-032021-003389-A	<1	FT-FY21-032021-003389-B	<1
WS-003390	9/15/2020	9/15/2021	1	Bathroom	In classroom 138 in bathroom	WF-09152020-003390	3/18/2021	FT-FY21-032021-003390-A	<1	FT-FY21-032021-003390-B	<1
WS-003396	6/24/2020	6/24/2021	1	Health Suite	In health suite in exam room 106D	WF-06242020-003396	3/18/2021	FT-FY21-032021-003396-A	<1	FT-FY21-032021-003396-B	<1
WS-003401	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 125	WF-06242020-003401	3/18/2021	FT-FY21-032021-003401-A	<1	FT-FY21-032021-003401-B	<1
WS-003402	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 125	WF-09152020-003402	3/18/2021	FT-FY21-032021-003402-A	<1	FT-FY21-032021-003402-B	<1
WS-003403	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 128	WF-06242020-003403	3/18/2021	FT-FY21-032021-003403-A	<1	FT-FY21-032021-003403-B	<1
WS-003404	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 128	WF-09152020-003404	3/18/2021	FT-FY21-032021-003404-A	<1	FT-FY21-032021-003404-B	<1
WS-003405	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 130	WF-06242020-003405	3/18/2021	FT-FY21-032021-003405-A	<1	FT-FY21-032021-003405-B	<1
WS-003406	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 130	WF-09152020-003406	3/18/2021	FT-FY21-032021-003406-A	<1	FT-FY21-032021-003406-B	<1
WS-003407	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 136	WF-06242020-003407	3/18/2021	FT-FY21-032021-003407-A	<1	FT-FY21-032021-003407-B	<1
WS-003408	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 136	WF-09152020-003408	3/18/2021	FT-FY21-032021-003408-A	<1	FT-FY21-032021-003408-B	<1
WS-003409	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 137	WF-06242020-003409	3/18/2021	FT-FY21-032021-003409-A	<1	FT-FY21-032021-003409-B	<1
WS-003410	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 137	WF-09152020-003410	3/18/2021	FT-FY21-032021-003410-A	<1	FT-FY21-032021-003410-B	<1
WS-003411	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 138	WF-06242020-003411	3/18/2021	FT-FY21-032021-003411-A	<1	FT-FY21-032021-003411-B	<1
WS-003412	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 138	WF-09152020-003412	3/18/2021	FT-FY21-032021-003412-A	<1	FT-FY21-032021-003412-B	<1
WS-003413	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 142	WF-06242020-003413	3/18/2021	FT-FY21-032021-003413-A	<1	FT-FY21-032021-003413-B	<1
WS-003414	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 142	WF-09152020-003414	3/18/2021	FT-FY21-032021-003414-A	<1	FT-FY21-032021-003414-B	<1
WS-003415	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 143	WF-06242020-003415	3/18/2021	FT-FY21-032021-003415-A	<1	FT-FY21-032021-003415-B	<1
WS-003416	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 143	WF-09152020-003416	3/18/2021	FT-FY21-032021-003416-A	<1	FT-FY21-032021-003416-B	<1
WS-003417	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 145	WF-06242020-003417	3/18/2021	FT-FY21-032021-003417-A	<1	FT-FY21-032021-003417-B	<1
WS-003418	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 145	WF-09152020-003418	3/18/2021	FT-FY21-032021-003418-A	<1	FT-FY21-032021-003418-B	<1

WS- 003419	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 147	WF-06242020-003419	3/18/2021	FT-FY21-032021-003419-A	<1	FT-FY21-032021-003419-B	<1
WS- 003420	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 147	WF-09152020-003420	3/18/2021	FT-FY21-032021-003420-A	<1	FT-FY21-032021-003420-B	<1
WS- 003421	6/24/2020	6/24/2021	1	Combo Fountain	In classroom 146	WF-06242020-003421	3/18/2021	FT-FY21-032021-003421-A	<1	FT-FY21-032021-003421-B	<1
WS- 003422	9/15/2020	9/15/2021	1	Combo Faucet	In classroom 146	WF-09152020-003422	3/18/2021	FT-FY21-032021-003422-A	<1	FT-FY21-032021-003422-B	<1
WS- 003423	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 228	WF-06242020-003423	3/18/2021	FT-FY21-032021-003423-A	<1	FT-FY21-032021-003423-B	<1
WS- 003424	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 228	WF-09152020-003424	3/18/2021	FT-FY21-032021-003424-A	<1	FT-FY21-032021-003424-B	<1
WS- 003425	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 239	WF-06242020-003425	3/18/2021	FT-FY21-032021-003425-A	<1	FT-FY21-032021-003425-B	<1
WS- 003426	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 239	WF-09152020-003426	3/18/2021	FT-FY21-032021-003426-A	<1	FT-FY21-032021-003426-B	<1
WS- 003427	6/24/2020	6/24/2021	2	Combo Fountain	In staff workroom 237	WF-06242020-003427	3/18/2021	FT-FY21-032021-003427-A	<1	FT-FY21-032021-003427-B	<1
WS- 003428	6/24/2020	6/24/2021	2	Break Room	In staff workroom 237	WF-06242020-003428	3/18/2021	FT-FY21-032021-003428-A	<1	FT-FY21-032021-003428-B	<1
WS- 003429	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 235	WF-06242020-003429	3/18/2021	FT-FY21-032021-003429-A	<1	FT-FY21-032021-003429-B	<1
WS- 003430	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 235	WF-09152020-003430	3/18/2021	FT-FY21-032021-003430-A	<1	FT-FY21-032021-003430-B	<1
WS- 003431	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 224	WF-06242020-003431	3/18/2021	FT-FY21-032021-003431-A	<1	FT-FY21-032021-003431-B	<1
WS- 003432	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 224	WF-09152020-003432	3/18/2021	FT-FY21-032021-003432-A	<1	FT-FY21-032021-003432-B	<1
WS- 003433	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 231	WF-06242020-003433	3/18/2021	FT-FY21-032021-003433-A	<1	FT-FY21-032021-003433-B	<1
WS- 003434	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 231	WF-09152020-003434	3/18/2021	FT-FY21-032021-003434-A	<1	FT-FY21-032021-003434-B	<1
WS- 003435	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 218	WF-06242020-003435	3/18/2021	FT-FY21-032021-003435-A	<1	FT-FY21-032021-003435-B	<1
WS- 003436	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 218	WF-09152020-003436	3/18/2021	FT-FY21-032021-003436-A	<1	FT-FY21-032021-003436-B	<1
WS- 003437	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 216	WF-06242020-003437	3/18/2021	FT-FY21-032021-003437-A	<1	FT-FY21-032021-003437-B	<1
WS- 003438	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 216	WF-09152020-003438	3/18/2021	FT-FY21-032021-003438-A	<1	FT-FY21-032021-003438-B	<1
WS- 003439	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 214	WF-06242020-003439	3/18/2021	FT-FY21-032021-003439-A	<1	FT-FY21-032021-003439-B	<1
WS- 003440	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 214	WF-09152020-003440	3/18/2021	FT-FY21-032021-003440-A	<1	FT-FY21-032021-003440-B	<1
WS- 003441	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 212	WF-06242020-003441	3/18/2021	FT-FY21-032021-003441-A	<1	FT-FY21-032021-003441-B	<1
WS- 003442	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 212	WF-09152020-003442	3/18/2021	FT-FY21-032021-003442-A	<1	FT-FY21-032021-003442-B	<1
WS- 003443	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 213	WF-06242020-003443	3/18/2021	FT-FY21-032021-003443-A	<1	FT-FY21-032021-003443-B	<1
WS- 003444	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 213	WF-09152020-003444	3/18/2021	FT-FY21-032021-003444-A	<1	FT-FY21-032021-003444-B	<1
WS- 003445	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 210	WF-06242020-003445	3/18/2021	FT-FY21-032021-003445-A	<1	FT-FY21-032021-003445-B	<1
WS- 003446	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 210	WF-09152020-003446	3/18/2021	FT-FY21-032021-003446-A	<1	FT-FY21-032021-003446-B	<1
WS- 003448	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 208 on south wall	WF-09152020-003448	3/18/2021	FT-FY21-032021-003448-A	<1	FT-FY21-032021-003448-B	<1
WS- 003449	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 208 on south wall	WF-06242020-003449	3/18/2021	FT-FY21-032021-003449-A	<1	FT-FY21-032021-003449-B	<1
WS- 003450	6/24/2020	6/24/2021	2	Combo Fountain	In classroom 206	WF-06242020-003450	3/18/2021	FT-FY21-032021-003450-A	<1	FT-FY21-032021-003450-B	<1
WS- 003452	9/15/2020	9/15/2021	2	Combo Faucet	In classroom 206	WF-09152020-003452	3/18/2021	FT-FY21-032021-003452-A	<1	FT-FY21-032021-003452-B	<1
WS- 003456	6/24/2020	6/24/2021	3	Combo Fountain	In classroom 309	WF-06242020-003456	3/18/2021	FT-FY21-032021-003456-A	<1	FT-FY21-032021-003456-B	<1
WS- 003457	9/15/2020	9/15/2021	3	Combo Faucet	In classroom 309	WF-09152020-003457	3/18/2021	FT-FY21-032021-003457-A	<1	FT-FY21-032021-003457-B	<1
WS- 003458	6/24/2020	6/24/2021	3	Combo Fountain	In classroom 308	WF-06242020-003458	3/18/2021	FT-FY21-032021-003458-A	<1	FT-FY21-032021-003458-B	<1
WS- 003459	9/15/2020	9/15/2021	3	Combo Faucet	In classroom 308	WF-09152020-003459	3/18/2021	FT-FY21-032021-003459-A	<1	FT-FY21-032021-003459-B	<1
WS- 003460	6/24/2020	6/24/2021	3	Combo Fountain	In classroom 310	WF-06242020-003460	3/18/2021	FT-FY21-032021-003460-A	<1	FT-FY21-032021-003460-B	<1
WS- 003461	9/15/2020	9/15/2021	3	Combo Faucet	In classroom 310	WF-09152020-003461	3/18/2021	FT-FY21-032021-003461-A	<1	FT-FY21-032021-003461-B	<1

WS- 003462	6/24/2020	6/24/2021	3	Combo Fountain	In classroom 312	WF-06242020-003462	3/18/2021	FT-FY21-032021-003462-A	<1	FT-FY21-032021-003462-B	<1
WS- 003463	9/15/2020	9/15/2021	3	Combo Faucet	In classroom 312	WF-09152020-003463	3/18/2021	FT-FY21-032021-003463-A	<1	FT-FY21-032021-003463-B	<1
WS- 003464	6/24/2020	6/24/2021	3	Combo Fountain	In classroom 314	WF-06242020-003464	3/18/2021	FT-FY21-032021-003464-A	<1	FT-FY21-032021-003464-B	<1
WS- 003465	9/15/2020	9/15/2021	3	Combo Faucet	In classroom 314	WF-09152020-003465	3/18/2021	FT-FY21-032021-003465-A	<1	FT-FY21-032021-003465-B	<1
WS- 003466	6/24/2020	6/24/2021	3	Combo Fountain	In classroom 316	WF-06242020-003466	3/18/2021	FT-FY21-032021-003466-A	<1	FT-FY21-032021-003466-B	<1
WS- 003467	9/15/2020	9/15/2021	3	Combo Faucet	In classroom 316	WF-09152020-003467	3/18/2021	FT-FY21-032021-003467-A	2.5	FT-FY21-032021-003467-B	<1
WS- 003468	6/24/2020	6/24/2021	3	Combo Fountain	In classroom 331	WF-06242020-003468	3/18/2021	FT-FY21-032021-003468-A	<1	FT-FY21-032021-003468-B	<1
WS- 003470	6/24/2020	6/24/2021	3	Combo Fountain	In classroom 325	WF-06242020-003470	3/18/2021	FT-FY21-032021-003470-A	<1	FT-FY21-032021-003470-B	<1
WS- 003471	9/15/2020	9/15/2021	3	Combo Faucet	In classroom 325	WF-09152020-003471	3/18/2021	FT-FY21-032021-003471-A	<1	FT-FY21-032021-003471-B	<1
WS- 003474	9/15/2020	9/15/2021	3	Combo Faucet	In classroom 331	WF-09152020-003474	3/18/2021	FT-FY21-032021-003474-A	<1	FT-FY21-032021-003474-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003392	2/3/2021	2/3/2022	1	Food Prep Sink	In kitchen on south wall Left	WF-02032021-003392	3/18/2021	FT-FY21-032021-003392-A	<1	FT-FY21-032021-003392-B	<1