



Brightwood Education Campus Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003371	4/23/2025	4/23/2026	1	Bottle Filler	In hallway adjacent to 106A	WF-04232025-003371	11/4/2025	FT-FY26-10172025-003371-A	<2	FT-FY26-10172025-003371-B	<2
WS- 003372	4/23/2025	4/23/2026	1	Bottle Filler	In hallway adjacent to room 123	WF-04232025-003372	11/4/2025	FT-FY26-10172025-003372-A	<2	FT-FY26-10172025-003372-B	<2
WS- 003374	4/23/2025	4/23/2026	2	Bottle Filler	In hallway adjacent to room 211	WF-04232025-003374	11/4/2025	FT-FY26-10172025-003374-A	<2	FT-FY26-10172025-003374-B	<2
WS- 003382	8/11/2025	8/11/2026	1	Bathroom	In classroom 142 in bathroom	WF-08112025-003382	11/4/2025	FT-FY26-10172025-003382-A	<2	FT-FY26-10172025-003382-B	<2
WS- 003383	8/11/2025	8/11/2026	1	Bathroom	In classroom 143 in bathroom	WF-08112025-003383	11/4/2025	FT-FY26-10172025-003383-A	<2	FT-FY26-10172025-003383-B	<2
WS- 003384	8/11/2025	8/11/2026	1	Bathroom	In classroom 146 in bathroom	WF-08112025-003384	11/4/2025	FT-FY26-10172025-003384-A	<2	FT-FY26-10172025-003384-B	<2
WS- 003385	8/11/2025	8/11/2026	1	Bathroom	In classroom 147 in bathroom	WF-08112025-003385	11/4/2025	FT-FY26-10172025-003385-A	<2	FT-FY26-10172025-003385-B	<2
WS- 003386	8/11/2025	8/11/2026	1	Bathroom	In classroom 125 in bathroom	WF-08112025-003386	11/4/2025	FT-FY26-10172025-003386-A	<2	FT-FY26-10172025-003386-B	<2
WS- 003387	8/11/2025	8/11/2026	1	Bathroom	In classroom 130 in bathroom	WF-08112025-003387	11/4/2025	FT-FY26-10172025-003387-A	<2	FT-FY26-10172025-003387-B	<2
WS- 003388	8/11/2025	8/11/2026	1	Bathroom	In classroom 136 in bathroom	WF-08112025-003388	11/4/2025	FT-FY26-10172025-003388-A	<2	FT-FY26-10172025-003388-B	<2
WS- 003389	8/11/2025	8/11/2026	1	Bathroom	In classroom 137 in bathroom	WF-08112025-003389	11/4/2025	FT-FY26-10172025-003389-A	<2	FT-FY26-10172025-003389-B	<2
WS- 003390	8/11/2025	8/11/2026	1	Bathroom	In classroom 138 in bathroom	WF-08112025-003390	11/4/2025	FT-FY26-10172025-003390-A	<2	FT-FY26-10172025-003390-B	<2
WS- 003394	4/23/2025	4/23/2026	1	Cooler	In hallway adjacent to 106a High Left	WF-04232025-003394	11/4/2025	FT-FY26-10172025-003394-A	<2	FT-FY26-10172025-003394-B	<2
WS- 003395	4/23/2025	4/23/2026	1	Cooler	In hallway adjacent to 106A Low Right	WF-04232025-003395	11/4/2025	FT-FY26-10172025-003395-A	<2	FT-FY26-10172025-003395-B	<2
WS- 003396	4/23/2025	4/23/2026	1	Health Suite	In health suite in exam room 106D	WF-04232025-003396	11/4/2025	FT-FY26-10172025-003396-A	<2	FT-FY26-10172025-003396-B	<2
WS- 003399	4/23/2025	4/23/2026	1	Cooler	In hallway adjacent to room 123 Low Right	WF-04232025-003399	11/4/2025	FT-FY26-10172025-003399-A	<2	FT-FY26-10172025-003399-B	<2
WS- 003400	4/23/2025	4/23/2026	1	Cooler	In hallway adjacent to room 123 High Left	WF-04232025-003400	11/4/2025	FT-FY26-10172025-003400-A	<2	FT-FY26-10172025-003400-B	<2
WS- 003401	4/23/2025	4/23/2026	1	Combo Fountain	In classroom 125	WF-04232025-003401	11/4/2025	FT-FY26-10172025-003401-A	<2	FT-FY26-10172025-003401-B	<2
WS- 003402	8/11/2025	8/11/2026	1	Combo Faucet	In classroom 125	WF-08112025-003402	11/4/2025	FT-FY26-10172025-003402-A	<2	FT-FY26-10172025-003402-B	<2
WS- 003403	4/23/2025	4/23/2026	1	Combo Fountain	In classroom 128	WF-04232025-003403	11/4/2025	FT-FY26-10172025-003403-A	<2	FT-FY26-10172025-003403-B	<2
WS- 003404	8/11/2025	8/11/2026	1	Combo Faucet	In classroom 128	WF-08112025-003404	11/4/2025	FT-FY26-10172025-003404-A	<2	FT-FY26-10172025-003404-B	<2
WS- 003405	4/23/2025	4/23/2026	1	Combo Fountain	In classroom 130	WF-04232025-003405	11/4/2025	FT-FY26-10172025-003405-A	<2	FT-FY26-10172025-003405-B	<2
WS- 003406	8/11/2025	8/11/2026	1	Combo Faucet	In classroom 130	WF-08112025-003406	11/4/2025	FT-FY26-10172025-003406-A	<2	FT-FY26-10172025-003406-B	<2
WS- 003407	4/23/2025	4/23/2026	1	Combo Fountain	In classroom 136	WF-04232025-003407	11/4/2025	FT-FY26-10172025-003407-A	<2	FT-FY26-10172025-003407-B	<2
WS- 003408	8/11/2025	8/11/2026	1	Combo Faucet	In classroom 136	WF-08112025-003408	11/4/2025	FT-FY26-10172025-003408-A	<2	FT-FY26-10172025-003408-B	<2
WS- 003409	4/23/2025	4/23/2026	1	Combo Fountain	In classroom 137	WF-04232025-003409	11/4/2025	FT-FY26-10172025-003409-A	<2	FT-FY26-10172025-003409-B	<2
WS- 003410	8/11/2025	8/11/2026	1	Combo Faucet	In classroom 137	WF-08112025-003410	11/4/2025	FT-FY26-10172025-003410-A	<2	FT-FY26-10172025-003410-B	<2
WS- 003411	4/23/2025	4/23/2026	1	Combo Fountain	In classroom 138	WF-04232025-003411	11/4/2025	FT-FY26-10172025-003411-A	<2	FT-FY26-10172025-003411-B	<2
WS- 003412	8/11/2025	8/11/2026	1	Combo Faucet	In classroom 138	WF-08112025-003412	11/4/2025	FT-FY26-10172025-003412-A	<2	FT-FY26-10172025-003412-B	<2
WS- 003413	4/23/2025	4/23/2026	1	Combo Fountain	In classroom 142	WF-04232025-003413	11/4/2025	FT-FY26-10172025-003413-A	<2	FT-FY26-10172025-003413-B	<2
WS- 003414	8/11/2025	8/11/2026	1	Combo Faucet	In classroom 142	WF-08112025-003414	11/4/2025	FT-FY26-10172025-003414-A	<2	FT-FY26-10172025-003414-B	<2
WS- 003415	4/23/2025	4/23/2026	1	Combo Fountain	In classroom 143	WF-04232025-003415	11/4/2025	FT-FY26-10172025-003415-A	<2	FT-FY26-10172025-003415-B	<2
WS- 003416	8/11/2025	8/11/2026	1	Combo Faucet	In classroom 143	WF-08112025-003416	11/4/2025	FT-FY26-10172025-003416-A	<2	FT-FY26-10172025-003416-B	<2
WS- 003417	4/23/2025	4/23/2026	1	Combo Fountain	In classroom 145	WF-04232025-003417	11/4/2025	FT-FY26-10172025-003417-A	<2	FT-FY26-10172025-003417-B	<2

WS- 003464	4/23/2025	4/23/2026	3	Combo Fountain	In classroom 314		WF-04232025-003464	11/4/2025	FT-FY26-10172025-003464-A	<2	FT-FY26-10172025-003464-B	<2
WS- 003465	8/11/2025	8/11/2026	3	Combo Faucet	In classroom 314		WF-08112025-003465	11/4/2025	FT-FY26-10172025-003465-A	<2	FT-FY26-10172025-003465-B	<2
WS- 003466	4/23/2025	4/23/2026	3	Combo Fountain	In classroom 316		WF-04232025-003466	11/4/2025	FT-FY26-10172025-003466-A	<2	FT-FY26-10172025-003466-B	<2
WS- 003467	8/11/2025	8/11/2026	3	Combo Faucet	In classroom 316		WF-08112025-003467	11/4/2025	FT-FY26-10172025-003467-A	<2	FT-FY26-10172025-003467-B	<2
WS- 003468	4/23/2025	4/23/2026	3	Combo Fountain	In classroom 331		WF-04232025-003468	11/4/2025	FT-FY26-10172025-003468-A	<2	FT-FY26-10172025-003468-B	<2
WS- 003470	4/23/2025	4/23/2026	3	Combo Fountain	In classroom 325		WF-04232025-003470	11/4/2025	FT-FY26-10172025-003470-A	<2	FT-FY26-10172025-003470-B	<2
WS- 003471	8/11/2025	8/11/2026	3	Combo Faucet	In classroom 325		WF-08112025-003471	11/4/2025	FT-FY26-10172025-003471-A	<2	FT-FY26-10172025-003471-B	<2
WS- 003472	4/23/2025	4/23/2026	3	Cooler	In hallway adjacent to room 307	Low Right	WF-04232025-003472	11/4/2025	FT-FY26-10172025-003472-A	<2	FT-FY26-10172025-003472-B	<2
WS- 003473	4/23/2025	4/23/2026	3	Cooler	In hallway adjacent to room 307	High Left	WF-04232025-003473	11/4/2025	FT-FY26-10172025-003473-A	<2	FT-FY26-10172025-003473-B	<2
WS- 003474	8/11/2025	8/11/2026	3	Combo Faucet	In classroom 331		WF-08112025-003474	11/4/2025	FT-FY26-10172025-003474-A	<2	FT-FY26-10172025-003474-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003392	12/2/2024	12/2/2025	1	Food Prep Sink	In kitchen on south wall	Left	WF-12022024-003392	11/4/2025	FT-FY26-10172025-003392-A	<2	FT-FY26-10172025-003392-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.