



BRIGHTWOOD EC ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003393	8/21/2016	1	Food Prep Sink	In kitchen on south wall Right	FT-82016-003393-A	< 1	FT-82016-003393-B	< 1
2	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003394	8/21/2016	1	Cooler	In hallway adjacent to 106a High Left	FT-82016-003394-A	< 1	FT-82016-003394-B	< 1
3	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003395	8/21/2016	1	Cooler	In hallway adjacent to 106A Low Right	FT-82016-003395-A	< 1	FT-82016-003395-B	< 1
4	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003396	8/21/2016	1	Health Suite	In exam room 106D in health suite	FT-82016-003396-A	< 1	FT-82016-003396-B	< 1
5	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003399	8/21/2016	1	Cooler	In hallway adjacent to room 123 Low Right	FT-82016-003399-A	< 1	FT-82016-003399-B	< 1
6	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003400	8/21/2016	1	Cooler	In hallway adjacent to room 123 High Left	FT-82016-003400-A	< 1	FT-82016-003400-B	< 1
7	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003401	8/21/2016	1	Fountain	In classroom 125	FT-82016-003401-A	< 1	FT-82016-003401-B	< 1
8	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003403	8/21/2016	1	Fountain	In classroom 128	FT-82016-003403-A	< 1	FT-82016-003403-B	< 1
9	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003405	8/21/2016	1	Fountain	In classroom 130	FT-82016-003405-A	< 1	FT-82016-003405-B	< 1
10	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003407	8/21/2016	1	Fountain	In classroom 136	FT-82016-003407-A	< 1	FT-82016-003407-B	< 1
11	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003409	8/21/2016	1	Fountain	In classroom 137	FT-82016-003409-A	< 1	FT-82016-003409-B	< 1
12	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003411	8/21/2016	1	Fountain	In classroom 138	FT-82016-003411-A	< 1	FT-82016-003411-B	< 1
13	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003413	8/21/2016	1	Fountain	In classroom 142	FT-82016-003413-A	< 1	FT-82016-003413-B	< 1
14	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003415	8/21/2016	1	Fountain	In classroom 143	FT-82016-003415-A	< 1	FT-82016-003415-B	< 1
15	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003417	8/21/2016	1	Fountain	In classroom 145	FT-82016-003417-A	< 1	FT-82016-003417-B	< 1
16	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003419	8/21/2016	1	Fountain	In classroom 147	FT-82016-003419-A	< 1	FT-82016-003419-B	< 1
17	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003421	8/21/2016	1	Fountain	In classroom 146	FT-82016-003421-A	< 1	FT-82016-003421-B	< 1
18	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003423	8/21/2016	2	Fountain	In classroom 227	FT-82016-003423-A	< 1	FT-82016-003423-B	< 1
19	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003425	8/21/2016	2	Fountain	In classroom 239	FT-82016-003425-A	< 1	FT-82016-003425-B	< 1
20	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003427	8/21/2016	2	Fountain	In staff workroom 237	FT-82016-003427-A	< 1	FT-82016-003427-B	< 1
21	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003429	8/21/2016	2	Fountain	In classroom 235	FT-82016-003429-A	< 1	FT-82016-003429-B	< 1
22	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003431	8/21/2016	2	Fountain	In classroom 224	FT-82016-003431-A	< 1	FT-82016-003431-B	< 1
23	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003433	8/21/2016	2	Fountain	In classroom 231	FT-82016-003433-A	< 1	FT-82016-003433-B	< 1
24	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003435	8/21/2016	2	Fountain	In classroom 218	FT-82016-003435-A	< 1	FT-82016-003435-B	< 1
25	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003437	8/21/2016	2	Fountain	In classroom 216	FT-82016-003437-A	< 1	FT-82016-003437-B	< 1
26	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003439	8/21/2016	2	Fountain	In classroom 214	FT-82016-003439-A	< 1	FT-82016-003439-B	< 1
27	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003441	8/21/2016	2	Fountain	In classroom 222	FT-82016-003441-A	< 1	FT-82016-003441-B	< 1
28	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003443	8/21/2016	2	Fountain	In classroom 213	FT-82016-003443-A	< 1	FT-82016-003443-B	< 1
29	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003445	8/21/2016	2	Fountain	In classroom 210	FT-82016-003445-A	< 1	FT-82016-003445-B	< 1
30	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003449	8/21/2016	2	Fountain	In classroom 208 on south wall	FT-82016-003449-A	< 1	FT-82016-003449-B	< 1
31	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003450	8/21/2016	2	Fountain	In classroom 206	FT-82016-003450-A	< 1	FT-82016-003450-B	< 1
32	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003453	8/21/2016	2	Cooler	In hallway adjacent to room 211 Low Right	FT-82016-003453-A	< 1	FT-82016-003453-B	< 1
33	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003454	8/21/2016	2	Cooler	In hallway adjacent to room 211 High Left	FT-82016-003454-A	< 1	FT-82016-003454-B	< 1
34	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003456	8/21/2016	3	Fountain	In classroom 309	FT-82016-003456-A	< 1	FT-82016-003456-B	< 1
35	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003458	8/21/2016	3	Fountain	In classroom 308	FT-82016-003458-A	< 1	FT-82016-003458-B	< 1
36	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003460	8/21/2016	3	Fountain	In classroom 310	FT-82016-003460-A	< 1	FT-82016-003460-B	< 1
37	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003462	8/21/2016	3	Fountain	In classroom 312	FT-82016-003462-A	< 1	FT-82016-003462-B	< 1
38	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003464	8/21/2016	3	Fountain	In classroom 314	FT-82016-003464-A	< 1	FT-82016-003464-B	< 1
39	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003466	8/21/2016	3	Fountain	In classroom 316	FT-82016-003466-A	< 1	FT-82016-003466-B	< 1
40	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003468	8/21/2016	3	Fountain	In classroom 331	FT-82016-003468-A	< 1	FT-82016-003468-B	< 1
41	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003470	8/21/2016	3	Fountain	In classroom 325	FT-82016-003470-A	< 1	FT-82016-003470-B	< 1
42	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003472	8/21/2016	3	Cooler	In hallway adjacent to room 307 Low Right	FT-82016-003472-A	< 1	FT-82016-003472-B	< 1
43	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003473	8/21/2016	3	Cooler	In hallway adjacent to room 307 High Left	FT-82016-003473-A	< 1	FT-82016-003473-B	< 1