



# BRIGHTWOOD LEAD WATER TEST RESULTS

May 4th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date
1	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003474	Classroom	3	In classroom 331	WT-042916-3491- A	< 1	WT-042916-3491- B	< 1		
2	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003473	Cooler	3	In hallway adjacent to 307 Left High	WT-042916-3490- A	< 1	WT-042916-3490- B	< 1		
3	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003472	Cooler	3	In hallway adjacent to room 307 Right Low	WT-042916-3489- A	< 1	WT-042916-3489- B	< 1		
4	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003470	Fountain	3	In 325	WT-042916-3487- A	< 1	WT-042916-3487- B	< 1		
5	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003468	Fountain	3	In 331	WT-042916-3485- A	< 1	WT-042916-3485- B	< 1		
6	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003466	Fountain	3	In classroom 316	WT-042916-3483- A	< 1	WT-042916-3483- B	< 1		
7	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003465	Classroom	3	In classroom 314	WT-042916-3482- A	< 1	WT-042916-3482- B	< 1		
8	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003464	Fountain	3	In classroom 314	WT-042916-3481- A	< 1	WT-042916-3481- B	< 1		
9	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003463	Classroom	3	In classroom 312	WT-042916-3480- A	< 1	WT-042916-3480- B	< 1		
10	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003462	Fountain	3	In classroom 312	WT-042916-3479- A	< 1	WT-042916-3479- B	< 1		
11	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003461	Classroom	3	In classroom 310	WT-042916-3478- A	< 1	WT-042916-3478- B	< 1		
12	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003460	Fountain	3	In classroom 310	WT-042916-3477- A	< 1	WT-042916-3477- B	< 1		
13	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003459	Classroom	3	In classroom 308	WT-042916-3476- A	< 1	WT-042916-3476- B	< 1		
14	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003458	Fountain	3	In classroom 308	WT-042916-3475- A	< 1	WT-042916-3475- B	< 1		
15	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003457	Classroom	3	In 309	WT-042916-3474- A	< 1	WT-042916-3474- B	< 1		
16	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003456	Fountain	3	In 309	WT-042916-3473- A	< 1	WT-042916-3473- B	< 1		
17	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003455	Classroom	2	In 202	WT-042916-3472- A	< 1	WT-042916-3472- B	< 1		
18	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003454	Cooler	2	In hallway adjacent to 211 Left High	WT-042916-3471- A	< 1	WT-042916-3471- B	< 1		
19	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003453	Cooler	2	In hallway adjacent to 211 Right Low	WT-042916-3470- A	< 1	WT-042916-3470- B	< 1		
20	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003452	Classroom	2	In classroom 206	WT-042916-3469- A	< 1	WT-042916-3469- B	< 1		
21	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003451	Classroom	2	In middle of classroom 208	WT-042916-3468- A	< 1	WT-042916-3468- B	< 1		
22	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003450	Fountain	2	In classroom 206	WT-042916-3467- A	< 1	WT-042916-3467- B	< 1		
23	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003449	Fountain	2	In classroom 208	WT-042916-3466- A	< 1	WT-042916-3466- B	< 1		
24	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003448	Classroom	2	In classroom 208 south wall	WT-042916-3465- A	< 1	WT-042916-3465- B	< 1		



# BRIGHTWOOD LEAD WATER TEST RESULTS

May 4th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date
25	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003447	Classroom	2	In classroom 208 northeast wall	WT-042916-3464- A	< 1	WT-042916-3464- B	< 1		
26	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003446	Classroom	2	In classroom 210	WT-042916-3463- A	< 1	WT-042916-3463- B	< 1		
27	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003445	Fountain	2	In classroom 210	WT-042916-3462- A	< 1	WT-042916-3462- B	< 1		
28	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003444	Classroom	2	In 213	WT-042916-3461- A	< 1	WT-042916-3461- B	< 1		
29	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003443	Fountain	2	In 213	WT-042916-3460- A	< 1	WT-042916-3460- B	< 1		
30	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003442	Classroom	2	In staff break room	WT-042916-3459- A	< 1	WT-042916-3459- B	< 1		
31	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003441	Fountain	2	In staff break room	WT-042916-3458- A	< 1	WT-042916-3458- B	< 1		
32	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003440	Classroom	2	In classroom 214	WT-042916-3457- A	< 1	WT-042916-3457- B	< 1		
33	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003439	Fountain	2	In classroom 214	WT-042916-3456- A	< 1	WT-042916-3456- B	< 1		
34	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003438	Classroom	2	In classroom 216	WT-042916-3455- A	< 1	WT-042916-3455- B	< 1		
35	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003437	Fountain	2	In classroom 216	WT-042916-3454- A	< 1	WT-042916-3454- B	< 1		
36	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003436	Classroom	2	In 237	WT-042916-3453- A	< 1	WT-042916-3453- B	< 1		
37	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003435	Fountain	2	In 218	WT-042916-3452- A	< 1	WT-042916-3452- B	< 1		
38	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003434	Classroom	2	In 231	WT-042916-3451- A	< 1	WT-042916-3451- B	< 1		
39	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003433	Fountain	2	In 231	WT-042916-3450- A	< 1	WT-042916-3450- B	< 1		
40	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003432	Classroom	2	In classroom 224	WT-042916-3449- A	< 1	WT-042916-3449- B	< 1		
41	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003431	Fountain	2	In classroom 224	WT-042916-3448- A	< 1	WT-042916-3448- B	< 1		
42	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003430	Classroom	2	In classroom 235	WT-042916-3447- A	< 1	WT-042916-3447- B	< 1		
43	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003429	Fountain	2	In classroom 235	WT-042916-3446- A	< 1	WT-042916-3446- B	< 1		
44	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003428	Classroom	2	In 237	WT-042916-3445- A	< 1	WT-042916-3445- B	< 1		
45	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003427	Fountain	2	In 237	WT-042916-3444- A	< 1	WT-042916-3444- B	< 1		
46	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003426	Classroom	2	In classroom 239	WT-042916-3443- A	< 1	WT-042916-3443- B	< 1		
47	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003425	Fountain	2	In classroom 239	WT-042916-3442- A	< 1	WT-042916-3442- B	< 1		
48	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003424	Classroom	2	In 227	WT-042916-3441- A	< 1	WT-042916-3441- B	< 1		



# BRIGHTWOOD LEAD WATER TEST RESULTS

May 4th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date
49	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003423	Fountain	2	In 227	WT-042916-3440- A	< 1	WT-042916-3440- B	< 1		
50	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003422	Classroom	1	In classroom 146	WT-042916-3439- A	< 1	WT-042916-3439- B	< 1		
51	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003421	Fountain	1	In classroom 146	WT-042916-3438- A	< 1	WT-042916-3438- B	< 1		
52	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003420	Classroom	1	In 147	WT-042916-3437- A	< 1	WT-042916-3437- B	< 1		
53	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003419	Fountain	1	In 147	WT-042916-3436- A	< 1	WT-042916-3436- B	< 1		
54	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003418	Classroom	1	In room 145	WT-042916-3435- A	< 1	WT-042916-3435- B	< 1		
55	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003417	Fountain	1	In room 145	WT-042916-3434- A	< 1	WT-042916-3434- B	< 1		
56	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003416	Classroom	1	In classroom 143	WT-042916-3433- A	< 1	WT-042916-3433- B	< 1		
57	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003415	Fountain	1	In classroom 143	WT-042916-3432- A	< 1	WT-042916-3432- B	< 1		
58	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003414	Classroom	1	In 142	WT-042916-3431- A	< 1	WT-042916-3431- B	< 1		
59	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003413	Fountain	1	In 142	WT-042916-3430- A	< 1	WT-042916-3430- B	< 1		
60	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003412	Classroom	1	In classroom 138	WT-042916-3429- A	< 1	WT-042916-3429- B	< 1		
61	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003411	Fountain	1	In classroom 138	WT-042916-3428- A	< 1	WT-042916-3428- B	< 1		
62	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003410	Classroom	1	In 137	WT-042916-3427- A	< 1	WT-042916-3427- B	< 1		
63	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003409	Fountain	1	In 137	WT-042916-3426- A	< 1	WT-042916-3426- B	< 1		
64	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003408	Classroom	1	In classroom 136	WT-042916-3425- A	< 1	WT-042916-3425- B	< 1		
65	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003407	Fountain	1	In classroom 136	WT-042916-3424- A	< 1	WT-042916-3424- B	< 1		
66	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003406	Classroom	1	In 130	WT-042916-3423- A	< 1	WT-042916-3423- B	< 1		
67	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003405	Fountain	1	In 130	WT-042916-3422- A	< 1	WT-042916-3422- B	< 1		
68	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003404	Classroom	1	In 128	WT-042916-3421- A	< 1	WT-042916-3421- B	< 1		
69	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003403	Fountain	1	In 128	WT-042916-3420- A	< 1	WT-042916-3420- B	< 1		
70	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003402	Classroom	1	In classroom 125	WT-042916-3419- A	< 1	WT-042916-3419- B	< 1		
71	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003401	Fountain	1	In classroom 125	WT-042916-3418- A	< 1	WT-042916-3418- B	< 1		
72	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003400	Cooler	1	In hallway adjacent to 123 Left High	WT-042916-3417- A	< 1	WT-042916-3417- B	< 1		



# BRIGHTWOOD LEAD WATER TEST RESULTS

May 4th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date
73	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003399	Cooler	1	In hallway adjacent to 123 Right Low	WT-042916-3416- A	< 1	WT-042916-3416- B	< 1		
74	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003398	Classroom	1	In room 120	WT-042916-3415- A	< 1	WT-042916-3415- B	< 1		
75	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003397	Classroom	1	In room 114	WT-042916-3414- A	< 1	WT-042916-3414- B	< 1		
76	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003396	Health Suite	1	In 106d	WT-042916-3413- A	< 1	WT-042916-3413- B	< 1		
77	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003394	Cooler	1	In hallway adjacent to 106a Left High	WT-042916-3411- A	< 1	WT-042916-3411- B	< 1		
78	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003393	Kitchen	Ground Floor	South wall Right	WT-042916-3410- A	< 1	WT-042916-3410- B	< 1		
79	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003392	Kitchen	1	South wall Left	WT-042916-3409- A	< 1	WT-042916-3409- B	< 1		
80	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003391	Utility	Basement	Main Water source	WT-042916-3408- A	< 1	WT-042916-3408- B	< 1		
81	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003467	Classroom	3	In classroom 316	WT-042916-3484- A	1.1	WT-042916-3484- B	< 1		
82	BRIGHTWOOD EDUCATIONAL CAMPUS	5/4/2016	WS- 003471	Classroom	3	In 325	WT-042916-3488- A	1.7	WT-042916-3488- B	< 1		

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.

Retest Results

<b>Retest Results</b>

Retest Results

Retest Results