



# BRIGHTWOOD EC LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003382	12/30/2016	1	Bathroom	In classroom 142 in bathroom	FT-122016-003382-A	< 1	FT-122016-003382-B	< 1
2	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003383	12/30/2016	1	Bathroom	In classroom 143 in bathroom	FT-122016-003383-A	< 1	FT-122016-003383-B	< 1
3	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003386	12/30/2016	1	Bathroom	In classroom 125 in bathroom	FT-122016-003386-A	< 1	FT-122016-003386-B	< 1
4	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003387	12/30/2016	1	Bathroom	In classroom 130 in bathroom	FT-122016-003387-A	< 1	FT-122016-003387-B	< 1
5	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003388	12/30/2016	1	Bathroom	In classroom 136 in bathroom	FT-122016-003388-A	< 1	FT-122016-003388-B	< 1
6	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003389	12/30/2016	1	Bathroom	In classroom 137 in bathroom	FT-122016-003389-A	< 1	FT-122016-003389-B	< 1
7	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003402	12/30/2016	1	Combo Faucet	In classroom 125	FT-122016-003402-A	< 1	FT-122016-003402-B	< 1
8	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003404	12/30/2016	1	Combo Faucet	In classroom 128	FT-122016-003404-A	< 1	FT-122016-003404-B	< 1
9	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003406	12/30/2016	1	Combo Faucet	In classroom 130	FT-122016-003406-A	< 1	FT-122016-003406-B	< 1
10	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003408	12/30/2016	1	Combo Faucet	In classroom 136	FT-122016-003408-A	< 1	FT-122016-003408-B	< 1
11	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003410	12/30/2016	1	Combo Faucet	In classroom 137	FT-122016-003410-A	< 1	FT-122016-003410-B	< 1
12	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003412	12/30/2016	1	Combo Faucet	In classroom 138	FT-122016-003412-A	< 1	FT-122016-003412-B	< 1
13	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003414	12/30/2016	1	Combo Faucet	In classroom 142	FT-122016-003414-A	< 1	FT-122016-003414-B	< 1
14	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003418	12/30/2016	1	Combo Faucet	In classroom 145	FT-122016-003418-A	< 1	FT-122016-003418-B	< 1
15	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003420	12/30/2016	1	Combo Faucet	In classroom 147	FT-122016-003420-A	< 1	FT-122016-003420-B	< 1
16	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003422	12/30/2016	1	Combo Faucet	In classroom 146	FT-122016-003422-A	< 1	FT-122016-003422-B	< 1
17	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003424	12/30/2016	2	Combo Faucet	In classroom 227	FT-122016-003424-A	< 1	FT-122016-003424-B	< 1
18	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003426	12/30/2016	2	Combo Faucet	In classroom 239	FT-122016-003426-A	< 1	FT-122016-003426-B	< 1
19	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003428	12/30/2016	2	Break Room	In staff workroom 237	FT-102016-003428-A	< 1	FT-102016-003428-B	< 1
20	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003432	12/30/2016	2	Combo Faucet	In classroom 224	FT-122016-003432-A	< 1	FT-122016-003432-B	< 1
21	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003434	12/30/2016	2	Combo Faucet	In classroom 231	FT-122016-003434-A	< 1	FT-122016-003434-B	< 1
22	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003436	12/30/2016	2	Combo Faucet	In classroom 218	FT-122016-003436-A	< 1	FT-122016-003436-B	< 1
23	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003438	12/30/2016	2	Combo Faucet	In classroom 216	FT-122016-003438-A	< 1	FT-122016-003438-B	< 1
24	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003442	12/30/2016	2	Combo Faucet	In classroom 212	FT-122016-003442-A	< 1	FT-122016-003442-B	< 1
25	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003444	12/30/2016	2	Combo Faucet	In classroom 213	FT-122016-003444-A	< 1	FT-122016-003444-B	< 1
26	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003446	12/30/2016	2	Combo Faucet	In classroom 210	FT-122016-003446-A	< 1	FT-122016-003446-B	< 1
27	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003448	12/30/2016	2	Combo Faucet	In classroom 208 on south wall	FT-122016-003448-A	< 1	FT-122016-003448-B	< 1
28	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003452	12/30/2016	2	Combo Faucet	In classroom 206	FT-122016-003452-A	< 1	FT-122016-003452-B	< 1
29	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003457	12/30/2016	3	Combo Faucet	In classroom 309	FT-122016-003457-A	< 1	FT-122016-003457-B	< 1
30	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003459	12/30/2016	3	Combo Faucet	In classroom 308	FT-122016-003459-A	< 1	FT-122016-003459-B	< 1
31	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003461	12/30/2016	3	Combo Faucet	In classroom 310	FT-122016-003461-A	< 1	FT-122016-003461-B	< 1
32	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003463	12/30/2016	3	Combo Faucet	In classroom 312	FT-122016-003463-A	< 1	FT-122016-003463-B	< 1
33	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003465	12/30/2016	3	Combo Faucet	In classroom 314	FT-122016-003465-A	< 1	FT-122016-003465-B	< 1
34	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003467	12/30/2016	3	Combo Faucet	In classroom 316	FT-122016-003467-A	< 1	FT-122016-003467-B	< 1
35	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003471	12/30/2016	3	Combo Faucet	In classroom 325	FT-122016-003471-A	< 1	FT-122016-003471-B	< 1
36	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003474	12/30/2016	3	Combo Faucet	In classroom 331	FT-122016-003474-A	< 1	FT-122016-003474-B	< 1

## Greater than 1 ppb - Devices Shut Off and Corrective Action Taken

Note :  
Filter re-tests are only performed to devices that have sampling results greater than 1 ppb

DCPS ECE Sink and DCPS Requested Sink Filtration

1	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003384	12/30/2016	1	Bathroom	In classroom 146 in bathroom	FT-122016-003384-A	3.8	FT-122016-003384-B	< 1
2	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003390	12/30/2016	1	Bathroom	In classroom 138 in bathroom	FT-122016-003390-A	2.2	FT-122016-003390-B	34
3	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003416	12/30/2016	1	Combo Faucet	In classroom 143	FT-122016-003416-A	1.4	FT-122016-003416-B	< 1
4	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003440	12/30/2016	2	Combo Faucet	In classroom 214	FT-122016-003440-A	1.3	FT-122016-003440-B	< 1
5	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003385	12/30/2016	1	Bathroom	In classroom 147 in bathroom	FT-122016-003385-A	< 1	FT-122016-003385-B	1.7
6	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003430	12/30/2016	2	Combo Faucet	In classroom 235	FT-122016-003430-A	< 1	FT-122016-003430-B	1.4

### First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service										
1	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003384	1/25/2017	1	Bathroom	In classroom 146 in bathroom	FT-122016-003384-A	< 1	FT-122016-003384-B	< 1
2	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003385	1/25/2017	1	Bathroom	In classroom 147 in bathroom	FT-122016-003385-A	< 1	FT-122016-003385-B	< 1
3	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003390	1/25/2017	1	Bathroom	In classroom 138 in bathroom	FT-122016-003390-A	< 1	FT-122016-003390-B	< 1
4	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003416	1/25/2017	1	Combo Faucet	In classroom 143	FT-122016-003416-A	< 1	FT-122016-003416-B	< 1
5	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003440	1/25/2017	2	Combo Faucet	In classroom 214	FT-122016-003440-A	< 1	FT-122016-003440-B	< 1

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003430	1/25/2017	2	Combo Faucet	In classroom 235	FT-122016-003430-A	1.3	FT-122016-003430-B	< 1

### Second Filter Re-Test (After Device Replacement)

Less than 1 ppb - Device Returned to Service										
1	BRIGHTWOOD EDUCATIONAL CAMPUS	WS- 003430	4/7/2017	2	Combo Faucet	In classroom 235	FT-122016-003430-A	< 1	FT-122016-003430-B	< 1

Note :  
Filter re-tests are only performed to devices that have sampling results greater than 1 ppb