



Brookland Middle School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009358	5/3/2021	5/3/2022	1	Break Room	In staff lounge in main office 1112	WF-05032021-009358	2/28/2022	FT-FY22-02032022-009358-A	<1	FT-FY22-02032022-009358-B	<1
WS- 009365	5/3/2021	5/3/2022	1	Bottle Filler	In hallway adjacent to girls' and boys' restrooms (bottle filler)	WF-05032021-009365	2/28/2022	FT-FY22-02032022-009365-A	<1	FT-FY22-02032022-009365-B	<1
WS- 009366	5/3/2021	5/3/2022	1	Cooler	In hallway adjacent to girls' and boys' restrooms High Left	WF-05032021-009366	2/28/2022	FT-FY22-02032022-009366-A	<1	FT-FY22-02032022-009366-B	<1
WS- 009367	5/3/2021	5/3/2022	1	Cooler	In hallway adjacent to girls' and boys' restrooms Low Right	WF-05032021-009367	2/28/2022	FT-FY22-02032022-009367-A	<1	FT-FY22-02032022-009367-B	<1
WS- 009369	5/3/2021	5/3/2022	1	Cooler	In hallway across from room 1303 High Left	WF-05032021-009369	2/28/2022	FT-FY22-02032022-009369-A	<1	FT-FY22-02032022-009369-B	<1
WS- 009370	5/3/2021	5/3/2022	1	Cooler	In hallway across from room 1303 Low Right	WF-05032021-009370	2/28/2022	FT-FY22-02032022-009370-A	<1	FT-FY22-02032022-009370-B	<1
WS- 009379	5/3/2021	5/3/2022	1	Break Room	In staff workroom 1417	WF-05032021-009379	2/28/2022	FT-FY22-02032022-009379-A	<1	FT-FY22-02032022-009379-B	<1
WS- 009381	5/3/2021	5/3/2022	Basement	Bottle Filler	In hallway across from room L201 (bottle filler)	WF-05032021-009381	2/28/2022	FT-FY22-02032022-009381-A	<1	FT-FY22-02032022-009381-B	<1
WS- 009382	5/3/2021	5/3/2022	Basement	Bottle Filler	In hallway across from room L201 (bottle filler)	WF-05032021-009382	2/28/2022	FT-FY22-02032022-009382-A	<1	FT-FY22-02032022-009382-B	<1
WS- 009383	5/3/2021	5/3/2022	Basement	Cooler	In hallway across from room L201 Low Right	WF-05032021-009383	2/28/2022	FT-FY22-02032022-009383-A	<1	FT-FY22-02032022-009383-B	<1
WS- 009384	5/3/2021	5/3/2022	Basement	Cooler	In hallway across from room L201 High Left	WF-05032021-009384	2/28/2022	FT-FY22-02032022-009384-A	<1	FT-FY22-02032022-009384-B	<1
WS- 009385	5/3/2021	5/3/2022	Basement	Cooler	In hallway across from room L201 Low Left	WF-05032021-009385	2/28/2022	FT-FY22-02032022-009385-A	<1	FT-FY22-02032022-009385-B	<1
WS- 009386	5/3/2021	5/3/2022	Basement	Cooler	In hallway across from room L201 High Left	WF-05032021-009386	2/28/2022	FT-FY22-02032022-009386-A	<1	FT-FY22-02032022-009386-B	<1
WS- 010410	5/3/2021	5/3/2022	Basement	Health Suite	In health suite L202	WF-05032021-010410	2/28/2022	FT-FY22-02032022-010410-A	<1	FT-FY22-02032022-010410-B	<1
WS- 010411	5/3/2021	5/3/2022	Basement	Bottle Filler	In hallway adjacent to girls' and boys' restrooms (bottle filler)	WF-05032021-010411	2/28/2022	FT-FY22-02032022-010411-A	<1	FT-FY22-02032022-010411-B	<1
WS- 010412	5/3/2021	5/3/2022	Basement	Cooler	In hallway adjacent to girls' and boys' restrooms High Left	WF-05032021-010412	2/28/2022	FT-FY22-02032022-010412-A	<1	FT-FY22-02032022-010412-B	<1
WS- 010413	5/3/2021	5/3/2022	Basement	Cooler	In hallway adjacent to girls' and boys' restrooms Low Right	WF-05032021-010413	2/28/2022	FT-FY22-02032022-010413-A	<1	FT-FY22-02032022-010413-B	<1
WS- 010416	5/3/2021	5/3/2022	Basement	Cooler	In hallway across from room L303 C wing Low Right	WF-05032021-010416	2/28/2022	FT-FY22-02032022-010416-A	<1	FT-FY22-02032022-010416-B	<1
WS- 010418	5/3/2021	5/3/2022	Basement	Break Room	In staff workroom L417	WF-05032021-010418	2/28/2022	FT-FY22-02032022-010418-A	<1	FT-FY22-02032022-010418-B	<1
WS- 010430	5/3/2021	5/3/2022	2	Bottle Filler	In hallway adjacent to boys' restrooms (bottle filler)	WF-05032021-010430	2/28/2022	FT-FY22-02032022-010430-A	<1	FT-FY22-02032022-010430-B	<1
WS- 010431	5/3/2021	5/3/2022	2	Cooler	In hallway adjacent to boys' restroom High Left	WF-05032021-010431	2/28/2022	FT-FY22-02032022-010431-A	<1	FT-FY22-02032022-010431-B	<1
WS- 010432	5/3/2021	5/3/2022	2	Cooler	In hallway adjacent to boys' restroom Low Right	WF-05032021-010432	2/28/2022	FT-FY22-02032022-010432-A	<1	FT-FY22-02032022-010432-B	<1
WS- 010436	5/3/2021	5/3/2022	2	Cooler	In hallway across from room 2305 High Left	WF-05032021-010436	2/28/2022	FT-FY22-02032022-010436-A	<1	FT-FY22-02032022-010436-B	<1
WS- 010437	5/3/2021	5/3/2022	2	Cooler	In hallway across from room 2305 Low Right	WF-05032021-010437	2/28/2022	FT-FY22-02032022-010437-A	<1	FT-FY22-02032022-010437-B	<1
WS- 010438	5/3/2021	5/3/2022	2	Break Room	In staff workroom 2417	WF-05032021-010438	2/28/2022	FT-FY22-02032022-010438-A	<1	FT-FY22-02032022-010438-B	<1
WS- 010453	5/3/2021	5/3/2022	2	Break Room	In staff lounge 2213	WF-05032021-010453	2/28/2022	FT-FY22-02032022-010453-A	<1	FT-FY22-02032022-010453-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009360	2/2/2022	2/2/2023	1	Food Prep Sink	In kitchen on wall adjacent to icemaker	WF-02022022-009360	2/28/2022	FT-FY22-02032022-009360-A	<1	FT-FY22-02032022-009360-B	<1
WS- 009361	2/2/2022	2/2/2023	1	Food Prep Sink	In kitchen on island	WF-02022022-009361	2/28/2022	FT-FY22-02032022-009361-A	<1	FT-FY22-02032022-009361-B	<1