



Brookland Middle School Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009358	6/2/2020	6/2/2021	1	Break Room	In staff lounge in main office 1112	WF-06022020-009358	5/5/2021	FT-FY21-042021-009358-A	<1	FT-FY21-042021-009358-B	<1	
WS-009365	6/2/2020	6/2/2021	1	Bottle Filler	In hallway adjacent to girls' and boys' restrooms (bottle filler)	WF-06022020-009365	5/5/2021	FT-FY21-042021-009365-A	<1	FT-FY21-042021-009365-B	<1	
WS-009379	6/2/2020	6/2/2021	1	Break Room	In staff workroom 1417	WF-06022020-009379	5/5/2021	FT-FY21-042021-009379-A	<1	FT-FY21-042021-009379-B	<1	
WS-009381	6/2/2020	6/2/2021	Basement	Bottle Filler	In hallway across from room L201 (bottle filler)	WF-06022020-009381	5/5/2021	FT-FY21-042021-009381-A	<1	FT-FY21-042021-009381-B	<1	
WS-009385	6/2/2020	6/2/2021	Basement	Cooler	In hallway across from room L201	Low Left	WF-06022020-009385	5/5/2021	FT-FY21-042021-009385-A	<1	FT-FY21-042021-009385-B	<1
WS-009386	6/2/2020	6/2/2021	Basement	Cooler	In hallway across from room L201	High Left	WF-06022020-009386	5/5/2021	FT-FY21-042021-009386-A	<1	FT-FY21-042021-009386-B	<1
WS-010410	6/2/2020	6/2/2021	Basement	Health Suite	In health suite L202	WF-06022020-010410	5/5/2021	FT-FY21-042021-010410-A	<1	FT-FY21-042021-010410-B	<1	
WS-010411	6/2/2020	6/2/2021	Basement	Bottle Filler	In hallway adjacent to girls' and boys' restrooms (bottle filler)	WF-06022020-010411	5/5/2021	FT-FY21-042021-010411-A	<1	FT-FY21-042021-010411-B	<1	
WS-010418	6/2/2020	6/2/2021	Basement	Break Room	In staff workroom L417	WF-06022020-010418	5/5/2021	FT-FY21-042021-010418-A	<1	FT-FY21-042021-010418-B	<1	
WS-010430	6/2/2020	6/2/2021	2	Bottle Filler	In hallway adjacent to boys' restrooms (bottle filler)	WF-06022020-010430	5/5/2021	FT-FY21-042021-010430-A	<1	FT-FY21-042021-010430-B	<1	
WS-010438	6/2/2020	6/2/2021	2	Break Room	In staff workroom 2417	WF-06022020-010438	5/5/2021	FT-FY21-042021-010438-A	<1	FT-FY21-042021-010438-B	<1	
WS-010453	6/2/2020	6/2/2021	2	Break Room	In staff lounge 2213	WF-06022020-010453	5/5/2021	FT-FY21-042021-010453-A	<1	FT-FY21-042021-010453-B	<1	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009360	2/10/2021	2/10/2022	1	Food Prep Sink	In kitchen on wall adjacent to icemaker	WF-02102021-009360	5/5/2021	FT-FY21-042021-009360-A	<1	FT-FY21-042021-009360-B	<1
WS-009361	2/10/2021	2/10/2022	1	Food Prep Sink	In kitchen on island	WF-02102021-009361	5/5/2021	FT-FY21-042021-009361-A	<1	FT-FY21-042021-009361-B	<1