



Brookland Middle School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-009358	4/25/2022	4/25/2023	1	Break Room	In staff lounge in main office 1112	WF-04252022-009358	1/31/2023	FT-FY23-01102023-009358-A	<1	FT-FY23-01102023-009358-B	<1	
WS-009365	4/25/2022	4/25/2023	1	Bottle Filler	In hallway adjacent to girls' and boys' restrooms (bottle filler)	WF-04252022-009365	1/31/2023	FT-FY23-01102023-009365-A	<1	FT-FY23-01102023-009365-B	<1	
WS-009366	4/25/2022	4/25/2023	1	Cooler	In hallway adjacent to girls' and boys' restrooms	High Left	WF-04252022-009366	1/31/2023	FT-FY23-01102023-009366-A	<1	FT-FY23-01102023-009366-B	<1
WS-009367	4/25/2022	4/25/2023	1	Cooler	In hallway adjacent to girls' and boys' restrooms	Low Right	WF-04252022-009367	1/31/2023	FT-FY23-01102023-009367-A	<1	FT-FY23-01102023-009367-B	<1
WS-009369	4/25/2022	4/25/2023	1	Cooler	In hallway across from room 1303	High Left	WF-04252022-009369	1/31/2023	FT-FY23-01102023-009369-A	<1	FT-FY23-01102023-009369-B	<1
WS-009370	4/25/2022	4/25/2023	1	Cooler	In hallway across from room 1303	Low Right	WF-04252022-009370	1/31/2023	FT-FY23-01102023-009370-A	<1	FT-FY23-01102023-009370-B	<1
WS-009379	4/25/2022	4/25/2023	1	Break Room	In staff workroom 1417	WF-04252022-009379	1/31/2023	FT-FY23-01102023-009379-A	<1	FT-FY23-01102023-009379-B	<1	
WS-009381	4/25/2022	4/25/2023	Basement	Bottle Filler	In hallway across from room L201 (bottle filler)	WF-04252022-009381	1/31/2023	FT-FY23-01102023-009381-A	<1	FT-FY23-01102023-009381-B	<1	
WS-009385	4/25/2022	4/25/2023	Basement	Cooler	In hallway across from room L201	Low Left	WF-04252022-009385	1/31/2023	FT-FY23-01102023-009385-A	<1	FT-FY23-01102023-009385-B	<1
WS-009386	4/25/2022	4/25/2023	Basement	Cooler	In hallway across from room L201	High Left	WF-04252022-009386	1/31/2023	FT-FY23-01102023-009386-A	<1	FT-FY23-01102023-009386-B	<1
WS-010410	4/25/2022	4/25/2023	Basement	Health Suite	In health suite L202	WF-04252022-010410	1/31/2023	FT-FY23-01102023-010410-A	<1	FT-FY23-01102023-010410-B	<1	
WS-010411	4/25/2022	4/25/2023	Basement	Bottle Filler	In hallway adjacent to girls' and boys' restrooms (bottle filler)	WF-04252022-010411	1/31/2023	FT-FY23-01102023-010411-A	<1	FT-FY23-01102023-010411-B	<1	
WS-010412	4/25/2022	4/25/2023	Basement	Cooler	In hallway adjacent to girls' and boys' restrooms	High Left	WF-04252022-010412	1/31/2023	FT-FY23-01102023-010412-A	<1	FT-FY23-01102023-010412-B	<1
WS-010413	4/25/2022	4/25/2023	Basement	Cooler	In hallway adjacent to girls' and boys' restrooms	Low Right	WF-04252022-010413	1/31/2023	FT-FY23-01102023-010413-A	<1	FT-FY23-01102023-010413-B	<1
WS-010415	4/25/2022	4/25/2023	Basement	Bottle Filler	In hallway across from room L303 C wing (bottle filler)	WF-04252022-010415	1/31/2023	FT-FY23-01102023-010415-A	<1	FT-FY23-01102023-010415-B	<1	
WS-010416	4/25/2022	4/25/2023	Basement	Cooler	In hallway across from room L303 C wing	Low Right	WF-04252022-010416	1/31/2023	FT-FY23-01102023-010416-A	<1	FT-FY23-01102023-010416-B	<1
WS-010417	4/25/2022	4/25/2023	Basement	Cooler	In hallway across from room L303 C wing	High Left	WF-04252022-010417	1/31/2023	FT-FY23-01102023-010417-A	<1	FT-FY23-01102023-010417-B	<1
WS-010418	4/25/2022	4/25/2023	Basement	Break Room	In staff workroom L417	WF-04252022-010418	1/31/2023	FT-FY23-01102023-010418-A	<1	FT-FY23-01102023-010418-B	<1	
WS-010430	4/25/2022	4/25/2023	2	Bottle Filler	In hallway adjacent to boys' restrooms (bottle filler)	WF-04252022-010430	1/31/2023	FT-FY23-01102023-010430-A	<1	FT-FY23-01102023-010430-B	<1	
WS-010431	4/25/2022	4/25/2023	2	Cooler	In hallway adjacent to boys' restroom	High Left	WF-04252022-010431	1/31/2023	FT-FY23-01102023-010431-A	<1	FT-FY23-01102023-010431-B	<1
WS-010432	4/25/2022	4/25/2023	2	Cooler	In hallway adjacent to boys' restroom	Low Right	WF-04252022-010432	1/31/2023	FT-FY23-01102023-010432-A	<1	FT-FY23-01102023-010432-B	<1
WS-010436	4/25/2022	4/25/2023	2	Cooler	In hallway across from room 2305	High Left	WF-04252022-010436	1/31/2023	FT-FY23-01102023-010436-A	<1	FT-FY23-01102023-010436-B	<1
WS-010437	4/25/2022	4/25/2023	2	Cooler	In hallway across from room 2305	Low Right	WF-04252022-010437	1/31/2023	FT-FY23-01102023-010437-A	<1	FT-FY23-01102023-010437-B	<1
WS-010438	4/25/2022	4/25/2023	2	Break Room	In staff workroom 2417	WF-04252022-010438	1/31/2023	FT-FY23-01102023-010438-A	<1	FT-FY23-01102023-010438-B	<1	
WS-010453	4/25/2022	4/25/2023	2	Break Room	In staff lounge 2213	WF-04252022-010453	1/31/2023	FT-FY23-01102023-010453-A	<1	FT-FY23-01102023-010453-B	1.3	

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-009360	1/9/2023	1/9/2024	1	Food Prep Sink	In kitchen on wall adjacent to icemaker	WF-01092023-009360	1/31/2023	FT-FY23-01102023-009360-A	<1	FT-FY23-01102023-009360-B	<1
WS-009361	1/9/2023	1/9/2024	1	Food Prep Sink	In kitchen on island	WF-01092023-009361	1/31/2023	FT-FY23-01102023-009361-A	<1	FT-FY23-01102023-009361-B	<1