



Browne Education Campus Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015950	12/19/2024	12/19/2025	Basement	Bottle Filler	In hallway adjacent to room G010	WF-12192024-015950	1/6/2025	FT-FY25-12202024-015950-A	<2	FT-FY25-12202024-015950-B	<2
WS-015951	12/19/2024	12/19/2025	Basement	Cooler	In hallway adjacent to room G010 High Left	WF-12192024-015951	1/6/2025	FT-FY25-12202024-015951-A	<2	FT-FY25-12202024-015951-B	<2
WS-015952	12/19/2024	12/19/2025	Basement	Cooler	In hallway adjacent to room G010 Low Right	WF-12192024-015952	1/6/2025	FT-FY25-12202024-015952-A	<2	FT-FY25-12202024-015952-B	<2
WS-015953	12/19/2024	12/19/2025	Basement	Bottle Filler	In room G010 weight room	WF-12192024-015953	1/6/2025	FT-FY25-12202024-015953-A	<2	FT-FY25-12202024-015953-B	<2
WS-015954	12/19/2024	12/19/2025	Basement	Cooler	In room G010 weight room High Left	WF-12192024-015954	1/6/2025	FT-FY25-12202024-015954-A	<2	FT-FY25-12202024-015954-B	<2
WS-015955	12/19/2024	12/19/2025	Basement	Cooler	In room G010 weight room Low Right	WF-12192024-015955	1/6/2025	FT-FY25-12202024-015955-A	<2	FT-FY25-12202024-015955-B	<2
WS-015956	12/19/2024	12/19/2025	Basement	Bottle Filler	In hallway adjacent to room G002	WF-12192024-015956	1/6/2025	FT-FY25-12202024-015956-A	<2	FT-FY25-12202024-015956-B	<2
WS-015957	12/19/2024	12/19/2025	Basement	Cooler	In hallway adjacent to room G002 High Left	WF-12192024-015957	1/6/2025	FT-FY25-12202024-015957-A	<2	FT-FY25-12202024-015957-B	<2
WS-015958	12/19/2024	12/19/2025	Basement	Cooler	In hallway adjacent to room G002 Low Right	WF-12192024-015958	1/6/2025	FT-FY25-12202024-015958-A	<2	FT-FY25-12202024-015958-B	<2
WS-015959	12/19/2024	12/19/2025	Basement	Bottle Filler	In hallway between restrooms outside gym	WF-12192024-015959	1/6/2025	FT-FY25-12202024-015959-A	<2	FT-FY25-12202024-015959-B	<2
WS-015960	12/19/2024	12/19/2025	Basement	Cooler	In hallway between restrooms outside gym High Left	WF-12192024-015960	1/6/2025	FT-FY25-12202024-015960-A	<2	FT-FY25-12202024-015960-B	<2
WS-015961	12/19/2024	12/19/2025	Basement	Cooler	In hallway between restrooms outside gym Low Right	WF-12192024-015961	1/6/2025	FT-FY25-12202024-015961-A	<2	FT-FY25-12202024-015961-B	<2
WS-015966	12/19/2024	12/19/2025	Basement	Bottle Filler	In cafeteria	WF-12192024-015966	1/6/2025	FT-FY25-12202024-015966-A	<2	FT-FY25-12202024-015966-B	<2
WS-015967	12/19/2024	12/19/2025	Basement	Cooler	In cafeteria High Left	WF-12192024-015967	1/6/2025	FT-FY25-12202024-015967-A	<2	FT-FY25-12202024-015967-B	<2
WS-015968	12/19/2024	12/19/2025	Basement	Cooler	In cafeteria Low Right	WF-12192024-015968	1/6/2025	FT-FY25-12202024-015968-A	<2	FT-FY25-12202024-015968-B	<2
WS-015974	12/19/2024	12/19/2025	Basement	Bottle Filler	In hallway adjacent to room G050	WF-12192024-015974	1/6/2025	FT-FY25-12202024-015974-A	<2	FT-FY25-12202024-015974-B	<2
WS-015975	12/19/2024	12/19/2025	Basement	Cooler	In hallway adjacent to room G050	WF-12192024-015975	1/6/2025	FT-FY25-12202024-015975-A	<2	FT-FY25-12202024-015975-B	<2
WS-015977	12/19/2024	12/19/2025	Basement	Bottle Filler	In room G050	WF-12192024-015977	1/6/2025	FT-FY25-12202024-015977-A	<2	FT-FY25-12202024-015977-B	<2
WS-015978	12/19/2024	12/19/2025	Basement	Cooler	In room G050	WF-12192024-015978	1/6/2025	FT-FY25-12202024-015978-A	<2	FT-FY25-12202024-015978-B	<2
WS-015979	12/19/2024	12/19/2025	Basement	Bottle Filler	In room G040	WF-12192024-015979	1/6/2025	FT-FY25-12202024-015979-A	<2	FT-FY25-12202024-015979-B	<2
WS-015980	12/19/2024	12/19/2025	Basement	Cooler	In room G040	WF-12192024-015980	1/6/2025	FT-FY25-12202024-015980-A	<2	FT-FY25-12202024-015980-B	<2
WS-015986	12/19/2024	12/19/2025	1	Bottle Filler	In hallway adjacent to room 122	WF-12192024-015986	1/6/2025	FT-FY25-12202024-015986-A	<2	FT-FY25-12202024-015986-B	<2
WS-015987	12/19/2024	12/19/2025	1	Cooler	In hallway adjacent to room 122 High Left	WF-12192024-015987	1/6/2025	FT-FY25-12202024-015987-A	<2	FT-FY25-12202024-015987-B	<2
WS-015988	12/19/2024	12/19/2025	1	Cooler	In hallway adjacent to room 122 Low Right	WF-12192024-015988	1/6/2025	FT-FY25-12202024-015988-A	<2	FT-FY25-12202024-015988-B	<2
WS-015992	12/19/2024	12/19/2025	1	Combo Fountain	In room 168	WF-12192024-015992	1/6/2025	FT-FY25-12202024-015992-A	<2	FT-FY25-12202024-015992-B	<2
WS-015994	12/19/2024	12/19/2025	1	Bottle Filler	In hallway across from room 168	WF-12192024-015994	1/6/2025	FT-FY25-12202024-015994-A	<2	FT-FY25-12202024-015994-B	<2
WS-015995	12/19/2024	12/19/2025	1	Cooler	In hallway across from room 168	WF-12192024-015995	1/6/2025	FT-FY25-12202024-015995-A	<2	FT-FY25-12202024-015995-B	<2
WS-015997	12/19/2024	12/19/2025	1	Combo Fountain	In room 162	WF-12192024-015997	1/6/2025	FT-FY25-12202024-015997-A	2.0	FT-FY25-12202024-015997-B	<2
WS-015999	12/19/2024	12/19/2025	1	Bottle Filler	In hallway adjacent to room 158	WF-12192024-015999	1/6/2025	FT-FY25-12202024-015999-A	<2	FT-FY25-12202024-015999-B	<2
WS-016087	12/19/2024	12/19/2025	1	Cooler	In hallway adjacent to room 158	WF-12192024-016087	1/6/2025	FT-FY25-12202024-016087-A	<2	FT-FY25-12202024-016087-B	<2
WS-016091	12/19/2024	12/19/2025	1	Combo Fountain	In room 152	WF-12192024-016091	1/6/2025	FT-FY25-12202024-016091-A	<2	FT-FY25-12202024-016091-B	<2
WS-016095	12/19/2024	12/19/2025	1	Combo Fountain	In room 150	WF-12192024-016095	1/6/2025	FT-FY25-12202024-016095-A	<2	FT-FY25-12202024-016095-B	<2
WS-016097	12/19/2024	12/19/2025	1	Combo Fountain	In room 146	WF-12192024-016097	1/6/2025	FT-FY25-12202024-016097-A	<2	FT-FY25-12202024-016097-B	<2

WS-016101	12/19/2024	12/19/2025	1	Combo Fountain	In room 144		WF-12192024-016101	1/6/2025	FT-FY25-12202024-016101-A	<2	FT-FY25-12202024-016101-B	<2
WS-016103	12/19/2024	12/19/2025	1	Combo Fountain	In room 140		WF-12192024-016103	1/6/2025	FT-FY25-12202024-016103-A	<2	FT-FY25-12202024-016103-B	<2
WS-016105	12/19/2024	12/19/2025	1	Bottle Filler	In hallway across from stairwell A5		WF-12192024-016105	1/6/2025	FT-FY25-12202024-016105-A	<2	FT-FY25-12202024-016105-B	<2
WS-016106	12/19/2024	12/19/2025	1	Cooler	In hallway across from stairwell A5	High Left	WF-12192024-016106	1/6/2025	FT-FY25-12202024-016106-A	<2	FT-FY25-12202024-016106-B	<2
WS-016107	12/19/2024	12/19/2025	1	Cooler	In hallway across from stairwell A5	Low Right	WF-12192024-016107	1/6/2025	FT-FY25-12202024-016107-A	<2	FT-FY25-12202024-016107-B	<2
WS-016108	12/19/2024	12/19/2025	1	Bottle Filler	In hallway adjacent to room MA177		WF-12192024-016108	1/6/2025	FT-FY25-12202024-016108-A	<2	FT-FY25-12202024-016108-B	<2
WS-016109	12/19/2024	12/19/2025	1	Cooler	In hallway adjacent to room MA177	High Left	WF-12192024-016109	1/6/2025	FT-FY25-12202024-016109-A	<2	FT-FY25-12202024-016109-B	<2
WS-016110	12/19/2024	12/19/2025	1	Cooler	In hallway adjacent to room MA177	Low Right	WF-12192024-016110	1/6/2025	FT-FY25-12202024-016110-A	<2	FT-FY25-12202024-016110-B	<2
WS-016113	12/19/2024	12/19/2025	1	Combo Fountain	In room 170		WF-12192024-016113	1/6/2025	FT-FY25-12202024-016113-A	<2	FT-FY25-12202024-016113-B	<2
WS-016115	12/19/2024	12/19/2025	1	Combo Fountain	In room 179		WF-12192024-016115	1/6/2025	FT-FY25-12202024-016115-A	4.3	FT-FY25-12202024-016115-B	<2
WS-016118	12/19/2024	12/19/2025	1	Combo Fountain	In room 172 teacher collaboration		WF-12192024-016118	1/6/2025	FT-FY25-12202024-016118-A	4.0	FT-FY25-12202024-016118-B	<2
WS-016129	12/19/2024	12/19/2025	1	Bottle Filler	In hallway adjacent to room CDC-107		WF-12192024-016129	1/6/2025	FT-FY25-12202024-016129-A	<2	FT-FY25-12202024-016129-B	<2
WS-016130	12/19/2024	12/19/2025	1	Cooler	In hallway adjacent to room CDC-107		WF-12192024-016130	1/6/2025	FT-FY25-12202024-016130-A	<2	FT-FY25-12202024-016130-B	<2
WS-016131	12/19/2024	12/19/2025	1	Bottle Filler	In hallway adjacent to room 133		WF-12192024-016131	1/6/2025	FT-FY25-12202024-016131-A	<2	FT-FY25-12202024-016131-B	<2
WS-016132	12/19/2024	12/19/2025	1	Cooler	In hallway adjacent to room 133	High Left	WF-12192024-016132	1/6/2025	FT-FY25-12202024-016132-A	<2	FT-FY25-12202024-016132-B	<2
WS-016133	12/19/2024	12/19/2025	1	Cooler	In hallway adjacent to room 133	Low Right	WF-12192024-016133	1/6/2025	FT-FY25-12202024-016133-A	<2	FT-FY25-12202024-016133-B	<2
WS-016135	12/19/2024	12/19/2025	1	Combo Fountain	In room 132		WF-12192024-016135	1/6/2025	FT-FY25-12202024-016135-A	<2	FT-FY25-12202024-016135-B	<2
WS-016139	12/19/2024	12/19/2025	1	Combo Fountain	In room 134		WF-12192024-016139	1/6/2025	FT-FY25-12202024-016139-A	<2	FT-FY25-12202024-016139-B	<2
WS-016141	12/19/2024	12/19/2025	2	Combo Fountain	In room 224		WF-12192024-016141	1/6/2025	FT-FY25-12202024-016141-A	<2	FT-FY25-12202024-016141-B	<2
WS-016143	12/19/2024	12/19/2025	2	Combo Fountain	In room 222		WF-12192024-016143	1/6/2025	FT-FY25-12202024-016143-A	<2	FT-FY25-12202024-016143-B	<2
WS-016145	12/19/2024	12/19/2025	2	Combo Fountain	In room 220		WF-12192024-016145	1/6/2025	FT-FY25-12202024-016145-A	<2	FT-FY25-12202024-016145-B	<2
WS-016147	12/19/2024	12/19/2025	2	Combo Fountain	In room 206		WF-12192024-016147	1/6/2025	FT-FY25-12202024-016147-A	<2	FT-FY25-12202024-016147-B	<2
WS-016149	12/19/2024	12/19/2025	2	Combo Fountain	In room 204		WF-12192024-016149	1/6/2025	FT-FY25-12202024-016149-A	<2	FT-FY25-12202024-016149-B	<2
WS-016206	12/19/2024	12/19/2025	2	Combo Fountain	In room 202		WF-12192024-016206	1/6/2025	FT-FY25-12202024-016206-A	<2	FT-FY25-12202024-016206-B	<2
WS-016210	12/19/2024	12/19/2025	2	Combo Fountain	In room 268		WF-12192024-016210	1/6/2025	FT-FY25-12202024-016210-A	<2	FT-FY25-12202024-016210-B	<2
WS-016211	12/19/2024	12/19/2025	2	Bottle Filler	In hallway adjacent to room 267		WF-12192024-016211	1/6/2025	FT-FY25-12202024-016211-A	<2	FT-FY25-12202024-016211-B	<2
WS-016212	12/19/2024	12/19/2025	2	Cooler	In hallway adjacent to room 267		WF-12192024-016212	1/6/2025	FT-FY25-12202024-016212-A	<2	FT-FY25-12202024-016212-B	<2
WS-016220	12/19/2024	12/19/2025	2	Bottle Filler	In hallway adjacent to room 254		WF-12192024-016220	1/6/2025	FT-FY25-12202024-016220-A	<2	FT-FY25-12202024-016220-B	<2
WS-016221	12/19/2024	12/19/2025	2	Cooler	In hallway adjacent to room 254		WF-12192024-016221	1/6/2025	FT-FY25-12202024-016221-A	<2	FT-FY25-12202024-016221-B	<2
WS-016222	12/19/2024	12/19/2025	2	Bottle Filler	In hallway adjacent to room 249		WF-12192024-016222	1/6/2025	FT-FY25-12202024-016222-A	<2	FT-FY25-12202024-016222-B	<2
WS-016223	12/19/2024	12/19/2025	2	Cooler	In hallway adjacent to room 249		WF-12192024-016223	1/6/2025	FT-FY25-12202024-016223-A	<2	FT-FY25-12202024-016223-B	<2
WS-016224	12/19/2024	12/19/2025	2	Bottle Filler	In hallway adjacent to room 243		WF-12192024-016224	1/6/2025	FT-FY25-12202024-016224-A	<2	FT-FY25-12202024-016224-B	<2
WS-016225	12/19/2024	12/19/2025	2	Cooler	In hallway adjacent to room 243		WF-12192024-016225	1/6/2025	FT-FY25-12202024-016225-A	<2	FT-FY25-12202024-016225-B	<2
WS-016227	12/19/2024	12/19/2025	2	Combo Fountain	In room 240	Left	WF-12192024-016227	1/6/2025	FT-FY25-12202024-016227-A	<2	FT-FY25-12202024-016227-B	<2
WS-016229	12/19/2024	12/19/2025	2	Combo Fountain	In room 240	Right	WF-12192024-016229	1/6/2025	FT-FY25-12202024-016229-A	<2	FT-FY25-12202024-016229-B	<2
WS-016231	12/19/2024	12/19/2025	2	Combo Fountain	In room 236		WF-12192024-016231	1/6/2025	FT-FY25-12202024-016231-A	<2	FT-FY25-12202024-016231-B	<2
WS-016233	12/19/2024	12/19/2025	2	Combo Fountain	In room 232		WF-12192024-016233	1/6/2025	FT-FY25-12202024-016233-A	<2	FT-FY25-12202024-016233-B	<2
WS-016234	12/19/2024	12/19/2025	2	Bottle Filler	In hallway adjacent to room 233		WF-12192024-016234	1/6/2025	FT-FY25-12202024-016234-A	<2	FT-FY25-12202024-016234-B	<2
WS-016235	12/19/2024	12/19/2025	2	Cooler	In hallway adjacent to room 233	High Left	WF-12192024-016235	1/6/2025	FT-FY25-12202024-016235-A	<2	FT-FY25-12202024-016235-B	<2

WS-016236	12/19/2024	12/19/2025	2	Cooler	In hallway adjacent to room 233	Low Right	WF-12192024-016236	1/6/2025	FT-FY25-12202024-016236-A	<2	FT-FY25-12202024-016236-B	<2
WS-016238	12/19/2024	12/19/2025	2	Combo Fountain	In room 230		WF-12192024-016238	1/6/2025	FT-FY25-12202024-016238-A	<2	FT-FY25-12202024-016238-B	<2
WS-016239	12/19/2024	12/19/2025	Basement	Combo Fountain	In room G021		WF-12192024-016239	1/6/2025	FT-FY25-12202024-016239-A	<2	FT-FY25-12202024-016239-B	<2
WS-016240	12/19/2024	12/19/2025	Basement	Combo Fountain	In room G023		WF-12192024-016240	1/6/2025	FT-FY25-12202024-016240-A	<2	FT-FY25-12202024-016240-B	<2
WS-016241	12/19/2024	12/19/2025	1	Combo Fountain	In room CDC-104		WF-12192024-016241	1/6/2025	FT-FY25-12202024-016241-A	<2	FT-FY25-12202024-016241-B	<2
WS-016242	12/19/2024	12/19/2025	1	Combo Fountain	In room CDC-102		WF-12192024-016242	1/6/2025	FT-FY25-12202024-016242-A	<2	FT-FY25-12202024-016242-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015972	12/19/2024	12/19/2025	Basement	Food Prep Sink	In back of kitchen	WF-12192024-015972	1/6/2025	FT-FY25-12202024-015972-A	2.9	FT-FY25-12202024-015972-B	<2
WS-015973	12/19/2024	12/19/2025	Basement	Food Prep Sink	On kitchen island	WF-12192024-015973	1/6/2025	FT-FY25-12202024-015973-A	<2	FT-FY25-12202024-015973-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.