



# Browne EC Lead in Water Test Results



## FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000720	9/9/2019	9/9/2020	1	Bathroom	In classroom 1-103 in bathroom	WF-09092019-000720	12/27/2019	FT-FY20-122019-000720-A	1.5	FT-FY20-122019-000720-B	<1
WS- 000721	9/9/2019	9/9/2020	1	Bathroom	In classroom 1-108 in bathroom	WF-09092019-000721	12/27/2019	FT-FY20-122019-000721-A	<1	FT-FY20-122019-000721-B	<1
WS- 000722	9/9/2019	9/9/2020	1	Bathroom	In classroom 1-111 in bathroom	WF-09092019-000722	12/27/2019	FT-FY20-122019-000722-A	<1	FT-FY20-122019-000722-B	<1
WS- 000723	9/9/2019	9/9/2020	1	Bathroom	In classroom 1-119 in bathroom	WF-09092019-000723	12/27/2019	FT-FY20-122019-000723-A	<1	FT-FY20-122019-000723-B	<1
WS- 000724	9/9/2019	9/9/2020	1	Bathroom	In classroom 1-124 in bathroom	WF-09092019-000724	12/27/2019	FT-FY20-122019-000724-A	<1	FT-FY20-122019-000724-B	<1
WS- 000725	9/9/2019	9/9/2020	1	Bathroom	In classroom 1-128 in bathroom	WF-09092019-000725	12/27/2019	FT-FY20-122019-000725-A	<1	FT-FY20-122019-000725-B	<1
WS- 000726	9/9/2019	9/9/2020	1	Bathroom	In classroom 1-137 in bathroom	WF-09092019-000726	12/27/2019	FT-FY20-122019-000726-A	2.4	FT-FY20-122019-000726-B	<1
WS- 000727	9/9/2019	9/9/2020	1	Bathroom	In classroom 1-140 in bathroom	WF-09092019-000727	12/27/2019	FT-FY20-122019-000727-A	1.1	FT-FY20-122019-000727-B	<1
WS- 000728	9/9/2019	9/9/2020	1	Bathroom	In social worker room 1-112 in bathroom	WF-09092019-000728	12/27/2019	FT-FY20-122019-000728-A	3.2	FT-FY20-122019-000728-B	<1
WS- 000731	9/9/2019	9/9/2020	1	Bathroom	In Pre-K classroom 1-099 in bathroom	WF-09092019-000731	12/27/2019	FT-FY20-122019-000731-A	<1	FT-FY20-122019-000731-B	<1
WS- 000735	4/15/2019	4/15/2020	Basement	Cooler	In cafeteria on south wall	WF-04152019-000735	12/27/2019	FT-FY20-122019-000735-A	<1	FT-FY20-122019-000735-B	<1
WS- 000736	4/15/2019	4/15/2020	Basement	Cooler	In cafeteria on north wall	WF-04152019-000736	12/27/2019	FT-FY20-122019-000736-A	<1	FT-FY20-122019-000736-B	<1
WS- 000737	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to room 1-124	WF-04152019-000737	12/27/2019	FT-FY20-122019-000737-A	<1	FT-FY20-122019-000737-B	<1
WS- 000738	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 1-124	WF-04152019-000738	12/27/2019	FT-FY20-122019-000738-A	<1	FT-FY20-122019-000738-B	<1
WS- 000739	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 1-124	WF-09092019-000739	12/27/2019	FT-FY20-122019-000739-A	<1	FT-FY20-122019-000739-B	<1
WS- 000741	4/15/2019	4/15/2020	Basement	Cooler	In gym	WF-04152019-000741	12/27/2019	FT-FY20-122019-000741-A	<1	FT-FY20-122019-000741-B	<1
WS- 000743	4/15/2019	4/15/2020	Basement	Cooler	In boys' locker room	WF-04152019-000743	12/27/2019	FT-FY20-122019-000743-A	<1	FT-FY20-122019-000743-B	<1
WS- 000744	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to room 1-119	WF-04152019-000744	12/27/2019	FT-FY20-122019-000744-A	<1	FT-FY20-122019-000744-B	<1
WS- 000745	4/15/2019	4/15/2020	1	Combo Fountain	In social worker room 1-112	WF-04152019-000745	12/27/2019	FT-FY20-122019-000745-A	<1	FT-FY20-122019-000745-B	<1
WS- 000747	9/9/2019	9/9/2020	1	Combo Faucet	In Pre-K classroom 1-099	WF-09092019-000747	12/27/2019	FT-FY20-122019-000747-A	<1	FT-FY20-122019-000747-B	<1
WS- 000748	4/15/2019	4/15/2020	1	Combo Fountain	In Pre-K classroom 1-099	WF-04152019-000748	12/27/2019	FT-FY20-122019-000748-A	<1	FT-FY20-122019-000748-B	<1
WS- 000749	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 1-111	WF-04152019-000749	12/27/2019	FT-FY20-122019-000749-A	<1	FT-FY20-122019-000749-B	<1
WS- 000750	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 1-111	WF-09092019-000750	12/27/2019	FT-FY20-122019-000750-A	<1	FT-FY20-122019-000750-B	<1
WS- 000751	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to room 1-108	WF-04152019-000751	12/27/2019	FT-FY20-122019-000751-A	<1	FT-FY20-122019-000751-B	<1
WS- 000752	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 1-108	WF-04152019-000752	12/27/2019	FT-FY20-122019-000752-A	<1	FT-FY20-122019-000752-B	<1
WS- 000753	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 1-108	WF-09092019-000753	12/27/2019	FT-FY20-122019-000753-A	<1	FT-FY20-122019-000753-B	<1
WS- 000754	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 1-140	WF-09092019-000754	12/27/2019	FT-FY20-122019-000754-A	4	FT-FY20-122019-000754-B	<1
WS- 000755	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 1-140	WF-04152019-000755	12/27/2019	FT-FY20-122019-000755-A	<1	FT-FY20-122019-000755-B	<1
WS- 000756	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 1-137	WF-04152019-000756	12/27/2019	FT-FY20-122019-000756-A	<1	FT-FY20-122019-000756-B	<1
WS- 000757	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 1-137	WF-09092019-000757	12/27/2019	FT-FY20-122019-000757-A	<1	FT-FY20-122019-000757-B	<1
WS- 000758	4/15/2019	4/15/2020	1	Health Suite	In health suite 1-154	WF-04152019-000758	12/27/2019	FT-FY20-122019-000758-A	<1	FT-FY20-122019-000758-B	<1
WS- 000759	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 1-103	WF-09092019-000759	12/27/2019	FT-FY20-122019-000759-A	<1	FT-FY20-122019-000759-B	<1
WS- 000760	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 1-103	WF-04152019-000760	12/27/2019	FT-FY20-122019-000760-A	<1	FT-FY20-122019-000760-B	<1
WS- 000761	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to room 1-157	WF-04152019-000761	12/27/2019	FT-FY20-122019-000761-A	<1	FT-FY20-122019-000761-B	<1
WS- 000762	4/15/2019	4/15/2020	1	Cooler	In hallway adjacent to room 1-179	WF-04152019-000762	12/27/2019	FT-FY20-122019-000762-A	<1	FT-FY20-122019-000762-B	<1

WS-000771	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to room 2-269	WF-04152019-000771	12/27/2019	FT-FY20-122019-000771-A	<1	FT-FY20-122019-000771-B	<1	
WS-000773	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to room 2-273	WF-04152019-000773	12/27/2019	FT-FY20-122019-000773-A	<1	FT-FY20-122019-000773-B	<1	
WS-000774	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to room 2-301	WF-04152019-000774	12/27/2019	FT-FY20-122019-000774-A	<1	FT-FY20-122019-000774-B	<1	
WS-000775	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to stairwell 6	WF-04152019-000775	12/27/2019	FT-FY20-122019-000775-A	<1	FT-FY20-122019-000775-B	<1	
WS-000778	4/15/2019	4/15/2020	2	Cooler	In hallway adjacent to room 2-217	WF-04152019-000778	12/27/2019	FT-FY20-122019-000778-A	<1	FT-FY20-122019-000778-B	<1	
WS-000783	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 1-128	WF-09092019-000783	12/27/2019	FT-FY20-122019-000783-A	<1	FT-FY20-122019-000783-B	<1	
WS-000784	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 1-128	Left	WF-04152019-000784	12/27/2019	FT-FY20-122019-000784-A	<1	FT-FY20-122019-000784-B	<1
WS-000788	4/15/2019	4/15/2020	Basement	Cooler	In girls' locker room	WF-04152019-000788	12/27/2019	FT-FY20-122019-000788-A	<1	FT-FY20-122019-000788-B	<1	
WS-000789	4/15/2019	4/15/2020	3	Cooler	In hallway adjacent to room 1	WF-04152019-000789	12/27/2019	FT-FY20-122019-000789-A	<1	FT-FY20-122019-000789-B	<1	
WS-000792	7/11/2019	7/11/2020	Basement	Food Prep Sink	In kitchen across from unisex restroom	Left	WF-07112019-000792	12/27/2019	FT-FY20-122019-000792-A	<1	FT-FY20-122019-000792-B	<1
WS-000819	9/9/2019	9/9/2020	1	Combo Faucet	In classroom 1-119	WF-09092019-000819	12/27/2019	FT-FY20-122019-000819-A	<1	FT-FY20-122019-000819-B	<1	
WS-000820	4/15/2019	4/15/2020	1	Combo Fountain	In classroom 1-119	WF-04152019-000820	12/27/2019	FT-FY20-122019-000820-A	<1	FT-FY20-122019-000820-B	<1	
WS-000821	4/15/2019	4/15/2020	3	Cooler	In hallway adjacent to room 3-328	WF-04152019-000821	12/27/2019	FT-FY20-122019-000821-A	<1	FT-FY20-122019-000821-B	<1	
WS-000823	4/15/2019	4/15/2020	3	Cooler	In hallway adjacent to room 3	WF-04152019-000823	12/27/2019	FT-FY20-122019-000823-A	<1	FT-FY20-122019-000823-B	<1	
WS-000824	4/15/2019	4/15/2020	3	Cooler	In hallway adjacent to room 3-337	WF-04152019-000824	12/27/2019	FT-FY20-122019-000824-A	<1	FT-FY20-122019-000824-B	<1	

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000732	7/11/2019	7/11/2020	Basement	Food Prep Sink	In kitchen second clockwise from entry door	Right	WF-07112019-000732	12/27/2019	FT-FY20-122019-000732-A	<1	FT-FY20-122019-000732-B	<1
WS-000734	7/9/2019	7/9/2020	Basement	Food Prep Sink	In kitchen first clockwise from entry door		WF-07092019-000734	12/27/2019	FT-FY20-122019-000734-A	<1	FT-FY20-122019-000734-B	<1

### FY20 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000746	9/9/2019	9/9/2020	1	Combo Faucet	In social worker room 1-112	WF-09092019-000746	12/27/2019	FT-FY20-122019-000746-A	8.6	FT-FY20-122019-000746-B	<1

### FY20 Filter Test (After Plumbing Check)

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000746	12/31/2019	12/31/2020	1	Combo Faucet	In social worker room 1-112	WF-12312019-000746	1/9/2020	FT-FY20-012020-000746-A	<1	FT-FY20-012020-000746-B	<1