



# Browne Education Campus Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000720	9/1/2020	9/1/2021	1	Bathroom	In classroom 1-103 in bathroom	WF-09012020-000720	2/16/2021	FT-FY21-022021-000720-A	4.7	FT-FY21-022021-000720-B	<1
WS-000723	9/1/2020	9/1/2021	1	Bathroom	In classroom 1-119 in bathroom	WF-09012020-000723	2/16/2021	FT-FY21-022021-000723-A	<1	FT-FY21-022021-000723-B	<1
WS-000724	9/1/2020	9/1/2021	1	Bathroom	In classroom 1-124 in bathroom	WF-09012020-000724	2/16/2021	FT-FY21-022021-000724-A	<1	FT-FY21-022021-000724-B	<1
WS-000725	9/1/2020	9/1/2021	1	Bathroom	In classroom 1-128 in bathroom	WF-09012020-000725	2/16/2021	FT-FY21-022021-000725-A	<1	FT-FY21-022021-000725-B	<1
WS-000726	9/1/2020	9/1/2021	1	Bathroom	In classroom 1-137 in bathroom	WF-09012020-000726	2/16/2021	FT-FY21-022021-000726-A	<1	FT-FY21-022021-000726-B	<1
WS-000727	9/1/2020	9/1/2021	1	Bathroom	In classroom 1-140 in bathroom	WF-09012020-000727	2/16/2021	FT-FY21-022021-000727-A	<1	FT-FY21-022021-000727-B	<1
WS-000728	9/1/2020	9/1/2021	1	Bathroom	In social worker room 1-112 in bathroom	WF-09012020-000728	2/16/2021	FT-FY21-022021-000728-A	1.2	FT-FY21-022021-000728-B	<1
WS-000731	9/1/2020	9/1/2021	1	Bathroom	In Pre-K classroom 1-099 in bathroom	WF-09012020-000731	2/16/2021	FT-FY21-022021-000731-A	<1	FT-FY21-022021-000731-B	<1
WS-000735	12/4/2020	12/4/2021	Basement	Cooler	In cafeteria on south wall	WF-12042020-000735	2/16/2021	FT-FY21-022021-000735-A	<1	FT-FY21-022021-000735-B	<1
WS-000736	12/4/2020	12/4/2021	Basement	Cooler	In cafeteria on north wall	WF-12042020-000736	2/16/2021	FT-FY21-022021-000736-A	<1	FT-FY21-022021-000736-B	<1
WS-000738	4/6/2020	4/6/2021	1	Combo Fountain	In classroom 1-124	WF-04062020-000738	2/16/2021	FT-FY21-022021-000738-A	<1	FT-FY21-022021-000738-B	<1
WS-000739	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 1-124	WF-09012020-000739	2/16/2021	FT-FY21-022021-000739-A	<1	FT-FY21-022021-000739-B	<1
WS-000740	12/4/2020	12/4/2021	1	Cooler	In hallway adjacent to activity center	WF-12042020-000740	2/16/2021	FT-FY21-022021-000740-A	<1	FT-FY21-022021-000740-B	<1
WS-000741	12/4/2020	12/4/2021	Basement	Cooler	In gym	WF-12042020-000741	2/16/2021	FT-FY21-022021-000741-A	<1	FT-FY21-022021-000741-B	<1
WS-000743	4/6/2020	4/6/2021	Basement	Cooler	In boys' locker room	WF-04062020-000743	2/16/2021	FT-FY21-022021-000743-A	<1	FT-FY21-022021-000743-B	<1
WS-000744	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room 1-119	WF-04062020-000744	2/16/2021	FT-FY21-022021-000744-A	<1	FT-FY21-022021-000744-B	<1
WS-000745	4/6/2020	4/6/2021	1	Combo Fountain	In social worker room 1-112	WF-04062020-000745	2/16/2021	FT-FY21-022021-000745-A	<1	FT-FY21-022021-000745-B	<1
WS-000746	9/1/2020	9/1/2021	1	Combo Faucet	In social worker room 1-112	WF-09012020-000746	2/16/2021	FT-FY21-022021-000746-A	1.7	FT-FY21-022021-000746-B	<1
WS-000747	9/1/2020	9/1/2021	1	Combo Faucet	In Pre-K classroom 1-099	WF-09012020-000747	2/16/2021	FT-FY21-022021-000747-A	<1	FT-FY21-022021-000747-B	<1
WS-000748	4/6/2020	4/6/2021	1	Combo Fountain	In Pre-K classroom 1-099	WF-04062020-000748	2/16/2021	FT-FY21-022021-000748-A	<1	FT-FY21-022021-000748-B	<1
WS-000749	4/6/2020	4/6/2021	1	Combo Fountain	In classroom 1-111	WF-04062020-000749	2/16/2021	FT-FY21-022021-000749-A	<1	FT-FY21-022021-000749-B	<1
WS-000750	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 1-111	WF-09012020-000750	2/16/2021	FT-FY21-022021-000750-A	<1	FT-FY21-022021-000750-B	<1
WS-000751	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room 1-108	WF-04062020-000751	2/16/2021	FT-FY21-022021-000751-A	<1	FT-FY21-022021-000751-B	<1
WS-000752	4/6/2020	4/6/2021	1	Combo Fountain	In classroom 1-108	WF-04062020-000752	2/16/2021	FT-FY21-022021-000752-A	<1	FT-FY21-022021-000752-B	<1
WS-000753	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 1-108	WF-09012020-000753	2/16/2021	FT-FY21-022021-000753-A	<1	FT-FY21-022021-000753-B	<1
WS-000754	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 1-140	WF-09012020-000754	2/16/2021	FT-FY21-022021-000754-A	1.2	FT-FY21-022021-000754-B	<1
WS-000755	4/6/2020	4/6/2021	1	Combo Fountain	In classroom 1-140	WF-04062020-000755	2/16/2021	FT-FY21-022021-000755-A	<1	FT-FY21-022021-000755-B	<1
WS-000756	4/6/2020	4/6/2021	1	Combo Fountain	In classroom 1-137	WF-04062020-000756	2/16/2021	FT-FY21-022021-000756-A	<1	FT-FY21-022021-000756-B	<1
WS-000757	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 1-137	WF-09012020-000757	2/16/2021	FT-FY21-022021-000757-A	<1	FT-FY21-022021-000757-B	<1
WS-000758	4/6/2020	4/6/2021	1	Health Suite	In health suite 1-154	WF-04062020-000758	2/16/2021	FT-FY21-022021-000758-A	<1	FT-FY21-022021-000758-B	<1
WS-000759	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 1-103	WF-09012020-000759	2/16/2021	FT-FY21-022021-000759-A	<1	FT-FY21-022021-000759-B	<1
WS-000760	4/6/2020	4/6/2021	1	Combo Fountain	In classroom 1-103	WF-04062020-000760	2/16/2021	FT-FY21-022021-000760-A	<1	FT-FY21-022021-000760-B	<1

WS-000761	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room 1-157	WF-04062020-000761	2/16/2021	FT-FY21-022021-000761-A	<1	FT-FY21-022021-000761-B	<1	
WS-000762	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room 1-179	WF-04062020-000762	2/16/2021	FT-FY21-022021-000762-A	<1	FT-FY21-022021-000762-B	<1	
WS-000763	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room 1-193	WF-04062020-000763	2/16/2021	FT-FY21-022021-000763-A	<1	FT-FY21-022021-000763-B	<1	
WS-000770	4/6/2020	4/6/2021	1	Cooler	In hallway adjacent to room 2-208	WF-04062020-000770	2/16/2021	FT-FY21-022021-000770-A	<1	FT-FY21-022021-000770-B	<1	
WS-000771	12/4/2020	12/4/2021	2	Cooler	In hallway adjacent to room 2-269	WF-12042020-000771	2/16/2021	FT-FY21-022021-000771-A	<1	FT-FY21-022021-000771-B	<1	
WS-000773	12/4/2020	12/4/2021	2	Cooler	In hallway adjacent to room 2-273	WF-12042020-000773	2/16/2021	FT-FY21-022021-000773-A	<1	FT-FY21-022021-000773-B	<1	
WS-000774	4/6/2020	4/6/2021	2	Cooler	In hallway adjacent to room 2-301	WF-04062020-000774	2/16/2021	FT-FY21-022021-000774-A	<1	FT-FY21-022021-000774-B	<1	
WS-000775	12/4/2020	12/4/2021	2	Cooler	In hallway adjacent to stairwell 6	WF-12042020-000775	2/16/2021	FT-FY21-022021-000775-A	<1	FT-FY21-022021-000775-B	<1	
WS-000776	12/4/2020	12/4/2021	2	Cooler	In hallway adjacent to room 2-235	WF-12042020-000776	2/16/2021	FT-FY21-022021-000776-A	<1	FT-FY21-022021-000776-B	<1	
WS-000777	12/4/2020	12/4/2021	2	Cooler	In hallway adjacent to room 2-213	WF-12042020-000777	2/16/2021	FT-FY21-022021-000777-A	<1	FT-FY21-022021-000777-B	<1	
WS-000778	4/6/2020	4/6/2021	2	Cooler	In hallway adjacent to room 2-217	WF-04062020-000778	2/16/2021	FT-FY21-022021-000778-A	<1	FT-FY21-022021-000778-B	<1	
WS-000783	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 1-128	WF-09012020-000783	2/16/2021	FT-FY21-022021-000783-A	<1	FT-FY21-022021-000783-B	<1	
WS-000784	4/6/2020	4/6/2021	1	Combo Fountain	In classroom 1-128	Left	WF-04062020-000784	2/16/2021	FT-FY21-022021-000784-A	<1	FT-FY21-022021-000784-B	<1
WS-000788	4/6/2020	4/6/2021	Basement	Cooler	In girls' locker room	WF-04062020-000788	2/16/2021	FT-FY21-022021-000788-A	<1	FT-FY21-022021-000788-B	<1	
WS-000793	12/4/2020	12/4/2021	2	Bottle Filler	In hallway adjacent to room 2-269	WF-12042020-000793	2/16/2021	FT-FY21-022021-000793-A	<1	FT-FY21-022021-000793-B	<1	
WS-000794	12/4/2020	12/4/2021	2	Bottle Filler	In hallway adjacent to room 2-273	WF-12042020-000794	2/16/2021	FT-FY21-022021-000794-A	<1	FT-FY21-022021-000794-B	<1	
WS-000795	12/4/2020	12/4/2021	2	Bottle Filler	In hallway adjacent to stairwell 6	WF-12042020-000795	2/16/2021	FT-FY21-022021-000795-A	<1	FT-FY21-022021-000795-B	<1	
WS-000796	12/4/2020	12/4/2021	2	Bottle Filler	In hallway adjacent to room 2-235	WF-12042020-000796	2/16/2021	FT-FY21-022021-000796-A	<1	FT-FY21-022021-000796-B	<1	
WS-000797	12/4/2020	12/4/2021	2	Bottle Filler	In hallway adjacent to room 2-213	WF-12042020-000797	2/16/2021	FT-FY21-022021-000797-A	<1	FT-FY21-022021-000797-B	<1	
WS-000798	12/4/2020	12/4/2021	1	Bottle Filler	In hallway adjacent to room 1-124	WF-12042020-000798	2/16/2021	FT-FY21-022021-000798-A	<1	FT-FY21-022021-000798-B	<1	
WS-000799	12/4/2020	12/4/2021	1	Bottle Filler	In hallway adjacent to activity center	WF-12042020-000799	2/16/2021	FT-FY21-022021-000799-A	<1	FT-FY21-022021-000799-B	<1	
WS-000800	12/4/2020	12/4/2021	Basement	Bottle Filler	In gym	WF-12042020-000800	2/16/2021	FT-FY21-022021-000800-A	<1	FT-FY21-022021-000800-B	<1	
WS-000801	12/4/2020	12/4/2021	Basement	Bottle Filler	In cafeteria on north wall	WF-12042020-000801	2/16/2021	FT-FY21-022021-000801-A	<1	FT-FY21-022021-000801-B	<1	
WS-000802	12/4/2020	12/4/2021	Basement	Bottle Filler	In cafeteria on south wall	WF-12042020-000802	2/16/2021	FT-FY21-022021-000802-A	<1	FT-FY21-022021-000802-B	<1	
WS-000819	9/1/2020	9/1/2021	1	Combo Faucet	In classroom 1-119	WF-09012020-000819	2/16/2021	FT-FY21-022021-000819-A	<1	FT-FY21-022021-000819-B	<1	
WS-000820	4/6/2020	4/6/2021	1	Combo Fountain	In classroom 1-119	WF-04062020-000820	2/16/2021	FT-FY21-022021-000820-A	<1	FT-FY21-022021-000820-B	<1	
WS-000823	4/6/2020	4/6/2021	3	Cooler	In hallway adjacent to room 3	WF-04062020-000823	2/16/2021	FT-FY21-022021-000823-A	<1	FT-FY21-022021-000823-B	<1	
WS-000824	4/6/2020	4/6/2021	3	Cooler	In hallway adjacent to room 3-337	WF-04062020-000824	2/16/2021	FT-FY21-022021-000824-A	<1	FT-FY21-022021-000824-B	<1	

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000732	2/8/2021	2/8/2022	Basement	Food Prep Sink	In kitchen second clockwise from entry door	Right	WF-02082021-000732	2/16/2021	FT-FY21-022021-000732-A	<1	FT-FY21-022021-000732-B	<1
WS-000734	2/8/2021	2/8/2022	Basement	Food Prep Sink	In kitchen first clockwise from entry door		WF-02082021-000734	2/16/2021	FT-FY21-022021-000734-A	<1	FT-FY21-022021-000734-B	<1
WS-000792	2/8/2021	2/8/2022	Basement	Food Prep Sink	In kitchen across from unisex restroom	Left	WF-02082021-000792	2/16/2021	FT-FY21-022021-000792-A	<1	FT-FY21-022021-000792-B	<1

### FY21 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000721	9/1/2020	9/1/2021	1	Bathroom	In classroom 1-108 in bathroom	WF-09012020-000721	2/16/2021	FT-FY21-022021-000721-A	10	FT-FY21-022021-000721-B	2.6
WS- 000722	9/1/2020	9/1/2021	1	Bathroom	In classroom 1-111 in bathroom	WF-09012020-000722	2/16/2021	FT-FY21-022021-000722-A	8.6	FT-FY21-022021-000722-B	1.3

### FY21 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 000721	2/27/2021	2/27/2022	1	Bathroom	In classroom 1-108 in bathroom	WF-02272021-000721	3/5/2021	FT-FY21-032021-000721-A	<1	FT-FY21-032021-000721-B	<1
WS- 000722	2/27/2021	2/27/2022	1	Bathroom	In classroom 1-111 in bathroom	WF-02272021-000722	3/5/2021	FT-FY21-032021-000722-A	<1	FT-FY21-032021-000722-B	<1