



Browne Education Campus Swing Space Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015050	4/6/2023	4/6/2024	Ground Floor	Bottle Filler	In hallway adjacent to 108A	WF-04062023-015050	12/1/2023	FT-FY24-11012023-015050-A	<1	FT-FY24-11012023-015050-B	<1	
WS-015051	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 108A	High Left	WF-04062023-015051	12/1/2023	FT-FY24-11012023-015051-A	<1	FT-FY24-11012023-015051-B	<1
WS-015052	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 108A	Low Right	WF-04062023-015052	12/1/2023	FT-FY24-11012023-015052-A	<1	FT-FY24-11012023-015052-B	<1
WS-015053	4/6/2023	4/6/2024	Ground Floor	Bottle Filler	In hallway adjacent to 111B		WF-04062023-015053	12/1/2023	FT-FY24-11012023-015053-A	<1	FT-FY24-11012023-015053-B	<1
WS-015054	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 111B	High Left	WF-04062023-015054	12/1/2023	FT-FY24-11012023-015054-A	1.0	FT-FY24-11012023-015054-B	<1
WS-015055	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 111B	Low Right	WF-04062023-015055	12/1/2023	FT-FY24-11012023-015055-A	<1	FT-FY24-11012023-015055-B	<1
WS-015056	4/6/2023	4/6/2024	Ground Floor	Health Suite	In health suite 103C		WF-04062023-015056	12/1/2023	FT-FY24-11012023-015056-A	<1	FT-FY24-11012023-015056-B	<1
WS-015058	4/6/2023	4/6/2024	Ground Floor	Bottle Filler	In hallway adjacent to 208		WF-04062023-015058	12/1/2023	FT-FY24-11012023-015058-A	<1	FT-FY24-11012023-015058-B	<1
WS-015059	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 208	High Left	WF-04062023-015059	12/1/2023	FT-FY24-11012023-015059-A	<1	FT-FY24-11012023-015059-B	<1
WS-015060	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 208	Low Right	WF-04062023-015060	12/1/2023	FT-FY24-11012023-015060-A	<1	FT-FY24-11012023-015060-B	<1
WS-015061	4/6/2023	4/6/2024	Ground Floor	Bottle Filler	In hallway adjacent to 211B		WF-04062023-015061	12/1/2023	FT-FY24-11012023-015061-A	<1	FT-FY24-11012023-015061-B	<1
WS-015062	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 211B	High Left	WF-04062023-015062	12/1/2023	FT-FY24-11012023-015062-A	<1	FT-FY24-11012023-015062-B	<1
WS-015063	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 211B	Low Right	WF-04062023-015063	12/1/2023	FT-FY24-11012023-015063-A	<1	FT-FY24-11012023-015063-B	<1
WS-015064	4/6/2023	4/6/2024	Ground Floor	Health Suite	In MES health suite 204A restroom		WF-04062023-015064	12/1/2023	FT-FY24-11012023-015064-A	<1	FT-FY24-11012023-015064-B	<1
WS-015065	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 310		WF-09252023-015065	12/1/2023	FT-FY24-11012023-015065-A	<1	FT-FY24-11012023-015065-B	<1
WS-015066	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 301		WF-09252023-015066	12/1/2023	FT-FY24-11012023-015066-A	<1	FT-FY24-11012023-015066-B	<1
WS-015067	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 309		WF-09252023-015067	12/1/2023	FT-FY24-11012023-015067-A	<1	FT-FY24-11012023-015067-B	<1
WS-015068	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 302		WF-09252023-015068	12/1/2023	FT-FY24-11012023-015068-A	<1	FT-FY24-11012023-015068-B	<1
WS-015069	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 308		WF-09252023-015069	12/1/2023	FT-FY24-11012023-015069-A	<1	FT-FY24-11012023-015069-B	<1
WS-015070	4/6/2023	4/6/2024	Ground Floor	Bottle Filler	In hallway adjacent to 302		WF-04062023-015070	12/1/2023	FT-FY24-11012023-015070-A	<1	FT-FY24-11012023-015070-B	<1
WS-015071	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 302	High Left	WF-04062023-015071	12/1/2023	FT-FY24-11012023-015071-A	<1	FT-FY24-11012023-015071-B	<1
WS-015072	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 302	Low Right	WF-04062023-015072	12/1/2023	FT-FY24-11012023-015072-A	<1	FT-FY24-11012023-015072-B	<1
WS-015073	4/6/2023	4/6/2024	Ground Floor	Bottle Filler	In hallway adjacent to 303		WF-04062023-015073	12/1/2023	FT-FY24-11012023-015073-A	<1	FT-FY24-11012023-015073-B	<1
WS-015074	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 303	High Left	WF-04062023-015074	12/1/2023	FT-FY24-11012023-015074-A	<1	FT-FY24-11012023-015074-B	<1
WS-015075	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 303	Low Right	WF-04062023-015075	12/1/2023	FT-FY24-11012023-015075-A	<1	FT-FY24-11012023-015075-B	<1
WS-015076	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 303		WF-09252023-015076	12/1/2023	FT-FY24-11012023-015076-A	<1	FT-FY24-11012023-015076-B	<1
WS-015077	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 307		WF-09252023-015077	12/1/2023	FT-FY24-11012023-015077-A	<1	FT-FY24-11012023-015077-B	<1
WS-015078	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 304		WF-09252023-015078	12/1/2023	FT-FY24-11012023-015078-A	<1	FT-FY24-11012023-015078-B	<1
WS-015079	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 306		WF-09252023-015079	12/1/2023	FT-FY24-11012023-015079-A	<1	FT-FY24-11012023-015079-B	<1
WS-015080	9/25/2023	9/25/2024	Ground Floor	Bathroom	In bathroom of room 305		WF-09252023-015080	12/1/2023	FT-FY24-11012023-015080-A	<1	FT-FY24-11012023-015080-B	<1
WS-015082	4/6/2023	4/6/2024	Ground Floor	Bottle Filler	In hallway adjacent to 408		WF-04062023-015082	12/1/2023	FT-FY24-11012023-015082-A	<1	FT-FY24-11012023-015082-B	<1
WS-015083	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 408	High Left	WF-04062023-015083	12/1/2023	FT-FY24-11012023-015083-A	<1	FT-FY24-11012023-015083-B	<1
WS-015084	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 408	Low Right	WF-04062023-015084	12/1/2023	FT-FY24-11012023-015084-A	<1	FT-FY24-11012023-015084-B	<1
WS-015085	4/6/2023	4/6/2024	Ground Floor	Bottle Filler	In hallway adjacent to 411B		WF-04062023-015085	12/1/2023	FT-FY24-11012023-015085-A	<1	FT-FY24-11012023-015085-B	<1
WS-015086	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 411B	High Left	WF-04062023-015086	12/1/2023	FT-FY24-11012023-015086-A	<1	FT-FY24-11012023-015086-B	<1

WS-015087	4/6/2023	4/6/2024	Ground Floor	Cooler	In hallway adjacent to 411B	Low Right	WF-04062023-015087	12/1/2023	FT-FY24-11012023-015087-A	<1	FT-FY24-11012023-015087-B	<1
WS-015089	10/4/2023	10/4/2024	Ground Floor	Bottle Filler	In gym/multiple purpose room		WF-10042023-015089	12/1/2023	FT-FY24-11012023-015089-A	<1	FT-FY24-11012023-015089-B	<1
WS-015090	10/4/2023	10/4/2024	Ground Floor	Cooler	In gym/multiple purpose room	High Left	WF-10042023-015090	12/1/2023	FT-FY24-11012023-015090-A	<1	FT-FY24-11012023-015090-B	<1
WS-015093	10/3/2023	10/3/2024	Ground Floor	Cooler	In annex 2 on east side of room	High Left	WF-10032023-015093	12/1/2023	FT-FY24-11012023-015093-A	<1	FT-FY24-11012023-015093-B	<1
WS-015094	10/3/2023	10/3/2024	Ground Floor	Cooler	In annex 2 on east side of room	Low Right	WF-10032023-015094	12/1/2023	FT-FY24-11012023-015094-A	<1	FT-FY24-11012023-015094-B	<1
WS-015095	10/3/2023	10/3/2024	Ground Floor	Cooler	In annex 2 on west side of room	High Left	WF-10032023-015095	12/1/2023	FT-FY24-11012023-015095-A	<1	FT-FY24-11012023-015095-B	<1
WS-015096	10/3/2023	10/3/2024	Ground Floor	Cooler	In annex 2 on west side of room	Low Right	WF-10032023-015096	12/1/2023	FT-FY24-11012023-015096-A	<1	FT-FY24-11012023-015096-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015088	1/24/2023	1/24/2024	Ground Floor	Food Prep Sink	In room 403 food prints	WF-01242023-015088	12/1/2023	FT-FY24-11012023-015088-A	<1	FT-FY24-11012023-015088-B	<1
WS-015092	1/24/2023	1/24/2024	Ground Floor	Food Prep Sink	In kitchen trailer 1st clockwise from entry	WF-01242023-015092	12/1/2023	FT-FY24-11012023-015092-A	<1	FT-FY24-11012023-015092-B	<1