



Browne EC Swing Space Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015050	4/2/2024	4/2/2025	Ground Floor	Bottle Filler	In hallway adjacent to 108A	WF-04022024-015050	12/7/2024	FT-FY25-10312024-015050-A	<2	FT-FY25-10312024-015050-B	<2
WS-015051	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 108A High Left	WF-04022024-015051	12/7/2024	FT-FY25-10312024-015051-A	<2	FT-FY25-10312024-015051-B	<2
WS-015052	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 108A Low Right	WF-04022024-015052	12/7/2024	FT-FY25-10312024-015052-A	<2	FT-FY25-10312024-015052-B	<2
WS-015053	4/2/2024	4/2/2025	Ground Floor	Bottle Filler	In hallway adjacent to 111B	WF-04022024-015053	12/7/2024	FT-FY25-10312024-015053-A	<2	FT-FY25-10312024-015053-B	<2
WS-015054	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 111B High Left	WF-04022024-015054	12/7/2024	FT-FY25-10312024-015054-A	<2	FT-FY25-10312024-015054-B	<2
WS-015055	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 111B Low Right	WF-04022024-015055	12/7/2024	FT-FY25-10312024-015055-A	<2	FT-FY25-10312024-015055-B	<2
WS-015056	4/2/2024	4/2/2025	Ground Floor	Health Suite	In health suite 103C	WF-04022024-015056	12/7/2024	FT-FY25-10312024-015056-A	<2	FT-FY25-10312024-015056-B	<2
WS-015058	4/2/2024	4/2/2025	Ground Floor	Bottle Filler	In hallway adjacent to 208	WF-04022024-015058	12/7/2024	FT-FY25-10312024-015058-A	<2	FT-FY25-10312024-015058-B	<2
WS-015059	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 208 High Left	WF-04022024-015059	12/7/2024	FT-FY25-10312024-015059-A	<2	FT-FY25-10312024-015059-B	<2
WS-015060	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 208 Low Right	WF-04022024-015060	12/7/2024	FT-FY25-10312024-015060-A	<2	FT-FY25-10312024-015060-B	<2
WS-015061	4/2/2024	4/2/2025	Ground Floor	Bottle Filler	In hallway adjacent to 211B	WF-04022024-015061	12/7/2024	FT-FY25-10312024-015061-A	<2	FT-FY25-10312024-015061-B	<2
WS-015062	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 211B High Left	WF-04022024-015062	12/7/2024	FT-FY25-10312024-015062-A	<2	FT-FY25-10312024-015062-B	<2
WS-015063	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 211B Low Right	WF-04022024-015063	12/7/2024	FT-FY25-10312024-015063-A	<2	FT-FY25-10312024-015063-B	<2
WS-015064	4/2/2024	4/2/2025	Ground Floor	Health Suite	In MES health suite 204A restroom	WF-04022024-015064	12/7/2024	FT-FY25-10312024-015064-A	<2	FT-FY25-10312024-015064-B	<2
WS-015065	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 310	WF-09232024-015065	12/7/2024	FT-FY25-10312024-015065-A	<2	FT-FY25-10312024-015065-B	<2
WS-015066	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 301	WF-09232024-015066	12/7/2024	FT-FY25-10312024-015066-A	<2	FT-FY25-10312024-015066-B	<2
WS-015067	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 309	WF-09232024-015067	12/7/2024	FT-FY25-10312024-015067-A	<2	FT-FY25-10312024-015067-B	<2
WS-015068	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 302	WF-09232024-015068	12/7/2024	FT-FY25-10312024-015068-A	<2	FT-FY25-10312024-015068-B	<2
WS-015069	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 308	WF-09232024-015069	12/7/2024	FT-FY25-10312024-015069-A	<2	FT-FY25-10312024-015069-B	<2
WS-015070	4/2/2024	4/2/2025	Ground Floor	Bottle Filler	In hallway adjacent to 302	WF-04022024-015070	12/7/2024	FT-FY25-10312024-015070-A	<2	FT-FY25-10312024-015070-B	<2
WS-015071	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 302 High Left	WF-04022024-015071	12/7/2024	FT-FY25-10312024-015071-A	<2	FT-FY25-10312024-015071-B	<2
WS-015072	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 302 Low Right	WF-04022024-015072	12/7/2024	FT-FY25-10312024-015072-A	<2	FT-FY25-10312024-015072-B	<2
WS-015073	4/2/2024	4/2/2025	Ground Floor	Bottle Filler	In hallway adjacent to 303	WF-04022024-015073	12/7/2024	FT-FY25-10312024-015073-A	<2	FT-FY25-10312024-015073-B	<2
WS-015074	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 303 High Left	WF-04022024-015074	12/7/2024	FT-FY25-10312024-015074-A	<2	FT-FY25-10312024-015074-B	<2
WS-015075	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 303 Low Right	WF-04022024-015075	12/7/2024	FT-FY25-10312024-015075-A	<2	FT-FY25-10312024-015075-B	<2
WS-015076	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 303	WF-09232024-015076	12/7/2024	FT-FY25-10312024-015076-A	<2	FT-FY25-10312024-015076-B	<2
WS-015077	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 307	WF-09232024-015077	12/7/2024	FT-FY25-10312024-015077-A	<2	FT-FY25-10312024-015077-B	<2
WS-015078	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 304	WF-09232024-015078	12/7/2024	FT-FY25-10312024-015078-A	<2	FT-FY25-10312024-015078-B	<2
WS-015079	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 306	WF-09232024-015079	12/7/2024	FT-FY25-10312024-015079-A	<2	FT-FY25-10312024-015079-B	<2
WS-015080	9/23/2024	9/23/2025	Ground Floor	Bathroom	In bathroom of room 305	WF-09232024-015080	12/7/2024	FT-FY25-10312024-015080-A	<2	FT-FY25-10312024-015080-B	<2
WS-015082	4/2/2024	4/2/2025	Ground Floor	Bottle Filler	In hallway adjacent to 408	WF-04022024-015082	12/7/2024	FT-FY25-10312024-015082-A	<2	FT-FY25-10312024-015082-B	<2
WS-015083	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 408 High Left	WF-04022024-015083	12/7/2024	FT-FY25-10312024-015083-A	<2	FT-FY25-10312024-015083-B	<2
WS-015084	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 408 Low Right	WF-04022024-015084	12/7/2024	FT-FY25-10312024-015084-A	<2	FT-FY25-10312024-015084-B	<2

WS-015085	4/2/2024	4/2/2025	Ground Floor	Bottle Filler	In hallway adjacent to 411B		WF-04022024-015085	12/7/2024	FT-FY25-10312024-015085-A	<2	FT-FY25-10312024-015085-B	<2
WS-015086	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 411B	High Left	WF-04022024-015086	12/7/2024	FT-FY25-10312024-015086-A	<2	FT-FY25-10312024-015086-B	<2
WS-015087	4/2/2024	4/2/2025	Ground Floor	Cooler	In hallway adjacent to 411B	Low Right	WF-04022024-015087	12/7/2024	FT-FY25-10312024-015087-A	<2	FT-FY25-10312024-015087-B	<2
WS-015089	4/2/2024	4/2/2025	Ground Floor	Bottle Filler	In gym/multiple purpose room		WF-04022024-015089	12/7/2024	FT-FY25-10312024-015089-A	<2	FT-FY25-10312024-015089-B	<2
WS-015090	4/2/2024	4/2/2025	Ground Floor	Cooler	In gym/multiple purpose room	High Left	WF-04022024-015090	12/7/2024	FT-FY25-10312024-015090-A	2.4	FT-FY25-10312024-015090-B	<2
WS-015093	4/2/2024	4/2/2025	Ground Floor	Cooler	In annex 2 on east side of room	High Left	WF-04022024-015093	12/7/2024	FT-FY25-10312024-015093-A	<2	FT-FY25-10312024-015093-B	<2
WS-015094	4/2/2024	4/2/2025	Ground Floor	Cooler	In annex 2 on east side of room	Low Right	WF-04022024-015094	12/7/2024	FT-FY25-10312024-015094-A	<2	FT-FY25-10312024-015094-B	<2
WS-015095	4/2/2024	4/2/2025	Ground Floor	Cooler	In annex 2 on west side of room	High Left	WF-04022024-015095	12/7/2024	FT-FY25-10312024-015095-A	<2	FT-FY25-10312024-015095-B	<2
WS-015096	4/2/2024	4/2/2025	Ground Floor	Cooler	In annex 2 on west side of room	Low Right	WF-04022024-015096	12/7/2024	FT-FY25-10312024-015096-A	<2	FT-FY25-10312024-015096-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015088	12/14/2023	12/14/2024	Ground Floor	Food Prep Sink	In room 403 food prints	WF-12142023-015088	12/7/2024	FT-FY25-10312024-015088-A	<2	FT-FY25-10312024-015088-B	<2	
WS-015092	12/14/2023	12/14/2024	Ground Floor	Food Prep Sink	In kitchen trailer 1st clockwise from entry	WF-12142023-015092	12/7/2024	FT-FY25-10312024-015092-A	<2	FT-FY25-10312024-015092-B	<2	

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.