



Browne Education Campus Swing Space Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015050	4/12/2022	4/12/2023	Ground Floor	Bottle Filler	In hallway adjacent to 108A	WF-04122022-015050	12/30/2022	FT-FY23-11182022-015050-A	<1	FT-FY23-11182022-015050-B	<1	
WS-015051	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 108A	High Left	WF-04122022-015051	12/30/2022	FT-FY23-11182022-015051-A	<1	FT-FY23-11182022-015051-B	<1
WS-015052	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 108A	Low Right	WF-04122022-015052	12/30/2022	FT-FY23-11182022-015052-A	<1	FT-FY23-11182022-015052-B	<1
WS-015053	4/12/2022	4/12/2023	Ground Floor	Bottle Filler	In hallway adjacent to 111B		WF-04122022-015053	12/30/2022	FT-FY23-11182022-015053-A	<1	FT-FY23-11182022-015053-B	<1
WS-015054	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 111B	High Left	WF-04122022-015054	12/30/2022	FT-FY23-11182022-015054-A	<1	FT-FY23-11182022-015054-B	<1
WS-015055	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 111B	Low Right	WF-04122022-015055	12/30/2022	FT-FY23-11182022-015055-A	<1	FT-FY23-11182022-015055-B	<1
WS-015056	4/12/2022	4/12/2023	Ground Floor	Health Suite	In health suite 103C		WF-04122022-015056	12/30/2022	FT-FY23-11182022-015056-A	<1	FT-FY23-11182022-015056-B	<1
WS-015058	4/12/2022	4/12/2023	Ground Floor	Bottle Filler	In hallway adjacent to 208		WF-04122022-015058	12/30/2022	FT-FY23-11182022-015058-A	<1	FT-FY23-11182022-015058-B	<1
WS-015059	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 208	High Left	WF-04122022-015059	12/30/2022	FT-FY23-11182022-015059-A	<1	FT-FY23-11182022-015059-B	<1
WS-015060	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 208	Low Right	WF-04122022-015060	12/30/2022	FT-FY23-11182022-015060-A	<1	FT-FY23-11182022-015060-B	<1
WS-015061	4/12/2022	4/12/2023	Ground Floor	Bottle Filler	In hallway adjacent to 211B		WF-04122022-015061	12/30/2022	FT-FY23-11182022-015061-A	<1	FT-FY23-11182022-015061-B	<1
WS-015062	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 211B	High Left	WF-04122022-015062	12/30/2022	FT-FY23-11182022-015062-A	<1	FT-FY23-11182022-015062-B	<1
WS-015063	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 211B	Low Right	WF-04122022-015063	12/30/2022	FT-FY23-11182022-015063-A	<1	FT-FY23-11182022-015063-B	<1
WS-015064	4/12/2022	4/12/2023	Ground Floor	Health Suite	In MES health suite 204A restroom		WF-04122022-015064	12/30/2022	FT-FY23-11182022-015064-A	<1	FT-FY23-11182022-015064-B	<1
WS-015065	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 310		WF-10052022-015065	12/30/2022	FT-FY23-11182022-015065-A	1.6	FT-FY23-11182022-015065-B	<1
WS-015066	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 301		WF-10052022-015066	12/30/2022	FT-FY23-11182022-015066-A	<1	FT-FY23-11182022-015066-B	<1
WS-015067	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 309		WF-10052022-015067	12/30/2022	FT-FY23-11182022-015067-A	2.6	FT-FY23-11182022-015067-B	<1
WS-015068	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 302		WF-10052022-015068	12/30/2022	FT-FY23-11182022-015068-A	1.1	FT-FY23-11182022-015068-B	<1
WS-015069	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 308		WF-10052022-015069	12/30/2022	FT-FY23-11182022-015069-A	<1	FT-FY23-11182022-015069-B	<1
WS-015070	4/12/2022	4/12/2023	Ground Floor	Bottle Filler	In hallway adjacent to 302		WF-04122022-015070	12/30/2022	FT-FY23-11182022-015070-A	<1	FT-FY23-11182022-015070-B	<1
WS-015071	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 302	High Left	WF-04122022-015071	12/30/2022	FT-FY23-11182022-015071-A	1.4	FT-FY23-11182022-015071-B	<1
WS-015072	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 302	Low Right	WF-04122022-015072	12/30/2022	FT-FY23-11182022-015072-A	<1	FT-FY23-11182022-015072-B	<1
WS-015073	4/12/2022	4/12/2023	Ground Floor	Bottle Filler	In hallway adjacent to 303		WF-04122022-015073	12/30/2022	FT-FY23-11182022-015073-A	<1	FT-FY23-11182022-015073-B	<1
WS-015074	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 303	High Left	WF-04122022-015074	12/30/2022	FT-FY23-11182022-015074-A	<1	FT-FY23-11182022-015074-B	<1
WS-015075	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 303	Low Right	WF-04122022-015075	12/30/2022	FT-FY23-11182022-015075-A	1.9	FT-FY23-11182022-015075-B	<1
WS-015076	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 303		WF-10052022-015076	12/30/2022	FT-FY23-11182022-015076-A	<1	FT-FY23-11182022-015076-B	2.9
WS-015077	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 307		WF-10052022-015077	12/30/2022	FT-FY23-11182022-015077-A	<1	FT-FY23-11182022-015077-B	1.0
WS-015078	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 304		WF-10052022-015078	12/30/2022	FT-FY23-11182022-015078-A	<1	FT-FY23-11182022-015078-B	2.4
WS-015079	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 306		WF-10052022-015079	12/30/2022	FT-FY23-11182022-015079-A	<1	FT-FY23-11182022-015079-B	1.0
WS-015080	10/5/2022	10/5/2023	Ground Floor	Bathroom	In bathroom of room 305		WF-10052022-015080	12/30/2022	FT-FY23-11182022-015080-A	<1	FT-FY23-11182022-015080-B	1.7
WS-015082	4/12/2022	4/12/2023	Ground Floor	Bottle Filler	In hallway adjacent to 408		WF-04122022-015082	12/30/2022	FT-FY23-11182022-015082-A	<1	FT-FY23-11182022-015082-B	<1
WS-015083	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 408	High Left	WF-04122022-015083	12/30/2022	FT-FY23-11182022-015083-A	<1	FT-FY23-11182022-015083-B	<1
WS-015084	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 408	Low Right	WF-04122022-015084	12/30/2022	FT-FY23-11182022-015084-A	<1	FT-FY23-11182022-015084-B	<1
WS-015085	4/12/2022	4/12/2023	Ground Floor	Bottle Filler	In hallway adjacent to 411B		WF-04122022-015085	12/30/2022	FT-FY23-11182022-015085-A	<1	FT-FY23-11182022-015085-B	<1

WS-015086	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 411B	High	Left	WF-04122022-015086	12/30/2022	FT-FY23-11182022-015086-A	<1	FT-FY23-11182022-015086-B	<1
WS-015087	4/12/2022	4/12/2023	Ground Floor	Cooler	In hallway adjacent to 411B	Low	Right	WF-04122022-015087	12/30/2022	FT-FY23-11182022-015087-A	<1	FT-FY23-11182022-015087-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015088	2/22/2022	2/22/2023	Ground Floor	Food Prep Sink	In room 403 food prints	WF-02222022-015088	12/30/2022	FT-FY23-11182022-015088-A	<1	FT-FY23-11182022-015088-B	<1	
WS-015092	2/22/2022	2/22/2023	Ground Floor	Food Prep Sink	In kitchen trailer 2nd clockwise from entry	WF-02222022-015092	12/30/2022	FT-FY23-11182022-015092-A	<1	FT-FY23-11182022-015092-B	<1	