



BROWNE EC LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	BROWNE EDUCATIONAL CAMPUS	WS- 000734	8/20/2016	Basement	Food Prep Sink	In kitchen first clockwise from entry door	FT-72016-000734-A	< 1	FT-72016-000734-B	< 1
2	BROWNE EDUCATIONAL CAMPUS	WS- 000735	8/20/2016	Basement	Cooler	In cafeteria on south wall	FT-82016-000735-A	< 1	FT-82016-000735-B	< 1
3	BROWNE EDUCATIONAL CAMPUS	WS- 000736	8/20/2016	Basement	Cooler	In cafeteria on north wall	FT-82016-000736-A	< 1	FT-82016-000736-B	< 1
4	BROWNE EDUCATIONAL CAMPUS	WS- 000737	8/20/2016	1	Cooler	In hallway adjacent to room 1-124	FT-82016-000737-A	< 1	FT-82016-000737-B	< 1
5	BROWNE EDUCATIONAL CAMPUS	WS- 000738	8/20/2016	1	Fountain	In classroom 1-124	FT-82016-000738-A	< 1	FT-82016-000738-B	< 1
6	BROWNE EDUCATIONAL CAMPUS	WS- 000740	8/20/2016	1	Cooler	In hallway adjacent to gym	FT-82016-000740-A	< 1	FT-82016-000740-B	< 1
7	BROWNE EDUCATIONAL CAMPUS	WS- 000741	8/20/2016	Basement	Cooler	In gym	FT-82016-000741-A	< 1	FT-82016-000741-B	< 1
8	BROWNE EDUCATIONAL CAMPUS	WS- 000742	8/20/2016	Basement	Cooler	In hallway across from gym between girls' and boys' restrooms	FT-82016-000742-A	< 1	FT-82016-000742-B	< 1
9	BROWNE EDUCATIONAL CAMPUS	WS- 000743	8/20/2016	Basement	Cooler	In boys' locker room	FT-82016-000743-A	< 1	FT-82016-000743-B	< 1
10	BROWNE EDUCATIONAL CAMPUS	WS- 000744	8/20/2016	1	Cooler	In hallway adjacent to room 1-119	FT-82016-000744-A	< 1	FT-82016-000744-B	< 1
11	BROWNE EDUCATIONAL CAMPUS	WS- 000748	8/20/2016	1	Fountain	In Pre-K classroom 1-099	FT-82016-000748-A	< 1	FT-82016-000748-B	< 1
12	BROWNE EDUCATIONAL CAMPUS	WS- 000749	8/20/2016	1	Fountain	In classroom 1-111	FT-82016-000749-A	< 1	FT-82016-000749-B	< 1
13	BROWNE EDUCATIONAL CAMPUS	WS- 000751	8/20/2016	1	Cooler	In hallway adjacent to room 1-108	FT-82016-000751-A	< 1	FT-82016-000751-B	< 1
14	BROWNE EDUCATIONAL CAMPUS	WS- 000752	8/20/2016	1	Fountain	In classroom 1-108	FT-82016-000752-A	< 1	FT-82016-000752-B	< 1
15	BROWNE EDUCATIONAL CAMPUS	WS- 000753	8/20/2016	1	Classroom Faucet	In classroom 1-108	FT-82016-000753-A	< 1	FT-82016-000753-B	< 1
16	BROWNE EDUCATIONAL CAMPUS	WS- 000755	8/20/2016	1	Fountain	In classroom 1-140	FT-82016-000755-A	< 1	FT-82016-000755-B	< 1
17	BROWNE EDUCATIONAL CAMPUS	WS- 000756**	8/20/2016 9/2/2016	1	Fountain	In classroom 1-137	FT-82016-000756-A Re-test A	7.5 < 1	FT-82016-000756-B Re-test B	< 1 < 1
18	BROWNE EDUCATIONAL CAMPUS	WS- 000758	8/20/2016	1	Health Suite	In health suite 1-154	FT-72016-000758-A	< 1	FT-72016-000758-B	< 1
19	BROWNE EDUCATIONAL CAMPUS	WS- 000760	8/20/2016	1	Fountain	In classroom 1-103	FT-82016-000760-A	< 1	FT-82016-000760-B	< 1
20	BROWNE EDUCATIONAL CAMPUS	WS- 000761	8/20/2016	1	Cooler	In hallway adjacent to room 1-157	FT-82016-000761-A	< 1	FT-82016-000761-B	< 1
21	BROWNE EDUCATIONAL CAMPUS	WS- 000762	8/20/2016	1	Cooler	In hallway adjacent to room 1-179	FT-82016-000762-A	< 1	FT-82016-000762-B	< 1
22	BROWNE EDUCATIONAL CAMPUS	WS- 000763	8/20/2016	1	Cooler	In hallway adjacent to room 1-193	FT-82016-000763-A	< 1	FT-82016-000763-B	< 1
23	BROWNE EDUCATIONAL CAMPUS	WS- 000770	8/20/2016	2	Cooler	In hallway adjacent to room 1-208	FT-82016-000770-A	< 1	FT-82016-000770-B	< 1
24	BROWNE EDUCATIONAL CAMPUS	WS- 000771	8/20/2016	2	Cooler	In hallway adjacent to room 2-269	FT-82016-000771-A	< 1	FT-82016-000771-B	< 1
25	BROWNE EDUCATIONAL CAMPUS	WS- 000773	8/20/2016	2	Cooler	In hallway adjacent to room 2-273	FT-82016-000773-A	< 1	FT-82016-000773-B	< 1
26	BROWNE EDUCATIONAL CAMPUS	WS- 000774	8/20/2016	2	Cooler	In hallway adjacent to room 2-301	FT-82016-000774-A	< 1	FT-82016-000774-B	< 1
27	BROWNE EDUCATIONAL CAMPUS	WS- 000775	8/20/2016	2	Cooler	In hallway adjacent to stairwell 6	FT-82016-000775-A	< 1	FT-82016-000775-B	< 1
28	BROWNE EDUCATIONAL CAMPUS	WS- 000776	8/20/2016	2	Cooler	In hallway adjacent to room 2-235	FT-82016-000776-A	< 1	FT-82016-000776-B	< 1
29	BROWNE EDUCATIONAL CAMPUS	WS- 000777	8/20/2016	2	Cooler	In hallway adjacent to room 2-213	FT-82016-000777-A	< 1	FT-82016-000777-B	< 1
30	BROWNE EDUCATIONAL CAMPUS	WS- 000778	8/20/2016	2	Cooler	In hallway adjacent to room 2-217	FT-82016-000778-A	< 1	FT-82016-000778-B	< 1
31	BROWNE EDUCATIONAL CAMPUS	WS- 000784	8/20/2016	1	Fountain	In classroom 1-128 Left	FT-82016-000784-A	< 1	FT-82016-000784-B	< 1
32	BROWNE EDUCATIONAL CAMPUS	WS- 000788	8/20/2016	Basement	Cooler	In girls' locker room	FT-82016-000788-A	< 1	FT-82016-000788-B	< 1
33	BROWNE EDUCATIONAL CAMPUS	WS- 000789	8/20/2016	3	Cooler	In hallway adjacent to room 1	FT-82016-000789-A	< 1	FT-82016-000789-B	< 1
34	BROWNE EDUCATIONAL CAMPUS	WS- 000820	8/20/2016	1	Fountain	In classroom 1-119	FT-82016-000820-A	< 1	FT-82016-000820-B	< 1
35	BROWNE EDUCATIONAL CAMPUS	WS- 000821	8/20/2016	3	Cooler	In hallway adjacent to room 3-328	FT-82016-000821-A	< 1	FT-82016-000821-B	< 1
36	BROWNE EDUCATIONAL CAMPUS	WS- 000823	8/20/2016	3	Cooler	In hallway adjacent to room 3	FT-82016-000823-A	< 1	FT-82016-000823-B	< 1
37	BROWNE EDUCATIONAL CAMPUS	WS- 000824	8/20/2016	3	Cooler	In hallway adjacent to room 3-337	FT-82016-000824-A	< 1	FT-82016-000824-B	< 1

**Filter inspected, found improperly installed, repaired, and re-sampled.