



BROWNE EC LEAD WATER TEST RESULTS



Initial Filter Test After Installation

| | Building Location: Building Name | RECORD ID | Date Analyzed | Floor | Device Type | Device Location | 1st Draw - Sample ID | Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | Final Result - 2nd Draw (ppb) |
|----|----------------------------------|------------|---------------|-------|--------------|---|----------------------|-------------------------------|----------------------|-------------------------------|
| 1 | BROWNE EDUCATIONAL CAMPUS | WS- 000754 | 1/26/2017 | 1 | Combo Faucet | In classroom 1-140 | FT-112016-000754-A | 1.7 | FT-112016-000754-B | < 1 |
| 2 | BROWNE EDUCATIONAL CAMPUS | WS- 000739 | 1/26/2017 | 1 | Combo Faucet | In classroom 1-124 | FT-112016-000739-A | 1.3 | FT-112016-000739-B | < 1 |
| 3 | BROWNE EDUCATIONAL CAMPUS | WS- 000728 | 1/26/2017 | 1 | Bathroom | In social worker room 1-112 in bathroom | FT-112016-000728-A | 1.1 | FT-112016-000728-B | < 1 |
| 4 | BROWNE EDUCATIONAL CAMPUS | WS- 000783 | 1/26/2017 | 1 | Combo Faucet | In classroom 1-128 | FT-112016-000783-A | 2.8 | FT-112016-000783-B | < 1 |
| 5 | BROWNE EDUCATIONAL CAMPUS | WS- 000753 | 1/26/2017 | 1 | Combo Faucet | In classroom 1-108 | FT-112016-000753-A | 1.5 | FT-112016-000753-B | < 1 |
| 6 | BROWNE EDUCATIONAL CAMPUS | WS- 000819 | 1/26/2017 | 1 | Combo Faucet | In classroom 1-119 | FT-112016-000819-A | < 1 | FT-112016-000819-B | < 1 |
| 7 | BROWNE EDUCATIONAL CAMPUS | WS- 000722 | 1/26/2017 | 1 | Bathroom | In classroom 1-111 in bathroom | FT-112016-000722-A | 1.5 | FT-112016-000722-B | < 1 |
| 8 | BROWNE EDUCATIONAL CAMPUS | WS- 000726 | 1/26/2017 | 1 | Bathroom | In classroom 1-137 in bathroom | FT-112016-000726-A | < 1 | FT-112016-000726-B | < 1 |
| 9 | BROWNE EDUCATIONAL CAMPUS | WS- 000750 | 1/26/2017 | 1 | Combo Faucet | In classroom 1-111 | FT-112016-000750-A | < 1 | FT-112016-000750-B | < 1 |
| 10 | BROWNE EDUCATIONAL CAMPUS | WS- 000723 | 1/26/2017 | 1 | Bathroom | In classroom 1-119 in bathroom | FT-112016-000723-A | 1.8 | FT-112016-000723-B | < 1 |
| 11 | BROWNE EDUCATIONAL CAMPUS | WS- 000731 | 1/26/2017 | 1 | Bathroom | In Pre-K classroom 1-099 in bathroom | FT-112016-000731-A | 2.1 | FT-112016-000731-B | < 1 |
| 12 | BROWNE EDUCATIONAL CAMPUS | WS- 000757 | 1/26/2017 | 1 | Combo Faucet | In classroom 1-137 | FT-112016-000757-A | < 1 | FT-112016-000757-B | < 1 |
| 13 | BROWNE EDUCATIONAL CAMPUS | WS- 000724 | 1/26/2017 | 1 | Bathroom | In classroom 1-124 in bathroom | FT-112016-000724-A | < 1 | FT-112016-000724-B | < 1 |
| 14 | BROWNE EDUCATIONAL CAMPUS | WS- 000727 | 1/26/2017 | 1 | Bathroom | In classroom 1-140 in bathroom | FT-112016-000727-A | < 1 | FT-112016-000727-B | < 1 |
| 15 | BROWNE EDUCATIONAL CAMPUS | WS- 000746 | 1/26/2017 | 1 | Combo Faucet | In social worker room 1-112 | FT-112016-000746-A | 1.9 | FT-112016-000746-B | < 1 |
| 16 | BROWNE EDUCATIONAL CAMPUS | WS- 000720 | 1/26/2017 | 1 | Bathroom | In classroom 1-103 in bathroom | FT-112016-000720-A | 1.9 | FT-112016-000720-B | < 1 |
| 17 | BROWNE EDUCATIONAL CAMPUS | WS- 000725 | 1/26/2017 | 1 | Bathroom | In classroom 1-128 in bathroom | FT-112016-000725-A | 2.6 | FT-112016-000725-B | < 1 |
| 18 | BROWNE EDUCATIONAL CAMPUS | WS- 000721 | 1/26/2017 | 1 | Bathroom | In classroom 1-108 in bathroom | FT-112016-000721-A | 1.1 | FT-112016-000721-B | < 1 |
| 19 | BROWNE EDUCATIONAL CAMPUS | WS- 000759 | 1/26/2017 | 1 | Combo Faucet | In classroom 1-103 | FT-112016-000759-A | 1.6 | FT-112016-000759-B | < 1 |
| 20 | BROWNE EDUCATIONAL CAMPUS | WS- 000747 | 1/26/2017 | 1 | Combo Faucet | In Pre-K classroom 1-099 | FT-112016-000747-A | 1.3 | FT-112016-000747-B | < 1 |

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

| | | | | | | | | | | |
|----|---------------------------|------------|-----------|---|--------------|---|--------------------|-----|--------------------|-----|
| 1 | BROWNE EDUCATIONAL CAMPUS | WS- 000754 | 2/13/2017 | 1 | Combo Faucet | In classroom 1-140 | FT-112016-000754-A | < 1 | FT-112016-000754-B | < 1 |
| 2 | BROWNE EDUCATIONAL CAMPUS | WS- 000739 | 2/13/2017 | 1 | Combo Faucet | In classroom 1-124 | FT-112016-000739-A | < 1 | FT-112016-000739-B | < 1 |
| 3 | BROWNE EDUCATIONAL CAMPUS | WS- 000728 | 2/13/2017 | 1 | Bathroom | In social worker room 1-112 in bathroom | FT-112016-000728-A | < 1 | FT-112016-000728-B | < 1 |
| 4 | BROWNE EDUCATIONAL CAMPUS | WS- 000783 | 2/13/2017 | 1 | Combo Faucet | In classroom 1-128 | FT-112016-000783-A | < 1 | FT-112016-000783-B | < 1 |
| 5 | BROWNE EDUCATIONAL CAMPUS | WS- 000753 | 2/13/2017 | 1 | Combo Faucet | In classroom 1-108 | FT-112016-000753-A | < 1 | FT-112016-000753-B | < 1 |
| 7 | BROWNE EDUCATIONAL CAMPUS | WS- 000722 | 2/13/2017 | 1 | Bathroom | In classroom 1-111 in bathroom | FT-112016-000722-A | < 1 | FT-112016-000722-B | < 1 |
| 10 | BROWNE EDUCATIONAL CAMPUS | WS- 000723 | 2/13/2017 | 1 | Bathroom | In classroom 1-119 in bathroom | FT-112016-000723-A | < 1 | FT-112016-000723-B | < 1 |
| 11 | BROWNE EDUCATIONAL CAMPUS | WS- 000731 | 2/13/2017 | 1 | Bathroom | In Pre-K classroom 1-099 in bathroom | FT-112016-000731-A | < 1 | FT-112016-000731-B | < 1 |
| 15 | BROWNE EDUCATIONAL CAMPUS | WS- 000746 | 2/13/2017 | 1 | Combo Faucet | In social worker room 1-112 | FT-112016-000746-A | < 1 | FT-112016-000746-B | < 1 |
| 16 | BROWNE EDUCATIONAL CAMPUS | WS- 000720 | 2/13/2017 | 1 | Bathroom | In classroom 1-103 in bathroom | FT-112016-000720-A | < 1 | FT-112016-000720-B | < 1 |
| 17 | BROWNE EDUCATIONAL CAMPUS | WS- 000725 | 2/13/2017 | 1 | Bathroom | In classroom 1-128 in bathroom | FT-112016-000725-A | < 1 | FT-112016-000725-B | < 1 |
| 18 | BROWNE EDUCATIONAL CAMPUS | WS- 000721 | 2/13/2017 | 1 | Bathroom | In classroom 1-108 in bathroom | FT-112016-000721-A | < 1 | FT-112016-000721-B | < 1 |
| 19 | BROWNE EDUCATIONAL CAMPUS | WS- 000759 | 2/13/2017 | 1 | Combo Faucet | In classroom 1-103 | FT-112016-000759-A | < 1 | FT-112016-000759-B | < 1 |
| 20 | BROWNE EDUCATIONAL CAMPUS | WS- 000747 | 2/13/2017 | 1 | Combo Faucet | In Pre-K classroom 1-099 | FT-112016-000747-A | < 1 | FT-112016-000747-B | < 1 |

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb