



Browne Education Campus Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000727	10/9/17	10/9/18	1	Bathroom	In classroom 1-140 in bathroom	WF-102017-000727	12/4/17	FT-FY18-102017-000727-A	<1	FT-FY18-102017-000727-B	<1
WS-000731	10/9/17	10/9/18	1	Bathroom	In Pre-K classroom 1-099 in bathroom	WF-102017-000731	12/4/17	FT-FY18-102017-000731-A	<1	FT-FY18-102017-000731-B	<1
WS-000736	5/28/17	5/28/18	Basement	Cooler	In cafeteria on north wall	WF-52017-000736	12/4/17	FT-FY18--52017-000736-A	<1	FT-FY18--52017-000736-B	<1
WS-000737	5/28/17	5/28/18	1	Cooler	In hallway adjacent to room 1-124	WF-52017-000737	12/4/17	FT-FY18--52017-000737-A	<1	FT-FY18--52017-000737-B	<1
WS-000738	5/28/17	5/28/18	1	Combo Fountain	In classroom 1-124	WF-52017-000738	12/4/17	FT-FY18--52017-000738-A	<1	FT-FY18--52017-000738-B	<1
WS-000740	5/28/17	5/28/18	1	Cooler	In hallway adjacent to gym	WF-52017-000740	12/4/17	FT-FY18--52017-000740-A	<1	FT-FY18--52017-000740-B	<1
WS-000742	5/28/17	5/28/18	Basement	Cooler	In hallway across from gym between girls' and boys' restrooms	WF-52017-000742	12/4/17	FT-FY18--52017-000742-A	<1	FT-FY18--52017-000742-B	<1
WS-000746	10/9/17	10/9/18	1	Combo Faucet	In social worker room 1-112	WF-102017-000746	12/4/17	FT-FY18-102017-000746-A	<1	FT-FY18-102017-000746-B	<1
WS-000748	5/28/17	5/28/18	1	Combo Fountain	In Pre-K classroom 1-099	WF-52017-000748	12/4/17	FT-FY18--52017-000748-A	<1	FT-FY18--52017-000748-B	<1
WS-000749	5/28/17	5/28/18	1	Combo Fountain	In classroom 1-111	WF-52017-000749	12/4/17	FT-FY18--52017-000749-A	<1	FT-FY18--52017-000749-B	<1
WS-000759	10/9/17	10/9/18	1	Combo Faucet	In classroom 1-103	WF-102017-000759	12/4/17	FT-FY18-102017-000759-A	<1	FT-FY18-102017-000759-B	<1
WS-000761	5/28/17	5/28/18	1	Cooler	In hallway adjacent to room 1-157	WF-52017-000761	12/4/17	FT-FY18--52017-000761-A	<1	FT-FY18--52017-000761-B	<1
WS-000770	5/28/17	5/28/18	1	Cooler	In hallway adjacent to room 2-208	WF-52017-000770	12/4/17	FT-FY18--52017-000770-A	<1	FT-FY18--52017-000770-B	<1
WS-000773	5/28/17	5/28/18	2	Cooler	In hallway adjacent to room 2-273	WF-52017-000773	12/4/17	FT-FY18--52017-000773-A	<1	FT-FY18--52017-000773-B	<1
WS-000775	5/28/17	5/28/18	2	Cooler	In hallway adjacent to stairwell 6	WF-52017-000775	12/4/17	FT-FY18--52017-000775-A	<1	FT-FY18--52017-000775-B	<1
WS-000778	5/28/17	5/28/18	2	Cooler	In hallway adjacent to room 2-217	WF-52017-000778	12/4/17	FT-FY18--52017-000778-A	<1	FT-FY18--52017-000778-B	<1
WS-000783	10/9/17	10/9/18	1	Combo Faucet	In classroom 1-128	WF-102017-000783	12/4/17	FT-FY18-102017-000783-A	<1	FT-FY18-102017-000783-B	<1
WS-000823	5/28/17	5/28/18	3	Cooler	In hallway adjacent to room 3	WF-52017-000823	12/4/17	FT-FY18--52017-000823-A	<1	FT-FY18--52017-000823-B	<1
WS-000824	5/28/17	5/28/18	3	Cooler	In hallway adjacent to room 3-337	WF-52017-000824	12/4/17	FT-FY18--52017-000824-A	<1	FT-FY18--52017-000824-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-000734	Basement	Food Prep Sink	In kitchen first clockwise from entry door	12/4/17	FT-FY18-102017-000734-A	<1	FT-FY18-102017-000734-B	<1	