



Browne EC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000720	9/17/2018	9/17/2019	1	Bathroom	In classroom 1-103 in bathroom	WF-09172018-000720	12/12/2018	FT-FY19-122018-000720-A	<1	FT-FY19-122018-000720-B	<1
WS-000721	9/17/2018	9/17/2019	1	Bathroom	In classroom 1-108 in bathroom	WF-09172018-000721	12/12/2018	FT-FY19-122018-000721-A	<1	FT-FY19-122018-000721-B	<1
WS-000722	9/17/2018	9/17/2019	1	Bathroom	In classroom 1-111 in bathroom	WF-09172018-000722	12/12/2018	FT-FY19-122018-000722-A	<1	FT-FY19-122018-000722-B	<1
WS-000723	9/17/2018	9/17/2019	1	Bathroom	In classroom 1-119 in bathroom	WF-09172018-000723	12/12/2018	FT-FY19-122018-000723-A	<1	FT-FY19-122018-000723-B	<1
WS-000724	9/17/2018	9/17/2019	1	Bathroom	In classroom 1-124 in bathroom	WF-09172018-000724	12/12/2018	FT-FY19-122018-000724-A	<1	FT-FY19-122018-000724-B	<1
WS-000725	9/17/2018	9/17/2019	1	Bathroom	In classroom 1-128 in bathroom	WF-09172018-000725	12/12/2018	FT-FY19-122018-000725-A	<1	FT-FY19-122018-000725-B	<1
WS-000726	9/17/2018	9/17/2019	1	Bathroom	In classroom 1-137 in bathroom	WF-09172018-000726	12/12/2018	FT-FY19-122018-000726-A	<1	FT-FY19-122018-000726-B	<1
WS-000727	9/17/2018	9/17/2019	1	Bathroom	In classroom 1-140 in bathroom	WF-09172018-000727	12/12/2018	FT-FY19-122018-000727-A	<1	FT-FY19-122018-000727-B	<1
WS-000728	9/17/2018	9/17/2019	1	Bathroom	In social worker room 1-112 in bathroom	WF-09172018-000728	12/12/2018	FT-FY19-122018-000728-A	1.1	FT-FY19-122018-000728-B	<1
WS-000731	9/17/2018	9/17/2019	1	Bathroom	In Pre-K classroom 1-099 in bathroom	WF-09172018-000731	12/12/2018	FT-FY19-122018-000731-A	<1	FT-FY19-122018-000731-B	<1
WS-000735	4/18/2018	4/18/2019	Basement	Cooler	In cafeteria on south wall	WF-04182018-000735	12/12/2018	FT-FY19-122018-000735-A	<1	FT-FY19-122018-000735-B	<1
WS-000736	4/18/2018	4/18/2019	Basement	Cooler	In cafeteria on north wall	WF-04182018-000736	12/12/2018	FT-FY19-122018-000736-A	<1	FT-FY19-122018-000736-B	<1
WS-000737	4/18/2018	4/18/2019	1	Cooler	In hallway adjacent to room 1-124	WF-04182018-000737	12/12/2018	FT-FY19-122018-000737-A	<1	FT-FY19-122018-000737-B	<1
WS-000738	4/18/2018	4/18/2019	1	Combo Fountain	In classroom 1-124	WF-04182018-000738	12/12/2018	FT-FY19-122018-000738-A	<1	FT-FY19-122018-000738-B	<1
WS-000739	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 1-124	WF-09172018-000739	12/12/2018	FT-FY19-122018-000739-A	<1	FT-FY19-122018-000739-B	<1
WS-000740	12/4/2018	12/4/2019	1	Cooler	In hallway adjacent to activity center	WF-12042018-000740	12/12/2018	FT-FY19-122018-000740-A	<1	FT-FY19-122018-000740-B	<1
WS-000741	4/18/2018	4/18/2019	Basement	Cooler	In gym	WF-04182018-000741	12/12/2018	FT-FY19-122018-000741-A	<1	FT-FY19-122018-000741-B	<1
WS-000742	4/18/2018	4/18/2019	Basement	Cooler	In hallway across from gym between girls' and boys' restrooms	WF-04182018-000742	12/12/2018	FT-FY19-122018-000742-A	<1	FT-FY19-122018-000742-B	<1
WS-000743	4/18/2018	4/18/2019	Basement	Cooler	In boys' locker room	WF-04182018-000743	12/12/2018	FT-FY19-122018-000743-A	<1	FT-FY19-122018-000743-B	<1
WS-000744	4/18/2018	4/18/2019	1	Cooler	In hallway adjacent to room 1-119	WF-04182018-000744	12/12/2018	FT-FY19-122018-000744-A	<1	FT-FY19-122018-000744-B	<1
WS-000745	4/18/2018	4/18/2019	1	Combo Fountain	In social worker room 1-112	WF-04182018-000745	12/12/2018	FT-FY19-122018-000745-A	<1	FT-FY19-122018-000745-B	<1
WS-000746	9/17/2018	9/17/2019	1	Combo Faucet	In social worker room 1-112	WF-09172018-000746	12/12/2018	FT-FY19-122018-000746-A	<1	FT-FY19-122018-000746-B	<1
WS-000747	9/17/2018	9/17/2019	1	Combo Faucet	In Pre-K classroom 1-099	WF-09172018-000747	12/12/2018	FT-FY19-122018-000747-A	<1	FT-FY19-122018-000747-B	<1
WS-000748	4/18/2018	4/18/2019	1	Combo Fountain	In Pre-K classroom 1-099	WF-04182018-000748	12/12/2018	FT-FY19-122018-000748-A	<1	FT-FY19-122018-000748-B	<1
WS-000749	4/18/2018	4/18/2019	1	Combo Fountain	In classroom 1-111	WF-04182018-000749	12/12/2018	FT-FY19-122018-000749-A	<1	FT-FY19-122018-000749-B	<1
WS-000750	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 1-111	WF-09172018-000750	12/12/2018	FT-FY19-122018-000750-A	<1	FT-FY19-122018-000750-B	<1
WS-000751	4/18/2018	4/18/2019	1	Cooler	In hallway adjacent to room 1-108	WF-04182018-000751	12/12/2018	FT-FY19-122018-000751-A	<1	FT-FY19-122018-000751-B	<1
WS-000752	4/18/2018	4/18/2019	1	Combo Fountain	In classroom 1-108	WF-04182018-000752	12/12/2018	FT-FY19-122018-000752-A	<1	FT-FY19-122018-000752-B	<1
WS-000753	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 1-108	WF-09172018-000753	12/12/2018	FT-FY19-122018-000753-A	<1	FT-FY19-122018-000753-B	<1
WS-000754	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 1-140	WF-09172018-000754	12/12/2018	FT-FY19-122018-000754-A	2.2	FT-FY19-122018-000754-B	1.1
WS-000755	4/18/2018	4/18/2019	1	Combo Fountain	In classroom 1-140	WF-04182018-000755	12/12/2018	FT-FY19-122018-000755-A	<1	FT-FY19-122018-000755-B	<1
WS-000756	4/18/2018	4/18/2019	1	Combo Fountain	In classroom 1-137	WF-04182018-000756	12/12/2018	FT-FY19-122018-000756-A	<1	FT-FY19-122018-000756-B	<1
WS-000757	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 1-137	WF-09172018-000757	12/12/2018	FT-FY19-122018-000757-A	1.4	FT-FY19-122018-000757-B	<1
WS-000758	4/18/2018	4/18/2019	1	Health Suite	In health suite 1-154	WF-04182018-000758	12/12/2018	FT-FY19-122018-000758-A	<1	FT-FY19-122018-000758-B	<1
WS-000759	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 1-103	WF-09172018-000759	12/12/2018	FT-FY19-122018-000759-A	<1	FT-FY19-122018-000759-B	<1
WS-000760	4/18/2018	4/18/2019	1	Combo Fountain	In classroom 1-103	WF-04182018-000760	12/12/2018	FT-FY19-122018-000760-A	<1	FT-FY19-122018-000760-B	<1
WS-000761	4/18/2018	4/18/2019	1	Cooler	In hallway adjacent to room 1-157	WF-04182018-000761	12/12/2018	FT-FY19-122018-000761-A	<1	FT-FY19-122018-000761-B	<1

WS-000762	4/18/2018	4/18/2019	1	Cooler	In hallway adjacent to room 1-179	WF-04182018-000762	12/12/2018	FT-FY19-122018-000762-A	<1	FT-FY19-122018-000762-B	<1
WS-000770	4/18/2018	4/18/2019	1	Cooler	In hallway adjacent to room 2-208	WF-04182018-000770	12/12/2018	FT-FY19-122018-000770-A	<1	FT-FY19-122018-000770-B	<1
WS-000771	4/18/2018	4/18/2019	2	Cooler	In hallway adjacent to room 2-269	WF-04182018-000771	12/12/2018	FT-FY19-122018-000771-A	<1	FT-FY19-122018-000771-B	<1
WS-000773	4/18/2018	4/18/2019	2	Cooler	In hallway adjacent to room 2-273	WF-04182018-000773	12/12/2018	FT-FY19-122018-000773-A	<1	FT-FY19-122018-000773-B	<1
WS-000774	4/18/2018	4/18/2019	2	Cooler	In hallway adjacent to room 2-301	WF-04182018-000774	12/12/2018	FT-FY19-122018-000774-A	<1	FT-FY19-122018-000774-B	<1
WS-000775	4/18/2018	4/18/2019	2	Cooler	In hallway adjacent to stairwell 6	WF-04182018-000775	12/12/2018	FT-FY19-122018-000775-A	<1	FT-FY19-122018-000775-B	<1
WS-000777	4/18/2018	4/18/2019	2	Cooler	In hallway adjacent to room 2-213	WF-04182018-000777	12/12/2018	FT-FY19-122018-000777-A	<1	FT-FY19-122018-000777-B	<1
WS-000778	4/18/2018	4/18/2019	2	Cooler	In hallway adjacent to room 2-217	WF-04182018-000778	12/12/2018	FT-FY19-122018-000778-A	<1	FT-FY19-122018-000778-B	<1
WS-000783	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 1-128	WF-09172018-000783	12/12/2018	FT-FY19-122018-000783-A	1.1	FT-FY19-122018-000783-B	<1
WS-000784	4/18/2018	4/18/2019	1	Combo Fountain	In classroom 1-128 Left	WF-04182018-000784	12/12/2018	FT-FY19-122018-000784-A	<1	FT-FY19-122018-000784-B	<1
WS-000788	4/18/2018	4/18/2019	Basement	Cooler	In girls' locker room	WF-04182018-000788	12/12/2018	FT-FY19-122018-000788-A	<1	FT-FY19-122018-000788-B	<1
WS-000789	4/18/2018	4/18/2019	3	Cooler	In hallway adjacent to room 1	WF-04182018-000789	12/12/2018	FT-FY19-122018-000789-A	<1	FT-FY19-122018-000789-B	<1
WS-000819	9/17/2018	9/17/2019	1	Combo Faucet	In classroom 1-119	WF-09172018-000819	12/12/2018	FT-FY19-122018-000819-A	<1	FT-FY19-122018-000819-B	<1
WS-000820	4/18/2018	4/18/2019	1	Combo Fountain	In classroom 1-119	WF-04182018-000820	12/12/2018	FT-FY19-122018-000820-A	<1	FT-FY19-122018-000820-B	<1
WS-000821	4/18/2018	4/18/2019	3	Cooler	In hallway adjacent to room 3-328	WF-04182018-000821	12/12/2018	FT-FY19-122018-000821-A	<1	FT-FY19-122018-000821-B	<1
WS-000823	4/18/2018	4/18/2019	3	Cooler	In hallway adjacent to room 3	WF-04182018-000823	12/12/2018	FT-FY19-122018-000823-A	<1	FT-FY19-122018-000823-B	<1
WS-000824	4/18/2018	4/18/2019	3	Cooler	In hallway adjacent to room 3-337	WF-04182018-000824	12/12/2018	FT-FY19-122018-000824-A	<1	FT-FY19-122018-000824-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation										
Record ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-000734	Basement	Food Prep Sink	In kitchen first clockwise from entry door			12/12/2018	FT-FY19-122018-000734-A	<1	FT-FY19-122018-000734-B	<1