



Bruce Monroe Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003663	6/22/2020	6/22/2021	Ground Floor	Cooler	In classroom 006	WF-06222020-003663	1/27/2021	FT-FY21-012021-003663-A	<1	FT-FY21-012021-003663-B	<1	
WS- 003664	6/22/2020	6/22/2021	Ground Floor	Cooler	In classroom 008	WF-06222020-003664	1/27/2021	FT-FY21-012021-003664-A	<1	FT-FY21-012021-003664-B	<1	
WS- 003665	8/20/2020	8/20/2021	Ground Floor	Cooler	In hallway 037	WF-08202020-003665	1/27/2021	FT-FY21-012021-003665-A	<1	FT-FY21-012021-003665-B	<1	
WS- 003667	6/22/2020	6/22/2021	Ground Floor	Cooler	In classroom 022	WF-06222020-003667	1/27/2021	FT-FY21-012021-003667-A	<1	FT-FY21-012021-003667-B	<1	
WS- 003668	6/22/2020	6/22/2021	Ground Floor	Cooler	In classroom 024	WF-06222020-003668	1/27/2021	FT-FY21-012021-003668-A	<1	FT-FY21-012021-003668-B	<1	
WS- 003670	8/20/2020	8/20/2021	1	Cooler	In hallway 156 adjacent to restroom	WF-08202020-003670	1/27/2021	FT-FY21-012021-003670-A	<1	FT-FY21-012021-003670-B	<1	
WS- 003671	6/22/2020	6/22/2021	1	Cooler	In classroom 126	WF-06222020-003671	1/27/2021	FT-FY21-012021-003671-A	<1	FT-FY21-012021-003671-B	<1	
WS- 003672	6/22/2020	6/22/2021	1	Cooler	In classroom 127	WF-06222020-003672	1/27/2021	FT-FY21-012021-003672-A	<1	FT-FY21-012021-003672-B	<1	
WS- 003673	6/22/2020	6/22/2021	1	Cooler	In classroom 123	WF-06222020-003673	1/27/2021	FT-FY21-012021-003673-A	<1	FT-FY21-012021-003673-B	<1	
WS- 003674	6/22/2020	6/22/2021	1	Cooler	In classroom 122	WF-06222020-003674	1/27/2021	FT-FY21-012021-003674-A	<1	FT-FY21-012021-003674-B	<1	
WS- 003675	8/20/2020	8/20/2021	1	Cooler	In hallway 144	WF-08202020-003675	1/27/2021	FT-FY21-012021-003675-A	<1	FT-FY21-012021-003675-B	<1	
WS- 003676	6/22/2020	6/22/2021	1	Health Suite	In health suite	WF-06222020-003676	1/27/2021	FT-FY21-012021-003676-A	<1	FT-FY21-012021-003676-B	<1	
WS- 003677	6/22/2020	6/22/2021	1	Break Room	In staff lounge	WF-06222020-003677	1/27/2021	FT-FY21-012021-003677-A	<1	FT-FY21-012021-003677-B	<1	
WS- 003679	8/20/2020	8/20/2021	1	Cooler	In hallway 151 adjacent to restroom	WF-08202020-003679	1/27/2021	FT-FY21-012021-003679-A	<1	FT-FY21-012021-003679-B	<1	
WS- 003680	8/20/2020	8/20/2021	2	Cooler	In hallway 234 adjacent to restroom	WF-08202020-003680	1/27/2021	FT-FY21-012021-003680-A	<1	FT-FY21-012021-003680-B	<1	
WS- 003681	8/20/2020	8/20/2021	2	Cooler	In hallway 229 adjacent to library	WF-08202020-003681	1/27/2021	FT-FY21-012021-003681-A	<1	FT-FY21-012021-003681-B	<1	
WS- 003682	8/20/2020	8/20/2021	2	Cooler	In hallway 240 adjacent to restroom	WF-08202020-003682	1/27/2021	FT-FY21-012021-003682-A	<1	FT-FY21-012021-003682-B	<1	
WS- 004281	6/22/2020	6/22/2021	Basement	Bottle Filler	In cafeteria	WF-06222020-004281	1/27/2021	FT-FY21-012021-004281-A	<1	FT-FY21-012021-004281-B	<1	
WS- 004282	6/22/2020	6/22/2021	Basement	Cooler	In cafeteria	Low Left	WF-06222020-004282	1/27/2021	FT-FY21-012021-004282-A	<1	FT-FY21-012021-004282-B	<1
WS- 004283	6/22/2020	6/22/2021	Basement	Cooler	In cafeteria	High Right	WF-06222020-004283	1/27/2021	FT-FY21-012021-004283-A	<1	FT-FY21-012021-004283-B	<1
WS- 004560	10/6/2020	10/6/2021	Ground Floor	Classroom Faucet	In classroom 022	WF-10062020-004560	1/27/2021	FT-FY21-012021-004560-A	<1	FT-FY21-012021-004560-B	<1	
WS- 004561	10/6/2020	10/6/2021	Ground Floor	Classroom Faucet	In classroom 021	WF-10062020-004561	1/27/2021	FT-FY21-012021-004561-A	<1	FT-FY21-012021-004561-B	<1	
WS- 004562	10/6/2020	10/6/2021	Ground Floor	Classroom Faucet	In classroom 024	WF-10062020-004562	1/27/2021	FT-FY21-012021-004562-A	<1	FT-FY21-012021-004562-B	<1	
WS- 004563	10/6/2020	10/6/2021	Ground Floor	Classroom Faucet	In classroom 008	WF-10062020-004563	1/27/2021	FT-FY21-012021-004563-A	<1	FT-FY21-012021-004563-B	<1	
WS- 004564	10/6/2020	10/6/2021	Ground Floor	Classroom Faucet	In classroom 007	WF-10062020-004564	1/27/2021	FT-FY21-012021-004564-A	<1	FT-FY21-012021-004564-B	<1	
WS- 004565	10/6/2020	10/6/2021	Ground Floor	Classroom Faucet	In classroom 006	WF-10062020-004565	1/27/2021	FT-FY21-012021-004565-A	<1	FT-FY21-012021-004565-B	<1	
WS- 004566	8/20/2020	8/20/2021	1	Bottle Filler	In hallway 156 adjacent to restroom	WF-08202020-004566	1/27/2021	FT-FY21-012021-004566-A	<1	FT-FY21-012021-004566-B	<1	
WS- 004567	8/20/2020	8/20/2021	1	Bottle Filler	In hallway 144	WF-08202020-004567	1/27/2021	FT-FY21-012021-004567-A	<1	FT-FY21-012021-004567-B	<1	
WS- 004568	8/20/2020	8/20/2021	1	Bottle Filler	In hallway 151 adjacent to restroom	WF-08202020-004568	1/27/2021	FT-FY21-012021-004568-A	<1	FT-FY21-012021-004568-B	<1	
WS- 004569	8/20/2020	8/20/2021	2	Bottle Filler	In hallway 234 adjacent to restroom	WF-08202020-004569	1/27/2021	FT-FY21-012021-004569-A	<1	FT-FY21-012021-004569-B	<1	
WS- 004570	8/20/2020	8/20/2021	2	Bottle Filler	In hallway 229 adjacent to library	WF-08202020-004570	1/27/2021	FT-FY21-012021-004570-A	<1	FT-FY21-012021-004570-B	<1	
WS- 004571	8/20/2020	8/20/2021	2	Bottle Filler	In hallway 240 adjacent to restroom	WF-08202020-004571	1/27/2021	FT-FY21-012021-004571-A	<1	FT-FY21-012021-004571-B	<1	
WS- 004572	8/20/2020	8/20/2021	2	Bottle Filler	In hallway across from 221	WF-08202020-004572	1/27/2021	FT-FY21-012021-004572-A	<1	FT-FY21-012021-004572-B	<1	

WS- 004573	8/20/2020	8/20/2021	2	Cooler	In hallway across from 221	WF-08202020-004573	1/27/2021	FT-FY21-012021-004573-A	<1	FT-FY21-012021-004573-B	<1
WS- 004574	8/20/2020	8/20/2021	Ground Floor	Bottle Filler	In hallway 037	WF-08202020-004574	1/27/2021	FT-FY21-012021-004574-A	<1	FT-FY21-012021-004574-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003661	1/5/2021	1/5/2022	Ground Floor	Food Prep Sink	In kitchen	WF-01052021-003661	1/27/2021	FT-FY21-012021-003661-A	<1	FT-FY21-012021-003661-B	<1