



# Bruce Monroe Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003664	5/17/2022	5/17/2023	Ground Floor	Cooler	In classroom 008	WF-05172022-003664	1/25/2023	FT-FY23-12292022-003664-A	<1	FT-FY23-12292022-003664-B	<1	
WS- 003665	5/17/2022	5/17/2023	Ground Floor	Cooler	In hallway 037	WF-05172022-003665	1/25/2023	FT-FY23-12292022-003665-A	<1	FT-FY23-12292022-003665-B	<1	
WS- 003670	10/5/2022	10/5/2023	1	Cooler	In hallway 156 adjacent to restroom	WF-10052022-003670	1/25/2023	FT-FY23-12292022-003670-A	2.0	FT-FY23-12292022-003670-B	<1	
WS- 003671	5/17/2022	5/17/2023	1	Cooler	In classroom 126	WF-05172022-003671	1/25/2023	FT-FY23-12292022-003671-A	<1	FT-FY23-12292022-003671-B	<1	
WS- 003673	5/17/2022	5/17/2023	1	Cooler	In classroom 123	WF-05172022-003673	1/25/2023	FT-FY23-12292022-003673-A	<1	FT-FY23-12292022-003673-B	<1	
WS- 003674	5/17/2022	5/17/2023	1	Cooler	In classroom 122	WF-05172022-003674	1/25/2023	FT-FY23-12292022-003674-A	<1	FT-FY23-12292022-003674-B	<1	
WS- 003675	5/17/2022	5/17/2023	1	Cooler	In hallway 144	WF-05172022-003675	1/25/2023	FT-FY23-12292022-003675-A	<1	FT-FY23-12292022-003675-B	<1	
WS- 003676	5/17/2022	5/17/2023	1	Health Suite	In health suite	WF-05172022-003676	1/25/2023	FT-FY23-12292022-003676-A	<1	FT-FY23-12292022-003676-B	1.4	
WS- 003677	5/17/2022	5/17/2023	1	Break Room	In staff lounge	WF-05172022-003677	1/25/2023	FT-FY23-12292022-003677-A	<1	FT-FY23-12292022-003677-B	<1	
WS- 003679	5/17/2022	5/17/2023	1	Cooler	In hallway 151 adjacent to restroom	WF-05172022-003679	1/25/2023	FT-FY23-12292022-003679-A	<1	FT-FY23-12292022-003679-B	<1	
WS- 003680	5/17/2022	5/17/2023	2	Cooler	In hallway 234 adjacent to restroom	WF-05172022-003680	1/25/2023	FT-FY23-12292022-003680-A	<1	FT-FY23-12292022-003680-B	<1	
WS- 003681	5/17/2022	5/17/2023	2	Cooler	In hallway 229 adjacent to library	WF-05172022-003681	1/25/2023	FT-FY23-12292022-003681-A	<1	FT-FY23-12292022-003681-B	<1	
WS- 003682	5/17/2022	5/17/2023	2	Cooler	In hallway 240 adjacent to restroom	WF-05172022-003682	1/25/2023	FT-FY23-12292022-003682-A	<1	FT-FY23-12292022-003682-B	<1	
WS- 004281	5/17/2022	5/17/2023	Basement	Bottle Filler	In cafeteria	WF-05172022-004281	1/25/2023	FT-FY23-12292022-004281-A	<1	FT-FY23-12292022-004281-B	<1	
WS- 004282	5/17/2022	5/17/2023	Basement	Cooler	In cafeteria	Low Left	WF-05172022-004282	1/25/2023	FT-FY23-12292022-004282-A	<1	FT-FY23-12292022-004282-B	<1
WS- 004283	5/17/2022	5/17/2023	Basement	Cooler	In cafeteria	High Right	WF-05172022-004283	1/25/2023	FT-FY23-12292022-004283-A	<1	FT-FY23-12292022-004283-B	<1
WS- 004560	9/20/2022	9/20/2023	Ground Floor	Classroom Faucet	In classroom 022	WF-09202022-004560	1/25/2023	FT-FY23-12292022-004560-A	<1	FT-FY23-12292022-004560-B	<1	
WS- 004561	9/20/2022	9/20/2023	Ground Floor	Classroom Faucet	In classroom 021	WF-09202022-004561	1/25/2023	FT-FY23-12292022-004561-A	<1	FT-FY23-12292022-004561-B	<1	
WS- 004562	9/20/2022	9/20/2023	Ground Floor	Classroom Faucet	In classroom 024	WF-09202022-004562	1/25/2023	FT-FY23-12292022-004562-A	<1	FT-FY23-12292022-004562-B	<1	
WS- 004565	9/20/2022	9/20/2023	Ground Floor	Classroom Faucet	In classroom 006	WF-09202022-004565	1/25/2023	FT-FY23-12292022-004565-A	<1	FT-FY23-12292022-004565-B	<1	
WS- 004566	10/5/2022	10/5/2023	1	Bottle Filler	In hallway 156 adjacent to restroom	WF-10052022-004566	1/25/2023	FT-FY23-12292022-004566-A	<1	FT-FY23-12292022-004566-B	<1	
WS- 004567	5/17/2022	5/17/2023	1	Bottle Filler	In hallway 144	WF-05172022-004567	1/25/2023	FT-FY23-12292022-004567-A	<1	FT-FY23-12292022-004567-B	<1	
WS- 004568	5/17/2022	5/17/2023	1	Bottle Filler	In hallway 151 adjacent to restroom	WF-05172022-004568	1/25/2023	FT-FY23-12292022-004568-A	<1	FT-FY23-12292022-004568-B	<1	
WS- 004569	5/17/2022	5/17/2023	2	Bottle Filler	In hallway 234 adjacent to restroom	WF-05172022-004569	1/25/2023	FT-FY23-12292022-004569-A	<1	FT-FY23-12292022-004569-B	<1	
WS- 004570	5/17/2022	5/17/2023	2	Bottle Filler	In hallway 229 adjacent to library	WF-05172022-004570	1/25/2023	FT-FY23-12292022-004570-A	<1	FT-FY23-12292022-004570-B	<1	
WS- 004571	5/17/2022	5/17/2023	2	Bottle Filler	In hallway 240 adjacent to restroom	WF-05172022-004571	1/25/2023	FT-FY23-12292022-004571-A	<1	FT-FY23-12292022-004571-B	<1	
WS- 004572	5/17/2022	5/17/2023	2	Bottle Filler	In hallway across from 221	WF-05172022-004572	1/25/2023	FT-FY23-12292022-004572-A	<1	FT-FY23-12292022-004572-B	<1	
WS- 004573	5/17/2022	5/17/2023	2	Cooler	In hallway across from 221	WF-05172022-004573	1/25/2023	FT-FY23-12292022-004573-A	<1	FT-FY23-12292022-004573-B	<1	
WS- 004574	5/17/2022	5/17/2023	Ground Floor	Bottle Filler	In hallway 037	WF-05172022-004574	1/25/2023	FT-FY23-12292022-004574-A	<1	FT-FY23-12292022-004574-B	<1	

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003661	12/20/2022	12/20/2023	Ground Floor	Food Prep Sink	In kitchen	WF-12202022-003661	1/25/2023	FT-FY23-12292022-003661-A	<1	FT-FY23-12292022-003661-B	1.2