



Bruce Monroe ES Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003662	5/6/2019	5/6/2020	Ground Floor	Cooler	In classroom 007	WF-05062019-003662	12/6/2019	FT-FY20-112019-003662-A	<1	FT-FY20-112019-003662-B	<1
WS- 003664	5/6/2019	5/6/2020	Ground Floor	Cooler	In classroom 008	WF-05062019-003664	12/6/2019	FT-FY20-112019-003664-A	<1	FT-FY20-112019-003664-B	<1
WS- 003665	5/6/2019	5/6/2020	Ground Floor	Cooler	In hallway 037	WF-05062019-003665	12/6/2019	FT-FY20-112019-003665-A	<1	FT-FY20-112019-003665-B	<1
WS- 003666	5/6/2019	5/6/2020	Ground Floor	Cooler	In classroom 021	WF-05062019-003666	12/6/2019	FT-FY20-112019-003666-A	<1	FT-FY20-112019-003666-B	<1
WS- 003667	5/6/2019	5/6/2020	Ground Floor	Cooler	In classroom 022	WF-05062019-003667	12/6/2019	FT-FY20-112019-003667-A	<1	FT-FY20-112019-003667-B	<1
WS- 003668	5/6/2019	5/6/2020	Ground Floor	Cooler	In classroom 024	WF-05062019-003668	12/6/2019	FT-FY20-112019-003668-A	<1	FT-FY20-112019-003668-B	<1
WS- 003670	5/6/2019	5/6/2020	1	Cooler	In hallway 156 adjacent to restroom	WF-05062019-003670	12/6/2019	FT-FY20-112019-003670-A	<1	FT-FY20-112019-003670-B	<1
WS- 003671	5/6/2019	5/6/2020	1	Cooler	In classroom 126	WF-05062019-003671	12/6/2019	FT-FY20-112019-003671-A	<1	FT-FY20-112019-003671-B	<1
WS- 003672	5/6/2019	5/6/2020	1	Cooler	In classroom 127	WF-05062019-003672	12/6/2019	FT-FY20-112019-003672-A	<1	FT-FY20-112019-003672-B	<1
WS- 003673	5/6/2019	5/6/2020	1	Cooler	In classroom 123	WF-05062019-003673	12/6/2019	FT-FY20-112019-003673-A	<1	FT-FY20-112019-003673-B	<1
WS- 003674	5/6/2019	5/6/2020	1	Cooler	In classroom 122	WF-05062019-003674	12/6/2019	FT-FY20-112019-003674-A	<1	FT-FY20-112019-003674-B	<1
WS- 003675	5/6/2019	5/6/2020	1	Cooler	In hallway 144	WF-05062019-003675	12/6/2019	FT-FY20-112019-003675-A	<1	FT-FY20-112019-003675-B	<1
WS- 003676	5/6/2019	5/6/2020	1	Health Suite	In health suite	WF-05062019-003676	12/6/2019	FT-FY20-112019-003676-A	<1	FT-FY20-112019-003676-B	<1
WS- 003677	5/6/2019	5/6/2020	1	Break Room	In staff lounge	WF-05062019-003677	12/6/2019	FT-FY20-112019-003677-A	<1	FT-FY20-112019-003677-B	<1
WS- 003679	5/6/2019	5/6/2020	1	Cooler	In hallway 151 adjacent to restroom	WF-05062019-003679	12/6/2019	FT-FY20-112019-003679-A	<1	FT-FY20-112019-003679-B	<1
WS- 003681	5/6/2019	5/6/2020	2	Cooler	In hallway 229 adjacent to library	WF-05062019-003681	12/6/2019	FT-FY20-112019-003681-A	<1	FT-FY20-112019-003681-B	<1
WS- 003682	5/6/2019	5/6/2020	2	Cooler	In hallway 240 adjacent to restroom	WF-05062019-003682	12/6/2019	FT-FY20-112019-003682-A	<1	FT-FY20-112019-003682-B	<1
WS- 004281	5/6/2019	5/6/2020	1	Bottle Filler	In cafeteria	WF-05062019-004281	12/6/2019	FT-FY20-112019-004281-A	<1	FT-FY20-112019-004281-B	<1
WS- 004282	5/6/2019	5/6/2020	1	Cooler	In cafeteria	WF-05062019-004282	12/6/2019	FT-FY20-112019-004282-A	<1	FT-FY20-112019-004282-B	<1
WS- 004283	5/6/2019	5/6/2020	1	Cooler	In cafeteria	WF-05062019-004283	12/6/2019	FT-FY20-112019-004283-A	<1	FT-FY20-112019-004283-B	<1
WS- 004560	10/16/2019	10/16/2020	Ground Floor	Classroom Faucet	In classroom 022	WF-10162019-004560	12/6/2019	FT-FY20-112019-004560-A	<1	FT-FY20-112019-004560-B	<1
WS- 004561	10/16/2019	10/16/2020	Ground Floor	Classroom Faucet	In classroom 021	WF-10162019-004561	12/6/2019	FT-FY20-112019-004561-A	<1	FT-FY20-112019-004561-B	<1
WS- 004562	10/16/2019	10/16/2020	Ground Floor	Classroom Faucet	In classroom 024	WF-10162019-004562	12/6/2019	FT-FY20-112019-004562-A	<1	FT-FY20-112019-004562-B	<1
WS- 004563	10/16/2019	10/16/2020	Ground Floor	Classroom Faucet	In classroom 008	WF-10162019-004563	12/6/2019	FT-FY20-112019-004563-A	<1	FT-FY20-112019-004563-B	<1
WS- 004564	10/16/2019	10/16/2020	Ground Floor	Classroom Faucet	In classroom 007	WF-10162019-004564	12/6/2019	FT-FY20-112019-004564-A	<1	FT-FY20-112019-004564-B	<1
WS- 004565	10/16/2019	10/16/2020	Ground Floor	Classroom Faucet	In classroom 006	WF-10162019-004565	12/6/2019	FT-FY20-112019-004565-A	<1	FT-FY20-112019-004565-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003661	7/23/2019	7/23/2020	Ground Floor	Food Prep Sink	In kitchen	WF-07232019-003661	12/6/2019	FT-FY20-112019-003661-A	<1	FT-FY20-112019-003661-B	<1