



Bruce Monroe Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003068	8/10/2023	8/10/2024	Ground Floor	Break Room	In Break Room 057	WF-08102023-003068	10/12/2023	FT-FY24-09182023-003068-A	<1	FT-FY24-09182023-003068-B	<1
WS- 003662	5/8/2023	5/8/2024	Ground Floor	Cooler	In classroom 007	WF-05082023-003662	10/12/2023	FT-FY24-09182023-003662-A	<1	FT-FY24-09182023-003662-B	<1
WS- 003664	5/8/2023	5/8/2024	Ground Floor	Cooler	In classroom 008	WF-05082023-003664	10/12/2023	FT-FY24-09182023-003664-A	<1	FT-FY24-09182023-003664-B	<1
WS- 003665	5/8/2023	5/8/2024	Ground Floor	Cooler	In hallway 037	WF-05082023-003665	10/12/2023	FT-FY24-09182023-003665-A	<1	FT-FY24-09182023-003665-B	<1
WS- 003666	5/8/2023	5/8/2024	Ground Floor	Cooler	In classroom 021	WF-05082023-003666	10/12/2023	FT-FY24-09182023-003666-A	<1	FT-FY24-09182023-003666-B	<1
WS- 003667	5/8/2023	5/8/2024	Ground Floor	Cooler	In classroom 022	WF-05082023-003667	10/12/2023	FT-FY24-09182023-003667-A	<1	FT-FY24-09182023-003667-B	<1
WS- 003670	5/8/2023	5/8/2024	1	Cooler	In hallway 156 adjacent to restroom	WF-05082023-003670	10/12/2023	FT-FY24-09182023-003670-A	<1	FT-FY24-09182023-003670-B	<1
WS- 003673	5/8/2023	5/8/2024	1	Cooler	In classroom 123	WF-05082023-003673	10/12/2023	FT-FY24-09182023-003673-A	<1	FT-FY24-09182023-003673-B	<1
WS- 003674	5/8/2023	5/8/2024	1	Cooler	In classroom 122	WF-05082023-003674	10/12/2023	FT-FY24-09182023-003674-A	<1	FT-FY24-09182023-003674-B	<1
WS- 003675	5/8/2023	5/8/2024	1	Cooler	In hallway 144	WF-05082023-003675	10/12/2023	FT-FY24-09182023-003675-A	<1	FT-FY24-09182023-003675-B	<1
WS- 003676	5/8/2023	5/8/2024	1	Health Suite	In health suite	WF-05082023-003676	10/12/2023	FT-FY24-09182023-003676-A	<1	FT-FY24-09182023-003676-B	<1
WS- 003677	5/8/2023	5/8/2024	1	Break Room	In staff lounge	WF-05082023-003677	10/12/2023	FT-FY24-09182023-003677-A	<1	FT-FY24-09182023-003677-B	<1
WS- 003679	5/8/2023	5/8/2024	1	Cooler	In hallway 151 adjacent to restroom	WF-05082023-003679	10/12/2023	FT-FY24-09182023-003679-A	<1	FT-FY24-09182023-003679-B	<1
WS- 003680	5/8/2023	5/8/2024	2	Cooler	In hallway 234 adjacent to restroom	WF-05082023-003680	10/12/2023	FT-FY24-09182023-003680-A	<1	FT-FY24-09182023-003680-B	<1
WS- 003681	5/8/2023	5/8/2024	2	Cooler	In hallway 229 adjacent to library	WF-05082023-003681	10/12/2023	FT-FY24-09182023-003681-A	<1	FT-FY24-09182023-003681-B	<1
WS- 003682	5/8/2023	5/8/2024	2	Cooler	In hallway 240 adjacent to restroom	WF-05082023-003682	10/12/2023	FT-FY24-09182023-003682-A	<1	FT-FY24-09182023-003682-B	<1
WS- 004281	5/8/2023	5/8/2024	Basement	Bottle Filler	In cafeteria	WF-05082023-004281	10/12/2023	FT-FY24-09182023-004281-A	<1	FT-FY24-09182023-004281-B	<1
WS- 004282	5/8/2023	5/8/2024	Basement	Cooler	In cafeteria	WF-05082023-004282	10/12/2023	FT-FY24-09182023-004282-A	<1	FT-FY24-09182023-004282-B	<1
WS- 004283	5/8/2023	5/8/2024	Basement	Cooler	In cafeteria	WF-05082023-004283	10/12/2023	FT-FY24-09182023-004283-A	<1	FT-FY24-09182023-004283-B	<1
WS- 004560	9/12/2023	9/12/2024	Ground Floor	Classroom Faucet	In classroom 022	WF-09122023-004560	10/12/2023	FT-FY24-09182023-004560-A	<1	FT-FY24-09182023-004560-B	<1
WS- 004561	9/12/2023	9/12/2024	Ground Floor	Classroom Faucet	In classroom 021	WF-09122023-004561	10/12/2023	FT-FY24-09182023-004561-A	<1	FT-FY24-09182023-004561-B	<1
WS- 004562	9/12/2023	9/12/2024	Ground Floor	Classroom Faucet	In classroom 024	WF-09122023-004562	10/12/2023	FT-FY24-09182023-004562-A	<1	FT-FY24-09182023-004562-B	<1
WS- 004563	9/12/2023	9/12/2024	Ground Floor	Classroom Faucet	In classroom 008	WF-09122023-004563	10/12/2023	FT-FY24-09182023-004563-A	1.1	FT-FY24-09182023-004563-B	<1
WS- 004564	9/12/2023	9/12/2024	Ground Floor	Classroom Faucet	In classroom 007	WF-09122023-004564	10/12/2023	FT-FY24-09182023-004564-A	1.4	FT-FY24-09182023-004564-B	<1
WS- 004565	9/12/2023	9/12/2024	Ground Floor	Classroom Faucet	In classroom 006	WF-09122023-004565	10/12/2023	FT-FY24-09182023-004565-A	<1	FT-FY24-09182023-004565-B	<1
WS- 004566	5/8/2023	5/8/2024	1	Bottle Filler	In hallway 156 adjacent to restroom	WF-05082023-004566	10/12/2023	FT-FY24-09182023-004566-A	<1	FT-FY24-09182023-004566-B	<1
WS- 004567	5/8/2023	5/8/2024	1	Bottle Filler	In hallway 144	WF-05082023-004567	10/12/2023	FT-FY24-09182023-004567-A	<1	FT-FY24-09182023-004567-B	<1
WS- 004568	5/8/2023	5/8/2024	1	Bottle Filler	In hallway 151 adjacent to restroom	WF-05082023-004568	10/12/2023	FT-FY24-09182023-004568-A	<1	FT-FY24-09182023-004568-B	<1
WS- 004569	5/8/2023	5/8/2024	2	Bottle Filler	In hallway 234 adjacent to restroom	WF-05082023-004569	10/12/2023	FT-FY24-09182023-004569-A	<1	FT-FY24-09182023-004569-B	<1
WS- 004570	5/8/2023	5/8/2024	2	Bottle Filler	In hallway 229 adjacent to library	WF-05082023-004570	10/12/2023	FT-FY24-09182023-004570-A	<1	FT-FY24-09182023-004570-B	<1
WS- 004571	5/8/2023	5/8/2024	2	Bottle Filler	In hallway 240 adjacent to restroom	WF-05082023-004571	10/12/2023	FT-FY24-09182023-004571-A	<1	FT-FY24-09182023-004571-B	<1
WS- 004572	5/8/2023	5/8/2024	2	Bottle Filler	In hallway across from 221	WF-05082023-004572	10/12/2023	FT-FY24-09182023-004572-A	<1	FT-FY24-09182023-004572-B	<1
WS- 004573	5/8/2023	5/8/2024	2	Cooler	In hallway across from 221	WF-05082023-004573	10/12/2023	FT-FY24-09182023-004573-A	<1	FT-FY24-09182023-004573-B	<1
WS- 004574	5/8/2023	5/8/2024	Ground Floor	Bottle Filler	In hallway 037	WF-05082023-004574	10/12/2023	FT-FY24-09182023-004574-A	<1	FT-FY24-09182023-004574-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003661	12/20/2022	12/20/2023	Ground Floor	Food Prep Sink	In kitchen	WF-12202022-003661	10/12/2023	FT-FY24-09182023-003661-A	<1	FT-FY24-09182023-003661-B	<1